

# Naturally

## Tokyo

*Found in translation?*

Mentors:

Dr. Regina Bokel  
Dr. Alejandro Prieto  
Dr. Ben Bronsema

Delegate of examiner:

Dr. Dirk van den Heuvel

P5 | 9 July 2021

Puji Nata Djaja | 5020379

A case study of Dutch

***Earth, Wind, and Fire***

system integration & optimization  
in an office building in Tokyo

"I want you to act as if the house is on fire, because it is."



it's hot






Figure 1 Sectoral Breakdown of energy-related CO2 emission (left) and energy consumption (right) in Tokyo in 2016 (Tokyo Metropolitan Government, 2019)

# Japan raises emissions reduction target to 46% by 2030

By MARI YAMAGUCHI April 22, 2021




(APnews.com, 2021)

## COMMENT

# Making Japan carbon neutral by 2050 is huge challenge

Technological innovations and bold social changes are called essential




(Asia.nikkei.com, 2021)

“Is the Dutch **Earth, Wind and Fire system (EWF)**,  
in place of the existing **air-conditioning system**,  
an efficient **energy-retrofitting method** to achieve  
**energy-neutrality** in an **office building in Tokyo** without  
compromising **thermal comfort** of users?”



**WIND:** Ventec/ Power Roof

*Energy production*



**EARTH:** Climate Cascade


Air supply

**FIRE:** Solar Chimney

Air exhaust

1. Over pressure room
2. Office rooms
3. Shunt duct
4. FiWiHex heat recovery
5. Auxiliary fan
6. Venturi ejector
7. Recirculation air damper
8. Heat storage
9. Equipment room





# The Four Elements Hotel, Amsterdam



# MFO-2 building, Erasmus University Rotterdam




Imperial  
Palace

Kogyogaien  
National Garden

Tokyo Station


Nihonbashi



Google




## Tokyo's Offices: Building Stock



■ Large ■ 20 years or older ■ Less than 20 years

## Space Availability



■ With Space ■ Without Space

*(Xymax Real Estate Institute , 2020)*


# EWF Integration Criteria

## Compulsory:

- Higher than its surrounding (for Power Roof)
- No load-bearing facades or walls
- Has sufficient load-bearing capacity for possible installation i.e. Power Roof

## Additional:

- Space availability on site
- Building height is over 15m
- Free-floor height
- Available vertical shaft
- etc





Google



# Case study: NK Building



South view



East view



# Case study: NK Building





North view





West view

# Case study: NK Building




<i>Location</i>	<i>1-16-3 Nihonbashi, Chuo-ku, Tokyo</i>
<i>Date of completion</i>	2016
<i>Total floor area</i>	5,116.39 m <sup>2</sup>
<i>Typical floor area</i>	391.30 m <sup>2</sup> / 118.37 tsubo
<i>Structure</i>	Steel structure, with vibration damping
<i>Building scale</i>	1 basement floor, 10 floors above ground
<i>Air-conditioning</i>	Individual air-conditioning
<i>Design</i>	Flying Pumpkins & Team FP


# Case study: NK Building



8-10



3-7



20.5 x 26 m


How do I design  
CC and SC?

*First:*

# Climate Analysis

# Excel calculation

# Climate Cascade (CC)



## CC Design Steps

### Climate analysis


- Temperature
- Relative humidity
- Ground water temperature

### Design parameter

- Air velocity
- Water/air factor (incl. no of spray heads)
- (With/without after-cooling)

### Outcome

- CC size
- Achieved pressure



# Climate Cascade (CC)

Tokyo

$\leq 16.5^{\circ}\text{C}$


cooling: when T outside air  $\geq 24^{\circ}\text{C}$

Scenario	Height [m]	Necessary Pressure [Pa]	No of spray-heads	Outgoing air temperature T33 [ $^{\circ}\text{C}$ ]	Achieved Pressure T24 [Pa]	Fan Energy [MWh]	Pump Energy [MWh] [kWh/m <sup>2</sup> ]	Heating Energy [MWh] [kWh/m <sup>2</sup> ]	Incoming water temperature	Cooling Energy [MWh] [kWh/m <sup>2</sup> ]	Amount of water [ton]	Total Energy [kWh/m <sup>2</sup> ]
1	<b>44</b>	100	<b>16</b>	16.4	307	0*	54 11	27 6	<b>13</b>	154 32	243,000	49
2	<b>44</b>	100	<b>10</b>	16.42	192	0*	34 7	33 7	<b>11</b>	199 42	152,000	56
3	<b>22</b>	100	<b>10</b>	16.42	96	0*	17 4	32 7	<b>11</b>	199 42	152,000	53
4	<b>22</b>	100	<b>12</b>	16.5	115	0*	20 4	28 6	<b>12</b>	177 37	182,000	47
5	<b>22</b>	100	<b>12</b>	16.87	115	0*	20 4	27 6	<b>12.5</b>	147 31	182,000	41
6	<b>22</b>	100	<b>9</b>	16.14	86	0*	15 3	36 8	<b>10</b>	226 48	137,000	59

\* Natural draft by EWF saved 1.68 MWh of Fan energy



# Climate Cascade (CC)



W x L x H : 1.08 x 1.08 x 44m  
Spray heads : 3 at the top (44 m)

9 at 22m

Pressure loss : 100 Pa

Air velocity : 3 m/s

Ventilation : 12,650 m<sup>3</sup>/h

50 m<sup>3</sup>/h/person

Air temperature into room : 16.5°C




Water temperature : Cooling mode 12.5°C (cooled)

Heating mode 15°C (ground temp.)


# Climate Cascade (CC)

Air						Water				Room		Pressure			n_sprayheads
$\theta_e$ -°C	$\varphi_e$ -%	$x_e$ -g/kg	$\theta_{uit}$ -°C	$\varphi_{uit}$ -%	$x_{uit}$ -g/kg	$\theta_{in}$ -°C	$\theta_{uit}$ -°C	Vin - m3/s	m_wat_in	$\theta_j$ -°C	$\varphi$ -%	$p_{hydr}$ -Pa	$p_{th}$ -Pa	$p_{tot}$ -Pa	
33	55	20.75	16.87	100.00	12.02	12.5	16.87	0.008	8.4	28	70.7	287.8	-11.4	299.2	12
30	66	17.69	16.77	100.00	11.94	12.5	16.77	0.006	6.3	28	70.2	215.9	-9.5	225.3	9
24	79	14.82	16.64	100.00	11.84	12.5	16.64	0.004	3.5	20	66.6	119.9	-5.4	125.3	5
18	71	9.13	15.28	96.05	10.40	15	14.91	0.001	0.7	20	60.4	24.0	-2.1	26.0	1
12	68	5.91	13.73	100.00	9.78	15	13.73	0.008	8.4	20	59.3	287.8	1.3	286.5	12
6	68	3.93	12.75	100.00	9.16	15	12.75	0.008	8.4	20	57.6	287.8	5.4	282.4	12
0	49	1.84	11.74	100.00	8.57	15	11.74	0.008	8.4	20	53.9	287.8	9.7	278.2	12
-2	50	1.59	11.49	100.00	8.43	15	11.49	0.008	8.4	20	53.0	287.8	11.2	276.6	12

# Solar Chimney (SC)





# Solar Chimney (SC)




W x L x H	: 0.65 x 2 x 44m x 2 chimney
Pressure loss	: 25 Pa
Air velocity	: 1.5 m/s
Heat recovery	: Microchannel

# Solar Chimney (SC)



# Solar Chimney (SC)



Months	Average of $T_e$ [°C]	Average of $Q$ [W/m <sup>2</sup> ]	Average of Thermal Draft [Pa]	Sum of Fan energy [MWh]	Sum of Heat Recovered [MWh]	Average of $T$ at top of SC
Off	15.00	21	8.84	0.04	21	20
Office hour	18.39	303	5.40	0.21	204	23
1	8.53	198	21.15	0.00	12	22
2	10.54	315	18.55	0.00	18	23
3	12.57	332	15.24	0.00	20	23
4	15.18	422	11.42	0.01	25	24
5	21.48	393	0.78	0.02	18	24
6	24.92	361	-4.99	0.03	14	24
7	25.49	234	-6.91	0.03	21	22
8	31.36	475	-14.10	0.04	18	25
9	25.73	256	-7.06	0.03	20	23
10	18.98	221	3.50	0.02	13	22
11	15.94	229	8.62	0.01	13	22
12	9.74	206	19.06	0.00	12	22
<b>Grand Total</b>	<b>16.55</b>	<b>150</b>	<b>7.27</b>	<b>0.25</b>	<b>225</b>	<b>21</b>

*Second:*

Integration  
(placement)

# 3 different proposals

## *Shouchikubai philosophy*

*Shou*

松

Pine

*Strength*

*Chiku*

竹

Bamboo

*Longevity*

*Bai*

梅

Plum

*Beauty*



(source: jing.fm)



# 3 different proposals

*Shouchikubai philosophy in design*

*Shou*

松

Pine

*Advanced*



*Chiku*

竹

Bamboo

*Moderate*

*Bai*


梅

Plum

*Basic*


(source: jing.fm)

# 3 different proposals




Basic design


RF



8-10




3-7




梅  
*Plum*

# 3 different proposals




Moderate design


RF



8-10




3-7




竹  
*Bamboo*

# 3 different proposals




Advanced design


RF



8-10



3-7



松  
Pine


# 3 different proposals

No.	Category	Plum	Bamboo	Pine
1	Performance (HR)	○	○	○
2	Material (quantity)	○	○	○
3	Visual comfort	△	△	✘
4	Maintenance	△	△	○
5	Space use	△	○	✘
6	Aesthetic	△	○	△


○ = 👍, △ = 😊, ✘ = 🗨️

Final Design

# Section





# Impressions





# Unitized SC



# Unitized SC

**Exhaust Shaft block (L x W x H: 2 x 0.65 x 4.2m )**  
Variation

**Heavy material**  
Lightweight concrete panel or ECP

**Lightweight material**  
Plywood or sandwich panel

**Transparent material**  
Glass or plexiglass

**All-around structural frame**  
Stainless steel or aluminium



Hook connection

**All-around transparent !**  
(further reserach)

**Combination frame**  
Stainless steel or aluminium  
frame with spider fitting


**...or...**  
Completely frameless &  
assemble on site, with protective  
layer that ensure airtightness added  
to cover the gap between module

**SC block (L x W x H: 2 x 0.65 x 4.2m )**  
Well-insulated glass






**Glass-to-glass connection (frameless)**  
Stainless-steel spider fitting


# Order of Assembly





# Order of Assembly




# Order of Assembly



# Details: connection within module






Detail A



Detail B

# DesignBuilder Simulation





# 3 different HVAC settings

No.		Existing	EWF design	Conventional
1	Construction	Wall 1 (SW & NW): ECP t60 R 0.14 Wall 2 (SE & NE): Curtain wall (DB template)		
2	Occupancy & Schedule	0.2 people/m <sup>2</sup>		
3	HVAC system	VRF with HR and DOAS	<u>Ventilation (mechanical):</u> VAV with no reheat, Constant air supply of 16.5°C <u>Space heating &amp; cooling:</u> Underfloor heating & chilled ceiling	VAV reheat, DX cooling with Dehumidification

# 2 different comparisons

No.		Existing	EWF design	Conventional
1	Construction		Wall 1 (SW & NW): ECP t60 R 0.14 Wall 2 (SE & NE): Curtain wall (DB template)	
2	Occupancy & Schedule		0.2 people/m <sup>2</sup>	
3	HVAC system	VRF with HR and DOAS	<u>Ventilation (mechanical):</u> VAV with no reheat, Constant air supply of 16.5°C <u>Space heating &amp; cooling:</u> Underfloor heating & chilled ceiling	VAV reheat, DX cooling with Dehumidification

# 4 different variations



	Variation 1	Existing	New	Variation 2	
<b>Ventilation amount</b>	50	25	50	25	m <sup>3</sup> /h/person
<b>Comfort design condition</b>					
Heating mode	22	22	20	20	°C
	40	40	40	40	% RH
Cooling mode	26	26	28	28	°C
	50	50	70	70	% RH

# Comparison 1: EWF – Existing (VRF)

	← <i>comfort</i> <b>Priority line</b> <i>energy</i> →			
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m3/h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

Comparison	Variation 1			Existing			New			Variation 2		
	Existing	EWF	%	Existing	EWF	%	Existing	EWF	%	Existing	EWF	%
Heating	3	15	<b>371</b>	2	14	<b>720</b>	3	10	<b>197</b>	2	10	<b>495</b> kWh/m2
Cooling	29	77	<b>164</b>	27	72	<b>161</b>	22	67	<b>205</b>	21	63	<b>201</b> kWh/m2
Ventilation	50	31	<b>-38</b>	29	29	<b>0</b>	48	25	<b>-47</b>	27	23	<b>-15</b> kWh/m2
Total	82	123	<b>50</b>	58	114	<b>96</b>	73	101	<b>39</b>	50	96	<b>94</b> kWh/m2

<u>Average difference %</u>		<u>Old &amp; New difference %</u>	
Heating	<b>446</b>	Heating	<b>475</b>
Cooling	<b>183</b>	Cooling	<b>143</b>
Ventilation	<b>-25</b>	Ventilation	<b>-14</b>
Total	<b>70</b>	Total	<b>74</b>

# Comparison 1: EWF – Existing (VRF)

	← <i>comfort</i> <b>Priority line</b> <i>energy</i> →			
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m3/h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
Cooling mode	40	40	40	40 % RH
	26	26	28	28 °C
	50	50	70	70 % RH

<i>Existing system</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	26	0	2102	2288 hours
Discomfort % in a year	0	0	24	26 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>76</b>	<b>74 %</b>
Hours at and above 29°C	0	0	41	0 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>
<i>EWF with climate ceiling</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	0	0	741	741 hours
Discomfort % in a year	0	0	8	8 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>92</b>	<b>92 %</b>
Hours at and above 29°C	0	0	0	0 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>


# Comparison 1: EWF – Existing (VRF)

← *comfort*      **Priority line**      *energy* →


	Variation 1	Existing	New	Variation 2
<b>Ventilation amount</b>	50	25	50	25 m3/h/person
<b>Comfort design condition</b>				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

Existing (VRF)

EWF



From top-left clockwise: Variation 1, Existing, New, and Variation 2.



From top-left clockwise: Variation 1, Existing, New, and Variation 2.

# Comparison 2: EWF – Conventional (VAV)

	Priority line			
	← comfort			energy →
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m3/h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

Comparison	Variation 1			Existing			New			Variation 2		
	Existing	EWF	%	Existing	EWF	%	Existing	EWF	%	Existing	EWF	%
Heating	72	15	-79	64	14	-79	2	10	414	1	10	626 kWh/m2
Cooling	152	77	-49	135	72	-47	89	67	-25	86	63	-27 kWh/m2
Ventilation	44	31	-29	44	29	-34	35	25	-28	35	23	-33 kWh/m2
Total	268	123	-54	243	114	-53	126	101	-19	122	96	-21 kWh/m2

Average difference %		Old & New difference %	
Heating	220	Heating	-85
Cooling	-37	Cooling	-50
Ventilation	-31	Ventilation	-43
Total	-37	Total	-58

# Comparison 2: EWF – Conventional (VAV)

	← <i>comfort</i> <b>Priority line</b> <i>energy</i> →			
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m <sup>3</sup> /h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

<i>Conventional system</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	0	0	851	851 hours
Discomfort % in a year	0	0	10	10 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>90</b>	<b>90 %</b>
Hours at and above 29°C	0	0	0	0 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>
<i>EWF with climate ceiling</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	0	0	741	741 hours
Discomfort % in a year	0	0	8	8 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>92</b>	<b>92 %</b>
Hours at and above 29°C	0	0	0	0 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>




# Comparison 2: EWF – Conventional (VAV)


	← <i>comfort</i> <b>Priority line</b> <i>energy</i> →			
	Variation 1	Existing	New	Variation 2
<b>Ventilation amount</b>	50	25	50	25 m3/h/person
<b>Comfort design condition</b>				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

Conventional (VAV)

EWF



From top-left clockwise: Variation 1, Existing, New, and Variation 2.



From top-left clockwise: Variation 1, Existing, New, and Variation 2.

# Energy neutrality & benchmarking

# Power Roof: PV Yield

Optimistic



Realistic



## SYSTEM INFO

Modify the inputs below to run the simulation.

DC System Size (kW):	<input type="text" value="62.4"/>
Module Type:	<input type="text" value="Premium"/> ⓘ
Array Type:	<input type="text" value="Fixed (roof mount)"/> ⓘ
System Losses (%):	<input type="text" value="14.08"/>
Tilt (deg):	<input type="text" value="40"/>
Azimuth (deg):	<input type="text" value="135"/>



(PVWatts® Calculator )

(Grasshopper)

# Zero energy?

<b>Annual energy consumption per m<sup>2</sup></b>	Existing	New
Heating	2	10 kWh/m <sup>2</sup>
Cooling	27	67 kWh/m <sup>2</sup>
Ventilation	29	25 kWh/m <sup>2</sup>
Lighting	81	81 kWh/m <sup>2</sup>
Computers etc.	56	56 kWh/m <sup>2</sup>
<b>Total energy consumption per m<sup>2</sup></b>	<b>196</b>	<b>239 kWh/m<sup>2</sup></b>
<b>Annual energy production per m<sup>2</sup></b>		
BAPV on Power Roof ( <i>optimistic</i> )	0	172 kWh/m <sup>2</sup>
% to energy consumption	0	72 %
BAPV on Power Roof ( <i>realistic</i> )	0	56 kWh/m <sup>2</sup>
% to energy consumption	0	24 %

Not zero energy

# Benchmarking: Primary energy

<b>Annual energy consumption per m<sup>2</sup> (primary energy)</b>	Existing	New	%
Heating	4	10	<b>155</b> MJ/m <sup>2</sup>
Cooling	87	33	<b>-51</b> MJ/m <sup>2</sup>
Ventilation	283	244	<b>-14</b> MJ/m <sup>2</sup>
Lighting	794	794	<b>0</b> MJ/m <sup>2</sup>
Computers etc.	551	551	<b>0</b> MJ/m <sup>2</sup>
<b>Total energy consumption per m<sup>2</sup> (primary energy)</b>	<b>1699</b>	<b>1631</b>	<b>-4</b> MJ/m <sup>2</sup>

Note:

Primary energy coefficients: Electricity: 9.76 MJ/kWh, City gas: 45 MJ/m<sup>3</sup>

COP used are as follows:

Existing heating (VRF) 4, existing cooling (VRF) 4

New heating (GSHP) 9, new cooling (direct groundsource) 20


**Below average**

# Benchmarking: Carbon Report

95.4 kg-CO<sub>2</sub>/m<sup>2</sup>  
(Range B2)

Medium-sized Buildings for Rent (3,000 m<sup>2</sup> or larger but smaller than 10,000 m<sup>2</sup>)

Range	Basis	Emission Intensity (kg / m <sup>2</sup> )	Number of Facilities	Percentage	Average Floor Area		
A4	0.25 or less	19.6 or less	7	0.7%	4988.83		
A3	More than 0.25 but 0.50 or less	More than 19.6 but 39.1 or less	58	6.1%	5063.63		
A2	More than 0.50 but 0.75 or less	More than 39.1 but 58.6 or less	250	26.2%	5526.83		
A1	More than 0.75 but 1.00 or less	More than 58.6 but 78.1 or less	321	33.7%	5444.23		
B2	More than 1.00 but 1.25 or less	More than 78.1 but 97.7 or less	153	16.1%	5930.80		
B1	More than 1.25 but 1.50 or less	More than 97.7 but 117.2 or less	70	7.3%	5981.22		
C	More than 1.50	More than 117.2	94	9.9%	5537.81		
		Average intensity	78.1	Total	953	100%	5566.20



**BELOW AVERAGE**

(TMG, 2012)


Improvement

*Hybrid system:*

EWF with chilled  
beams



# Comparison 3: EWF – EWF with chilled beams



# Comparison 3: EWF – EWF with chilled beams

	Priority line			
	← comfort			energy →
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m3/h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
Cooling mode	40	40	40	40 % RH
	26	26	28	28 °C
	50	50	70	70 % RH

Comparison	Variation 1			Existing			New			Variation 2		
	EWF	EWF2	%	EWF	EWF2	%	EWF	EWF2	%	EWF	EWF2	%
Heating	15	4	-74	14	4	-71	10	4	-62	10	4	-66 kWh/m2
Cooling	77	81	5	72	81	3	67	73	10	63	73	16 kWh/m2
Ventilation	31	31	0	29	29	0	25	25	0	23	23	0 kWh/m2
Total	123	116	-5	114	114	0	101	102	0	96	100	4 kWh/m2

Energy: marginally better

Average difference %	
Heating	-69
Cooling	11
Ventilation	0
<b>Total</b>	<b>-1</b>

Old & New difference %	
Heating	-74
Cooling	2
Ventilation	-14
<b>Total</b>	<b>-11</b>

# Comparison 3: EWF – EWF with chilled beams

	← <i>comfort</i> <b>Priority line</b> <i>energy</i> →			
	Variation 1	Existing	New	Variation 2
Ventilation amount	50	25	50	25 m3/h/person
Comfort design condition				
Heating mode	22	22	20	20 °C
Cooling mode	40	40	40	40 % RH
	26	26	28	28 °C
	50	50	70	70 % RH

<i>EWF with climate ceiling</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	0	0	741	741 hours
Discomfort % in a year	0	0	8	8 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>92</b>	<b>92 %</b>
Hours at and above 29°C	0	0	0	0 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>
<i>EWF with chilled beams</i>	Variation 1	Existing	New	Variation 2
Hours at and above 27°C	33	33	50	50 hours
Discomfort % in a year	0	0	1	1 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>99</b>	<b>99 %</b>
Hours at and above 29°C	0	3	3	3 hours
Discomfort % in a year	0	0	0	0 %
<b>Comfort % in a year</b>	<b>100</b>	<b>100</b>	<b>100</b>	<b>100 %</b>



# Comparison 3: EWF – EWF with chilled beams

← *comfort*      **Priority line**      *energy* →

	Variation 1	Existing	New	Variation 2
<b>Ventilation amount</b>	50	25	50	25 m3/h/person
<b>Comfort design condition</b>				
Heating mode	22	22	20	20 °C
	40	40	40	40 % RH
Cooling mode	26	26	28	28 °C
	50	50	70	70 % RH

EWF

EWF with chilled beams



Comfort: better!


From top-left clockwise: Variation 1, Existing, New, and Variation 2.

From top-left clockwise: Variation 1, Existing, New, and Variation 2.


Reuse heat/cold:

# Heat Recovery

# Summer scheme



# Winter scheme



# Algorithm


<b>Seasons</b>	<b>Te&lt;=Thr</b>	<b>Te&gt;Thr</b>	<b>Total</b>
Autumn	1505	679	2184 if [Te >= 16.5 AND Thr >= 16.5] then [min between Te&Thr], else if Te <= 16.5 then [default], else [min between Te&Thr]
Spring	2069	139	2208 if [Te >= 16.5 AND Thr >= 16.5] then [min between Te&Thr], else if Te <= 16.5 then [default], else [min between Te&Thr]
Summer	309	1899	2208 Choose the minimum between Te and Thr (ignore 16.5)
Winter	2184		2184 Always ignore Te, choose the minimum between Thr and 16.5
Total hours in 2020			8784 [default]=minimum between "16.5", and "that which is closest to 16.5"



# Examples

No	Date & time	Te	Thr	relation	CC Tin
1	01/01/2020 10:00	5.8	18.8	Te<=Thr	16.5
2	06/02/2020 13:00	6.1	21.7	Te<=Thr	16.5
3	22/03/2020 15:00	21.8	24.7	Te<=Thr	21.8
4	17/04/2020 17:00	14.9	20.5	Te<=Thr	16.5
5	14/05/2020 18:00	22	23.0	Te<=Thr	22
6	11/06/2020 09:00	27.3	27.1	Te>Thr	27.1
7	20/07/2020 13:00	30.7	28.3	Te>Thr	28.3
8	05/08/2020 15:00	33.4	30.1	Te>Tr	30.1
9	06/09/2020 20:00	25.6	23.1	Te>Tr	23.1
10	04/10/2020 09:00	20.7	22.5	Te<=Tr	20.7
11	21/11/2020 20:00	13.8	19.5	Te<=Tr	16.5
12	29/12/2020 20:00	8.3	17.8	Te<=Tr	16.5

# Results




Heat/cold reuse: success!

<u>HR - energy saving</u>	<u>X</u>	<u>✓</u>	<u>%</u>
Heating	6	5	-23 kWh/m <sup>2</sup>
Cooling	11	4	-59 kWh/m <sup>2</sup>

*Comparizon*


Tokyo - Amsterdam

Pre-cool the water is necessary




Tokyo

Pre-cool the water is NOT necessary




Amsterdam

External heating energy is less



Tokyo

External heating energy is more



Amsterdam

Tokyo

 $\leq 16.5^{\circ}\text{C}$ cooling: when T outside air  $\geq 24^{\circ}\text{C}$ 

Scenario	Height [m]	Necessary Pressure [Pa]	No of spray-heads	Outgoing air temperature T33 [ $^{\circ}\text{C}$ ]	Achieved Pressure T24 [Pa]	Fan Energy [MWh]	Pump Energy [MWh] [kWh/m <sup>2</sup> ]	Heating Energy [MWh] [kWh/m <sup>2</sup> ]	Incoming water temperature	Cooling Energy [MWh] [kWh/m <sup>2</sup> ]	Amount of water [ton]	Total Energy [kWh/m <sup>2</sup> ]
1	44	100	16	16.4	307	0*	54 11	27 6	13	154 32	243,000	49
2	44	100	10	16.42	192	0*	34 7	33 7	11	199 42	152,000	56
3	22	100	10	16.42	96	0*	17 4	32 7	11	199 42	152,000	53
4	22	100	12	16.5	115	0*	20 4	28 6	12	177 37	182,000	47
5	22	100	12	16.87	115	0*	20 4	27 6	12.5	147 31	182,000	41
6	22	100	9	16.14	86	0*	15 3	36 8	10	226 48	137,000	59

\* Natural draft by EWF saved 1.68 MWh of Fan energy

Tokyo: 51 kWh/m<sup>2</sup>

in average -&gt;

51

Amsterdam

 $\leq 18^{\circ}\text{C}$ cooling: when T outside air  $\geq 24^{\circ}\text{C}$ 

Scenario	Height [m]	Necessary Pressure [Pa]	No of spray-heads	Outgoing air temperature T28 [ $^{\circ}\text{C}$ ]	Achieved Pressure T24 [Pa]	Fan Energy [MWh]	Pump Energy [MWh] [kWh/m <sup>2</sup> ]	Heating Energy [MWh] [kWh/m <sup>2</sup> ]	Incoming water temperature T24 [ $^{\circ}\text{C}$ ]	Cooling Energy [MWh] [kWh/m <sup>2</sup> ]	Amount of water [ton]	Total Energy [kWh/m <sup>2</sup> ]
1	44	100	4	16.8	150	0*	18 4	85 18	13	0 0	82,000	22


\* Natural draft by EWF saved 1.62 MWh of Fan energy

Amsterdam: 22 kWh/m<sup>2</sup>

Tokyo


Amsterdam

Thermal draft is less, fan energy is more



Tokyo

Thermal draft is more, fan energy is less



Amsterdam



More heat recovered for reuse

Less heat recovered for reuse

<i>Solar Chimney</i>	TYO	AMS
Fan energy	0.1	0.0 kWh/m <sup>2</sup>
Heat recovered	48	37 kWh/m <sup>2</sup>



Tokyo




Amsterdam




# Urban setting

Compact, tight in space



Tokyo

Less compact, less tight in space



Amsterdam

# Comparison study


37% building related energy reduction

44% electric energy reduction

Comparison	Variation 1			Existing			New			Variation 2		
	Existing	EWf	%	Existing	EWf	%	Existing	EWf	%	Existing	EWf	%
Heating	72	15	-79	64	14	-79	2	10	414	1	10	626 kWh/m2
Cooling	152	77	-49	135	72	-47	89	67	-25	86	63	-27 kWh/m2
Ventilation	44	31	-29	44	29	-34	35	25	-28	35	23	-33 kWh/m2
Total	268	123	-54	243	114	-53	126	101	-19	122	96	-21 kWh/m2

Average difference %	Old & New difference %
Heating	220
Cooling	-37
Ventilation	-31
Total	-37

Found in translation? 🤔



(Teeling, 2020)



Tokyo



Amsterdam

Conclusion

# Answering the research question

“Is the Dutch **Earth, Wind and Fire system** (EWF),  
in place of the existing **air-conditioning system**,  
an efficient **energy-retrofitting method** to achieve **energy-neutrality** in an **office building in Tokyo**  
without compromising **thermal comfort** of users?”

**No**, it is **not efficient** at all for the case of NK Building, as it turned out that the existing air-conditioning system is already energy efficient.

However, **as a ventilation system**, EWF contributed to **15% energy reduction** proving the fact that the natural ventilation concept of EWF works.

**Thermal comfort is also improved**, from 75% to 92% comfort hours, with more balance temperature distribution.

# Elaboration

“Is the Dutch **Earth, Wind and Fire system** (EWF),  
in place of the existing **air-conditioning system**,

an efficient **energy-retrofitting method** to achieve **energy-neutrality** in an **office building in Tokyo**  
without compromising **thermal comfort** of users?”

Moreover, when **compared to a conventional air-conditioning system**, EWF uses **40% less energy**  
overall, with better thermal comfort.

On the other hand, **energy neutrality is not achieved**, and is very challenging without reducing  
the energy consumption first.

# Limitation

- COVID-19 pandemic
- Accuracy of simulating EWF in DB

# Recommendation

- Many *exciting* topic for follow up research:
  - EWF design without ATES -> use chiller to cool the CC water in Tokyo or other cities with similar climate
  - Integration of unitized SC with PV, PV/T, or Thermal Collector -> prioritizing electricity or heat gain
  - And more...
- Develop a standardized and easy-to-use Excel calculation for both CC and SC
- New template for EWF in DB, or any other dynamic simulation software

"I want you to act as if the house is on fire, otherwise..."

... comfort will be a luxury

... it's getting even hotter!

... the relation between human & nature is getting worse

... *(fill your own answer)*





*Thank you!*

Dank u wel!

ご清聴ありがとうございます