


de-VAP

Decentralized Desiccant Enhanced Evaporative
cooling integrated facade

PRETHVI RAJ // 4738659


Sustainable Design Graduation Studio
1st Mentor Façade Design : Dr. Alejandro Prieto
2nd Mentor Climate Design : Dr. WH Van der spoel
July 2019

Decentralized Desiccant Enhanced Evaporative Cooling Integrated Facade




2/3rd

Office stock is yet to
be built in India



50%

Energy consumption in
Indian Offices is HVAC




8x
Space Cooling
Demand in India




3x

Electricity consumption
of the national figure
of 90 kWh




25%

Reduction of
Cooling Demand after
Intervention by Indian
Govt.




DESICCANT COOLING

STULZ Indirect Evaporative Cooling Equipment (STULZ IceCE)
Heat Exchanger Operation
in Wet Mode



INDIRECT EVAPORATIVE COOLING




RADIANT COOLING



GEOHERMAL COOLING




STRUCTURE COOLING



VAPOUR ABSORPTION


Not in Kind

Cooling Upcoming Technologies - Low Energy Consumption - Cooling Systems




DESICCANT COOLING

STULZ Indirect Evaporative Cooling Equipment (STULZ IceC)
Heat Exchanger Operation
In Wet Mode



INDIRECT EVAPORATIVE COOLING




RADIANT COOLING



GEO THERMAL COOLING




STRUCTURE COOLING



VAPOUR ABSORPTION




HOSPITAL GENERAL DR. MANUEL GEA GONZÁLEZ, MEXICO




DESICCANT COOLING

STULZ Indirect Evaporative Cooling Equipment (STULZ Ice) Heat Exchanger Operation In Wet Mode



INDIRECT EVAPORATIVE COOLING




RADIANT COOLING



GEO THERMAL COOLING




STRUCTURE COOLING



VAPOUR ABSORPTION




AL BAHR TOWERS, ABU DHABI




DESICCANT COOLING

STULZ Indirect Evaporative Cooling Equipment (STULZ IceC)
Heat Exchanger Operation
In Wet Mode



INDIRECT EVAPORATIVE COOLING




RADIANT COOLING



GEO THERMAL COOLING



STRUCTURE COOLING




VAPOUR ABSORPTION




eat me

EAT ME WALL




DESICCANT COOLING

STULZ Indirect Evaporative Cooling Equipment (STULZ IceC)
Heat Exchanger Operation
In Wet Mode



INDIRECT EVAPORATIVE COOLING




RADIANT COOLING



GEOTHERMAL COOLING



STRUCTURE COOLING



VAPOUR ABSORPTION




POST TOWERS, BONN




Decentralized


Ventilation




Centralized Systems




Centralized Systems




Centralized / Decentralized system




Decentralized system - No Ducts




Supply Air




Supply Air
Return Air




Recirculation



Heat Recovery



Heating
Cooling




Humidification
Dehumidification

Decentralized systems are smart




*“ To what extent a **decentralized evaporative cooling** system can be integrated on a façade to reduce the cooling demand of offices in Delhi (composite climate) ? ”*

Centralized / Decentralized system




Sub - Research questions



Context:

1. What are the desired passive strategies that need to be integrated in a Composite climate (Delhi) for thermal comfort and air quality requirements for Delhi?


Sub - Research questions




Context:

1. What are the desired passive strategies that need to be integrated in a Composite climate (Delhi) for thermal comfort and air quality requirements for Delhi?


Sub - Research questions




Sub - Research questions




Sub - Research questions



Sub - Research questions




Sub - Research questions



■ Semi-arid climate (BSH, BSk)

■ Humid subtropical climate (Cwa, Cfa)


Koppen Climate Classification




Climate Of Delhi




Evaporative Cooling




Direct



Indirect




Dew-Point



Combined


Types



Direct

HUMIDITY
Increases


WB
Effectiveness
70% - 85%



Indirect

HUMIDITY
Neutral


WB
Effectiveness
40% - 60%



Dew-Point

HUMIDITY
Neutral

WB
Effectiveness
92% - 114%




Combined

HUMIDITY
Increases

WB
Effectiveness
109% - 116%


Types



Direct

HUMIDITY
Increases


WB
Effectiveness
70% - 85%



Indirect

HUMIDITY
Neutral


WB
Effectiveness
40% - 60%



Dew-Point

HUMIDITY
Neutral

WB
Effectiveness
92% - 114%




Combined

HUMIDITY
Increases

WB
Effectiveness
109% - 116%

Types




Wet Pad

Direct

HUMIDITY
Increases


WB
Effectiveness
70% - 85%



Indirect


HUMIDITY
Neutral

WB
Effectiveness
40% - 60%



Dew-Point


Complex Air flow
Less Primary air




Combined

Size
55% more water consumption
More components
Cost


Types




Direct



Indirect




**Dew-Point
Indirect Evaporative
Cooling**





Combined

Types



Dewpoint Indirect Evaporative Cooling



5mm
Channel Gap

> 1m
Channel Length

122%
WB Efficiency

Cooler Size

Sizing?



$$Q = M * C_p * \Delta T$$

$$V = Q / \rho * C_p * (T_{\text{set}} - T_{\text{sup}})$$

Cooling Capacity

$$Q = M * C_p * \Delta T$$

$$V = Q / \rho * C_p * (T_{set} - T_{sup})$$

Volume flow rate

Volume flow rate

Cooling Capacity

Cooling Capacity

Temp. Difference

Temp. Difference

Cooling Capacity


$$Q = M * C_p * \Delta T$$
$$V = Q / \rho * C_p * (T_{set} - T_{sup})$$

Cooling Capacity (Q)
(Building)

Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)

Size
of the
Systems

Cooling Capacity




Cooling Capacity (Q)
(Building)


Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)

Size
of the
Systems

Sizing The System




Cooling Capacity (Q)
(Building)




Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)

Size
of the
Systems

Sizing The System



Cooling Capacity (Q)
(Building)




Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)


Sizing The System

Size
of the
Systems





Cooling Capacity (Q)
(Building)



Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)

Size
of the
Systems

Sizing The System



Name	Wipro	VECH	IPB	SkyView
Year	2005	2012	2014	2015
WWR%	33	80	20	55
Glazing	1.8	2.1	1.8	1.8
Solid	0.6	1.1	0.5	1.1
Shading	Horizontal louvers	Louvers	Recessed	No Shading
LPD	5.4	4	5	9.5
Cooling	Central	HVAC underfloor	Geothermal	Central
EPI 179 kWh/m ² /year	85	96	45.25	112

Energy Efficient Buildings In Composite Climate

				
Name	Wipro	VECH	IPB	SkyView
Year	2005	2012	2014	2015
WWR%	33	80	20	55
Glazing	1.8	2.1	1.8	1.8
Solid	0.6	1.1	0.5	1.1
Shading	Horizontal louvers	Louvers	Recessed	No Shading
LPD	5.4	4	5	9.5
Cooling	Central	HVAC underfloor	Geothermal	Central
EPI 179 kWh/m ² /year	85	96	45.25	112

Energy Efficient Buildings In Composite Climate

				
Name	Wipro	VECH	IPB	SkyView
Year	2005	2012	2014	2015
WWR%	33	80	20	55
Glazing	1.8	2.1	1.8	1.8
Solid	0.6	1.1	0.5	1.1
Shading	Horizontal louvers	Louvers	Recessed	No Shading
LPD	5.4	4	5	9.5
Cooling	Central	HVAC underfloor	Geothermal	Central
EPI 179 kWh/m ² /year	85	96	45.25	112

Energy Efficient Buildings In Composite Climate



Name	Wipro	VECH	IPB	SkyView
Year	2005	2012	2014	2015
WWR%	33	80	20	55
Glazing	1.8	2.1	1.8	1.8
Solid	0.6	1.1	0.5	1.1
Shading	Horizontal louvers	Louvers	Recessed	No Shading
LPD	5.4	4	5	9.5
Cooling	Central	HVAC underfloor	Geothermal	Central
EPI 179 kWh/m ² /year	85	96	45.25	112

Energy Efficient Buildings In Composite Climate



Name	Wipro	VECH	IPB	SkyView
Year	2005	2012	2014	2015
WWR%	33	80	20	55
Glazing	1.8	2.1	1.8	1.8
Solid	0.6	1.1	0.5	1.1
Shading	Horizontal louvers	Louvers	Recessed	No Shading
LPD	5.4	4	5	9.5
Cooling	Central	HVAC underfloor	Geothermal	Central
EPI 179 kWh/m ² /year	85	96	45.25	112

Energy Efficient Buildings In Composite Climate



DLF Cyber City, Gurgaon



GLAZING IS COMING


DLF Cyber City, Gurgaon



Sky View, Gurgaon



Sky View, Gurgaon



Passive Strategies

WWR
60%

Location
New Delhi


Floor Area
1792m²

Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW

Cooling load
per m²
kW/m²



WWR
60%

Location
New Delhi

Floor Area
1792m²

Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW


Cooling load
per m²
W/m²

Base Case

343.2

190.72

109.6



WWR
60%

Location
New Delhi

Floor Area
1792m²

Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW

Cooling load per m²
W/m²


Base Case

343.2	190.72	109.6
--------------	---------------	--------------

Ventilation / Internal heat gains

183.4	145.6	83.4
-------	-------	------

25%



WWR
60%

Location
New Delhi



Floor Area
1792m²

Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW

Cooling load
per m²
W/m²



WWR
60%

Location
New Delhi

Floor Area
1792m²

Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW



Cooling load
per m²
W/m²

Base Case
343.2 **190.72** **109.6**

Ventilation / Internal heat gains
183.4 145.6 83.4

U-Value
168.54 100.3 57.2

Shading Strategy
151.35 89.3 51.3
157.45 95.4 54.4
146.41 **87.65** **50**



WWR
60%

Location
New Delhi

Floor Area
1792m²


Orientation
Longer axis N-S

Energy Performance Index
kWh/m²/year

Cooling Capacity
kW

Cooling load per m²
W/m²


	Energy Performance Index kWh/m ² /year	Cooling Capacity kW	Cooling load per m ² W/m ²
Base Case	343.2	190.72	109.6
Ventilation / Internal heat gains	183.4	145.6	83.4
U-Value	168.54	100.3	57.2
Shading Strategy	151.35	89.3	51.3
	157.45	95.4	54.4
Shading Strategy	146.41	87.65	50



50%




Cooling Capacity (Q)
(Building)




Diff. in Temp (ΔT)
(Set Temp. - Supply Temp.)

Size
of the
Systems

Sizing The System



**Design
Expectation**




VS



Design
Expectation

Design
Reality






*Moisture In The Air - Evaporative coolers **WORST** Enemy*

Climate Of Delhi

AUGUST - DELHI

30°C
Drybulb temperature
27°C
Wetbulb temperature





26.3°C
Supply temperature

122%
WB Efficiency



High Humidity

AUGUST - DELHI



High Humidity

AUGUST - DELHI




NO EFFECTIVE COOLING

High Humidity

Dehumidification



Cooling Coil




Desiccant System

Dehumidification Strategies




Cooling Coil




Desiccant System

Dehumidification Strategies




Desiccant Coated Heat Exchanger

De-humidification




Regeneration



DCHE - Cycle

De-humidification

Regeneration



DCHE - Cycle

B e f o r e

30°C
Drybulb temperature

25°C
Setpoint temperature

122%
WB Efficiency

A f t e r

0.014 kg/kg
Humidity Ratio



26.3°C
Supply temperature

*Desiccant
Coated Heat
Exchanger*

After Dehumidification

Before

30°C
Drybulb temperature

25°C
Setpoint temperature


122%
WB Efficiency

After

0.014 kg/kg
Humidity Ratio



26.3°C
Supply temperature



*Desiccant
Coated Heat
Exchanger*

After Dehumidification

Before

30°C
Drybulb temperature

25°C
Setpoint temperature


122%
WB Efficiency

After

0.014 kg/kg
Humidity Ratio



26.3°C
Supply temperature



*Desiccant
Coated Heat
Exchanger*




0.009 kg/kg
Humidity Ratio




16°C
Supply temperature

After Dehumidification



Yearly Supply Temperature


$$Q = M * C_p * \Delta T$$
$$V = Q / \rho * C_p * (T_{set} - T_{sup})$$



Cooling Capacity (Q)

(Building)

87.65 kW



Diff. in Temp (ΔT)

(Set Temp. - Supply Temp.)

9°C

Size
of the
Systems

8.19 m³/s
Volume Flow rate

Sizing The System

Area of Opening = Volume flow rate / Velocity

8.19 m³/s

Volume Flow rate

1.5 m/s

Velocity

Opening Size


$$\text{Area of Opening} = \text{Volume flow rate} / \text{Velocity}$$

8.19 m³/s

Volume Flow rate

1.5 m/s

Velocity



5.46 m²

Opening Required

Opening Size


$$\text{Area of Opening} = \text{Volume flow rate} / \text{Velocity}$$

8.19 m³/s

Volume Flow rate


1.5 m/s

Velocity



5.46 m²

Opening Required




0.15 m²

Opening of cooler

Opening Size



36
Devices
per floor





36
Devices
per floor


Design

Climate



Facade



Cooler Design





System Design





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process





- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Process





- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process



- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air


Process




- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Process



Facade Concepts




Sill Integrated



Wall Integrated





Initial Concepts




36
No. of Devices
/ per floor

Sill Integrated




18
No. of Devices
/ per floor

Wall Integrated





Initial Concepts




36
No. of Devices
/ per floor

Sill Integrated




18
No. of Devices
/ per floor

Wall Integrated




Initial Concepts


Outlet Design



**Displacement
Ventilation**




**Mixed/Displacement
Ventilation**




**Mixed
Ventilation**

Ventilation Strategy




Ventilation Strategy




Results


Displacement



Mixed+Displacement



Mixed






Temperature Distribution @ 0.4m

Displacement

Mixed+Displacement

Mixed






Temperature Distribution @ 0.4m

Displacement

Mixed+Displacement

Mixed






Temperature Distribution @ 1.1m


Displacement

Mixed+Displacement

Mixed




Temperature Distribution @ 1.8m



Displacement
Ventilation




Mixed/Displacement
Ventilation




Mixed
Ventilation

Ventilation Strategy


Thermal Resistance




Standalone System



100mm XPS




150mm Concrete



**150mm Concrete +
100mmXPS**






Standalone System

Inside




Outside




100mm XPS

Inside




Outside




150mm Concrete

Inside




Outside




**150mm Concrete +
100mmXPS**

Inside



Outside




Thermal Performance




Standalone System

Inside




Outside




100mm XPS

Inside




Outside




150mm Concrete

Inside




Outside




150mm Concrete +
100mmXPS

Inside




Outside




Thermal Performance

Final Design




Wall Integrated System
2.7m high




Shade Integrated System
3.0m high

Final Designs




- Ⓐ Re-circulated air
 Ⓑ After Mixing
 Ⓒ Outdoor Air
 Ⓓ De-humidified air
 Ⓔ Supply Air
 Ⓕ Room Condition
 Ⓖ Exhaust Air

Variation 01 - Wall System





- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Variation 01 - Wall System




- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Variation 01 - Wall System




- A** Re-circulated air
 B After Mixing
 C Outdoor Air
 D De-humidified air
 E Supply Air
 F Room Condition
 G Exhaust Air

Variation 01 - Wall System




- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Variation 01 - Wall System




Advantages




Advantages - Height Reduction




Wall Integrated System




Wall Integrated System



Wall Integrated System




Wall Integrated System



Wall Integrated System




Wall Integrated System




Wall Integrated System




Wall Integrated System




Design Variations



Design Variations




DeVAP
Exterior view




DeVAP
Interior view



Wall Integrated System
2.7m high




Shade Integrated System
3.0m high




- A Re-circulated air
- B After Mixing
- C Outdoor Air
- D De-humidified air
- E Supply Air
- F Room Condition
- G Exhaust Air

Variation 02 - Shade System




- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Variation 02 - Shade System




- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air

Variation 02 - Shade System




- A Re-circulated air
 B After Mixing
 C Outdoor Air
 D De-humidified air
 E Supply Air
 F Room Condition
 G Exhaust Air

Variation 02 - Shade System




- A** Re-circulated air
- B** After Mixing
- C** Outdoor Air
- D** De-humidified air
- E** Supply Air
- F** Room Condition
- G** Exhaust Air


Variation 02 - Shade System




Shade Integrated System




Shade Integrated System




Shade Integrated System




Shade Integrated System




Shade Integrated System




Shade Integrated System




Shade Integrated System




Shade Integrated System



Shade Integrated System




DeVAP
Exterior view



DeVAP
Interior view

No. Passive Strategy



57.8
WWR

115.1 W/m²
Cooling load per m²

77
No. of Devices

No. of Devices vs Cooling Load



Lighting




Equipment



Fresh air



Infiltration



68

WWR

84.2 W/m²

Cooling load per m²

57

No. of Devices

No. of Devices vs Cooling Load

Ventilation / Internal heat gains



Lighting



Equipment



Fresh air



Infiltration

U-Value




Wall



Glazing



Roof



76

WWR

64 W/m²

Cooling load per m²

43

No. of Devices

No. of Devices vs Cooling Load

Ventilation / Internal heat gains



Lighting



Equipment



Fresh air



Infiltration

U-Value



Wall



Glazing



Roof

Shading Strategy




Horizontal



Vertical



Egg Crate



80

WWR

55 W/m²

Cooling load per m²

37

No. of Devices

No. of Devices vs Cooling Load

Ventilation / Internal heat gains



Lighting



Equipment



Fresh air



Infiltration

U-Value



Wall



Glazing



Roof

Shading Strategy




Horizontal



Vertical



Egg Crate



80
WWR

55 W/m²
Cooling load per m²

37
No. of Devices

No. of Devices vs Cooling Load




40 WWR

Case 1

Cooling load
178 kW

Cooling load per m²
102.7 W/m²

No. of Devices per floor
70




Case 3

Cooling load
96.9 kW

Cooling load per m²
55.7 W/m²

No. of Devices per floor
37




Case 2

Cooling load
142 kW

Cooling load per m²
81.6 W/m²

No. of Devices per floor
55




Case 4

Cooling load
82.5 kW

Cooling load per m²
47.4 W/m²

No. of Devices per floor
32



Design Variation @ 40WWR




60 WWR

Case 1

Cooling load
190.7 kW

Cooling load per m²
109.6 W/m²

No. of Devices per floor
75




Case 3

Cooling load
99.5 kW

Cooling load per m²
57.2 W/m²

No. of Devices per floor
38




Case 2

Cooling load
144.9 kW

Cooling load per m²
83.3 W/m²

No. of Devices per floor
56




Case 4

Cooling load
87.0 kW


Cooling load per m²
50.0 W/m²

No. of Devices per floor
33



Design Variation @ 60WWR

Energy



New Delhi



Energy



Heat

Solar Integration




Energy




Heat

Solar Integration



Module



Roof

PV Integration

Maximum
Energy
produced

351
kWh/m²

Slope

27°

Orientation

South

Module

Maximum Energy produced

351 kWh/m²

Option 1



Option 1.1



Option 2



Option 2.1




West

South

East


Legend (Kwh/m2)



Module

Maximum Energy produced

351 kWh/m²




Module

Maximum Energy produced


351
kWh/m²



Module




Module




Roof


PV Integration



Azimuth Angle




Slope




Distance between Panels


PV Parameters



Simulation



Legend
(Kwh/m2)



3.2m
Distance

0°
Azimuth

2 m
Height of panel

27°
Slope

370.30
kWh/m2

352 MWh.Ann
Total Output

Roof Integration



Energy




Heat

Solar Integration

Cold Water for
De-humidification

Hot Water for
Regeneration



Desiccant Coated Heat Exchanger



Flat Plate



Evacuated Tube

Solar Collector

450 Wh/m²
Average Solar Radiation for Delhi

0.8
Efficiency of evacuated collector

426.3 kW
Heating Required

294.4 kW
Heat Produced

1392.84 m²
Req. Panel Area

952.31 m²
Panel Area Available



Heat from Solar Collector

450 Wh/m²
Average Solar Radiation for Delhi

0.8
Efficiency of evacuated collector

426.3 kW
Heating Required

294.4 kW
Heat Produced


1392.84 m²
Req. Panel Area

952.31 m²
Panel Area Available

HEAT PUMP FOR ADDITIONAL HEAT

Heat from Solar Collector

426.3 kW
Heating Required




CASE 1
100% S.C

+



Heat Pump




CASE 2
50% S.C + 50% P.V

+



Heat Pump



CASE 3
100% P.V


+



Heat Pump

Combination Of SC/PV/Heat Pump

426.3 kW
Heating Required




CASE 1
100% S.C

+



Heat Pump

- 87,120 kWh.ann



CASE 2
50% S.C + 50% P.V


+



Heat Pump

Power required

- 46,877 kWh.ann



CASE 3
100% P.V

+




Heat Pump

+ 28,646 kWh.ann

Combination Of SC/PV/Heat Pump

426.3 kW Heating Required




CASE 1
100% S.C

+




Heat Pump

- 87,120 kWh.ann



CASE 2
50% S.C + 50% P.V


+



Heat Pump

Power required

- 46,877 kWh.ann



CASE 3
100% P.V

+



Heat Pump

+ 28,646 kWh.ann

Combination Of SC/PV/Heat Pump

	Pumping water to Roof			Blower + Misc for the cooler		Heat Pump
	Hot water	Cold water	Cold water for cooler	Primary air	Working air	
Power required						
per device (kW)	0.0028	0.0028	4.38 E-05	0.13	0.03	0.3
per device for a year (kWh)	10.19	10.19	0.15	451.98	99.97	1,109.58
Total Power per device	1.7 MWh					
Number of devices	292 nos.					
Total Power	4,91 MWh					
Safety Factor 1.25	614 MWh					

Power Calculation


	Pumping water to Roof			Blower + Misc for the cooler		Heat Pump
	Hot water	Cold water	Cold water for cooler	Primary air	Working air	
Power required						
per device (kW)	0.0028	0.0028	4.38 E-05	0.13	0.03	0.3
per device for a year (kWh)	10.19	10.19	0.15	451.98	99.97	1,109.58
Total Power per device	1.7MWh					
Number of devices	292 nos.					
Total Power	4,91 MWh					
Safety Factor 1.25	614 MWh					

Heat Pump has the largest share in total energy

Power Calculation

Comparison

Conventional / Evaporative Cooling



Simulated Building


 Fan Coil - Water Based Chiller

 Dew-Point Indirect Evaporative Cooling

Comparison

Fan Coil - Water Based Chiller

Dew-Point Indirect Evaporative Cooling




Cooling Load

50%

Comparison


Fan Coil - Water Based Chiller

Dew-Point Indirect Evaporative Cooling



Cooling Load

50%




Total Energy

40%

Comparison


Fan Coil - Water Based Chiller

Dew-Point Indirect Evaporative Cooling




Cooling Load

50%



Total Energy


40%



Energy from PV

30%

Comparison




WWR
60%

Location
New Delhi

Floor Area
1792m²

Cooling load
50W/m²/year




WWR
60%


Location
New Delhi

Floor Area
1792m²

Cooling load
50W/m²/year



Existing
CENTRALIZED
Energy Performance Index
146.41
kWh/m²/year



WWR
60%

Location
New Delhi


Floor Area
1792m²

Cooling load
50W/m²/year

Proposed DECENTRALIZED


Energy Performance Index

92.26
kWh/m²/year



Existing CENTRALIZED

Energy Performance Index
146.41
kWh/m²/year



WWR
60%

Location
New Delhi

Floor Area
1792m²


Cooling load
50W/m²/year

Proposed DECENTRALIZED

Energy Performance Index

92.26

kWh/m²/year



**40%
ENERGY
SAVING**

U VALUE



Roof

0.2 W/m²K
150mm Insulated
Roof



Glazing

1.7 W/m²K
6/13/6
LoE Double glazing
with air



Wall

0.3 W/m²K
100mm Insulated Cavity
brick with dense plaster

SHADING



Egg Crate Combinative mask
0.6m by 0.6m
1.5m spacing



Infiltration

0.3
ac/h

Fresh air
5.2
l/s - person

VENTILATION



Lighting

2
W/m²/ 100 lux
LED linear control



Equipment

9
W/m²



People


INTERNAL
HEAT GAIN

Existing CENTRALIZED

Energy Performance Index

146.41

kWh/m²/year



Name

Year

WWR%

Glazing

Solid

Shading

LPD

Cooling

EPI
179 kWh/m²/year

Wipro

2005

33

1.8

0.6

Horizontal louvers

5.4

Central

85

IPB

2014

20

1.8

0.5

Recessed

5

Geothermal

45.25

SkyView

2015

55

1.8

1.1

No Shading

9.5

Central

112

SkyView

2015

55

1.5

0.3

Egg Crate

9.5

Evaporative

64.26

Comparison

Ventilating Interiors

Refurbishment Projects

Cost Analysis

Sustainable moisture removal


Market Scenario

Future works

*“Architecture is a three-legged stool:
Climate, Technology, and Culture.”*

- Charles Correa.





de-VAP
Systems

THANK YOU