

**Fault diagnosis of the 10MW Floating Offshore Wind Turbine benchmark
A mixed model and signal-based approach**

Liu, Yichao; Ferrari, Riccardo M.G.; Wu, Ping; Jiang, Xiaoli; Li, Sunwei; van Wingerden, Jan-Willem

DOI

[10.1016/j.renene.2020.06.130](https://doi.org/10.1016/j.renene.2020.06.130)

Publication date

2021

Document Version

Final published version

Published in

Renewable Energy

Citation (APA)

Liu, Y., Ferrari, R. M. G., Wu, P., Jiang, X., Li, S., & van Wingerden, J.-W. (2021). Fault diagnosis of the 10MW Floating Offshore Wind Turbine benchmark: A mixed model and signal-based approach. *Renewable Energy*, 164, 391-406. <https://doi.org/10.1016/j.renene.2020.06.130>

Important note


To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.



Fault diagnosis of the 10MW Floating Offshore Wind Turbine Benchmark: A mixed model and signal-based approach

Yichao Liu ^{a, *}, Riccardo Ferrari ^a, Ping Wu ^b, Xiaoli Jiang ^a, Sunwei Li ^c, Jan-Willem van Wingerden ^a

^a Delft University of Technology, Delft, 2628CD, the Netherlands

^b Zhejiang Sci-Tech University, Hangzhou, 310018, China

^c Graduate School at Shenzhen, Tsinghua University, Shenzhen, 518055, China

ARTICLE INFO

Article history:

Received 31 January 2020

Received in revised form

12 May 2020

Accepted 26 June 2020

Available online 9 September 2020

Keywords:

Fault diagnosis

Floating offshore wind turbine

Model-based scheme

Signal-based scheme

FAST simulation

ABSTRACT

Floating Offshore Wind Turbines (FOWTs) operate in the harsh marine environment with limited accessibility and maintainability. Not only failures are more likely to occur than in land-based turbines, but also corrective maintenance is more expensive. In the present study, a mixed model and signal-based Fault Diagnosis (FD) architecture is developed to detect and isolate critical faults in FOWTs. More specifically, a model-based scheme is developed to detect and isolate the faults associated with the turbine system. It is based on a fault detection and approximation estimator and fault isolation estimators, with time-varying adaptive thresholds to guarantee against false-alarms. In addition, a signal-based scheme is established, within the proposed architecture, for detecting and isolating two representative mooring lines faults. For the purpose of verification, a 10 MW FOWT benchmark is developed and its operating conditions, which contains predefined faults, are simulated by extending the high-fidelity simulator. Based on it, the effectiveness of the proposed architecture is illustrated. In addition, the advantages and limitations are discussed by comparing its fault detection to the results delivered by other approaches. Results show that the proposed architecture has the best performance in detecting and isolating the critical faults in FOWTs under diverse operating conditions.

© 2020 The Author(s). Published by Elsevier Ltd. This is an open access article under the CC BY license (<http://creativecommons.org/licenses/by/4.0/>).

1. Introduction

The penetration of wind power into the energy mix has been significantly growing over the past decade [1,2]. In 2018, the global installed capacity of wind energy reached 591,549 MW worldwide [3]. Following in the path of onshore wind exploitation, the development of offshore wind energy picks up the momentum in the race in transitioning from conventional fossil fuels to renewable energy. In particular, offshore wind turbines are less intrusive from a visual and acoustic point of view, and guarantee much higher and steady generation of power [4]. As the exploitation of offshore wind energy moves from shallow to deep waters, Floating Offshore Wind Turbines (FOWTs) become the ideal alternative to replace the bottom-fixed turbines and capture the abundant wind resources available over the deep sea [4]. Although FOWTs are evidently advantageous from the public acceptance and power generation point

of view, designing, operating and maintaining them pose a series of challenges:

1. FOWTs may experience unexpected faults and failures due to the complex environmental loads, which would in turn lead to operation interruption, economic losses and thus high Operation and Maintenance (O&M) costs [5].
2. The reliability of FOWTs decreases with increasing turbine size and complexity [6]. In particular, FOWTs tend to have larger rotor diameters than land-based counterpart, and hence structural faults of the rotor blade are more prominent in FOWTs.
3. FOWTs are usually situated in deep waters at a considerable distance from the shore, which restrict their accessibility and maintainability [7]. As a consequence, the O&M cost of a FOWT may account for as high as 30% of the total life cycle cost [8], and also is an influential factor in the determination of the turbine's cost of energy.

To assess the reliability of wind turbines and to reduce the O&M

* Corresponding author.

E-mail addresses: Y.Liu-17@tudelft.nl, yichao.liu629@gmail.com (Y. Liu).

Nomenclature	
<i>Floating offshore wind turbine benchmark</i>	
β	Time profile
$\Delta\rho$	Change of the nonlinear part of the dynamics
F	Fault class
F_1	Fault class 1 being addressed by the model-based scheme
F_2	Fault class 2 being addressed by the signal-based scheme
η_x	Modelling uncertainties
η_y	Output disturbances
φ_x	Process fault function
φ_y	Output fault function
ρ	Nominal nonlinear part of the wind turbine healthy dynamics
ϑ_x	Parameter vector of the process fault function
ϑ_y	Parameter vector of the output fault function
A^0	Nominal linear part of the wind turbine healthy dynamics
C	Scale factor of the rotor blade fault
C^0	Nominal output matrix
C_l^0	l -th row of the nominal output matrix C^0
e_i	All-zeroes column vector of a suitable size having a single 1 in its i -th position
K	Discrete time index
k_0	Unknown time index of faults occurrence
u	Controlled input vector
x	State vector
y	Measured output vector
<i>Model-based scheme</i>	
α, δ	Scalar constants of the threshold
$\bar{\eta}_x$	Bounding function of the process uncertainties
$\bar{\eta}_y$	Bounding function of the measurement uncertainties
$\bar{r}_{y,l}$	Threshold of the fault detection and approximation estimator
$\bullet^{(i)}$	i -th component of a vector quantity
$\hat{\varphi}_x$	Linearly parameterized function for the actuator fault
$\hat{\varphi}_y$	Linearly parameterized function for the sensor fault
$\hat{\varphi}_{x,0}$	General online estimator
$\hat{\Theta}^0$	User designed parameters domain
$\hat{\vartheta}_{x,l}$	Parameter vector in the linearly parameterized function for the actuator fault
$\hat{\vartheta}_{y,l}$	Parameter vector in the linearly parameterized function for the sensor fault
\hat{x}	Predicted state vector
\hat{y}	Predicted output vector
κ^l	Maximum possible parameter estimation error of the threshold
A, B, C, D	System matrices of the fault detection and approximation estimator
g^l	Fault-specific shape function of the fault isolation estimator
k_d	Fault detection time
L	Gain matrix of the fault detection and approximation estimator
l	Index of the estimators
$M_{\hat{\Theta}^0}$	Radius of the user designed parameters domain
$r_{y,l}$	Residuals of the l -th estimator
M	Size of the output
N	Total number of the faults
<i>Signal-based scheme</i>	
τ	Transformed time coordinate
$D_{K,q}$	Distance between the training spectra and the actual one
$h(\bullet)$	Moving window
K	Neighborhood size
P	Total number of the frequency bins
Q	Total number of the training spectra
$S_{\tilde{\alpha},q}$	Training spectrum of the tower-top acceleration
$S_{\tilde{\alpha}}$	Time-frequency spectrum of the tower-top acceleration
W	Angular frequency coordinate
w_p	Frequency bin
<i>Case study</i>	
θ_{in}	Control input of the pitch angle
H_s	Significant wave height
T_p	Peak-spectral period
T_s	Discrete time step
$T_{g,in}$	Control input of the generator torque
U_f	Fluctuating wind component
U_m	Constant wind speed

cost, several Fault Diagnosis (FD) architectures have been proposed in the literature [9]. In general, FD architectures employ sensor data for detection, isolation and identification of the faults in the wind turbine components, whose output can be used to implement fault tolerant control and condition-based maintenance [10]. Odgaard et al. [11] introduced a 4.8 MW bottom-fixed wind turbine benchmark in 2009. Using this benchmark, different FD approaches were implemented and verified, including a Kalman filter combined with a diagnostic observer approach [12], up-down counter [13], Gaussian-kernel support vector machine [14] and estimation-based method [15]. These approaches were summarized comprehensively by Odgaard et al. [16]. In fact, it has been found by Odgaard et al. [11] that most faults in the benchmark can be detected successfully by the above mentioned approaches. Recently, several attempts have been made to build FD architectures via alternative approaches, such as interval observer [17], sliding mode observer [18] and multi-physics graphical model [19].

Nevertheless, the existing FD architectures which have been developed for land-based wind turbines can not be directly applied to the FOWT, the reasons for this include:

1. There is no systematic study, to the best of authors' knowledge, addressing prominent faults of FOWTs, such as structural faults of the rotor blades and of the mooring lines. More specifically, the published works mainly focus on the pitch system, gearbox, bearings, and electrical system [11,16] only. One plausible explanation might be that there is currently no benchmark including the fault scenarios of the rotor blades and mooring lines, nor those are implementable in widely-used simulation packages such as Fatigue, Aerodynamics, Structures, and Turbulence (FAST) [20].
2. The existing FD architectures are, in general, based on a simplified model of the land-based wind turbine [11,16], which lacks the descriptions of hydro and mooring line dynamics.

However, the dynamics of the FOWT system are significantly influenced by the complex interactions among the floating foundation, the mooring system, and the rotor blades [21].

Therefore, it is urgent to develop an effective FD architecture for FOWTs, considering the inapplicability of existing architecture, increased system size and complexity of turbine-foundation interaction and reduced accessibility for maintenance.

Recently, some preliminary efforts have been made to develop FD architectures for selected FOWT components. For instance, Ghane et al. [22] utilized the statistical approach to detect and estimate the wear in the drivetrain of the 5 MW spar-type FOWT. Cho et al. [5] used the model-based approach to detect, isolate and accommodate the faults of the blade pitch system of the same FOWT. Zhang et al. [23] employed the data-driven approach, namely random forests, to detect several actuator and sensor faults of the 5 MW semi-submersible FOWT. In spite of these designated contributions, relatively few studies addressed aforementioned challenges.

Considering the lack of systematic studies concerning the FD architecture for FOWTs, the present study aims to develop an effective approach to detect and isolate the fault of the FOWTs, and therefore contributes in the following aspects.

1. Instead of considering one single component, e.g. blade pitch system [5], of the FOWT system, a mixed FD architecture is developed in the present study for the detection and isolation of faults in both the turbine and mooring systems in FOWTs. In particular, the proposed mixed FD architecture is established by integrating the model-based scheme suggested by Ferrari et al. [24] with a signal-based scheme.
2. In order to verify the proposed architecture, a novel 10 MW FOWT benchmark is set up based on the DTU three-bladed variable speed reference wind turbine and Triple-Spar floating foundation [25,26]. Several critical fault scenarios including not only actuator and sensor faults, but also structural faults of rotor blade and mooring lines, are generated for the FD purpose. Particularly, the models of actuator and sensor faults are extracted and improved from the models available in the literature [16,27].

In summary, the main contribution of this study is the FOWT-oriented mixed FD architecture, which integrates model and signal-based schemes to encompass most critical faults in FOWTs. Another novelty is the physics-based FOWT benchmark. For the first time, a FOWT benchmark is established for the purpose of developing and verifying a FOWT-oriented FD architecture. In particular, the structural faults of the rotor blades and of the mooring lines are taken into consideration.

From detecting and isolating the predefined faults in the developed 10 MW FOWT benchmark, the effectiveness of the proposed FD architecture is illustrated. In addition, two classic fault detection methods are applied to the 10 MW FOWT benchmark with predefined faults. The comparison concerning the fault detection hence reveals the advantages and limitations of the proposed mixed FD architecture.

The remainder of the paper is organized as follows. Section 2 introduces the 10 MW FOWT benchmark. In section 3, the overall structure and theoretical framework of the mixed FD architecture are presented. A case study employing the proposed method to discern the faults of the newly developed 10 MW FOWT benchmark is given in section 4. Then, its advantages and limitations are discussed by comparing the detection results to other classical approaches. Section 5 contains concluding remarks.

2. Description of the 10 MW FOWT benchmark

In this section, the 10 MW FOWT benchmark is presented. It is based on the DTU three-bladed variable speed reference wind turbine and the Triple-Spar floating platform [25,26]. Particularly, several critical fault scenarios, including not only the actuator and sensor faults, but also the structural faults, are defined and implemented in the benchmark. The overview of the FOWT is portrayed in Fig. 1 while its specifications are listed in Table 1.

For the purpose of developing the proposed mixed FD architecture, the dynamics of the 10 MW FOWT and of its actuators in state-space will be described, by means of the following discrete-time system

$$\begin{cases} x(k+1) &= A^0 x(k) + \rho(x(k), u(k)) + \beta(k - k_0) \times \\ &\quad \varphi_x(y(k), u(k), \vartheta_x) + \eta_x(x(k), u(k), k) \\ y(k) &= C^0 x(k) + \beta(k - k_0) \varphi_y(x(k), \vartheta_y) + \\ &\quad \eta_y(x(k), u(k), k) \end{cases}, \quad (1)$$

where $k = 0, 1, \dots$ is the discrete time index and $x \in \mathbb{R}^n$, $u \in \mathbb{R}^m$, $y \in \mathbb{R}^p$ represent the state, the controlled input and the measured output vectors, respectively. The contents of u and y are defined in Table 2. The matrix $A^0 \in \mathbb{R}^{n \times n}$ and the vector field $\rho : \mathbb{R}^n \times \mathbb{R}^m \mapsto \mathbb{R}^n$ denote the nominal linear and nonlinear parts of the FOWT healthy dynamics while $C^0 \in \mathbb{R}^{p \times n}$ is the nominal output matrix. The unavoidable modelling uncertainties and output disturbances are




Fig. 1. Lateral view of the DTU 10 MW wind turbine, of the TripleSpar floating platform and indication of mooring line faults location.

Table 1
Specifications of the 10 MW FOWT (SWL: Sea water level).

Parameter	Value
Turbine system	
Rating	10 MW
Rotor orientation, configuration	Upwind, 3 blades
Pitch control	Variable speed, collective pitch
Drivetrain	Medium speed, multiple stage gearbox
Rotor, hub diameter	178.3 m, 5.6 m
Hub height	119 m
Cut-in, rated, cut-out wind speed	4 m/s, 11.4 m/s, 25 m/s
Cut-in, rated rotor speed	6 rpm, 9.6 rpm
Rated tip speed	90 m/s
Floating platform	
Total height and draft	66 m, 56 m
Distance from the tower center-line	26 m
Single column diameter	15 m
Column elevation above SWL	10 m
Elevation of tower base above SWL	25 m
Water displacement	29497.7 m ³
Mooring lines	
Number of lines	3
Line angles from upwind direction	0°, 120°, 240°
Water depth and anchor radius	180 m, 599.98 m
Fairleads above SWL	8.7 m
Fairleads radius	47.181 m
Line diameter	0.18 m
Total length	707 m
Mass/length in air	594 kg/m

described by the functions $\eta_x : \mathbb{R}^n \times \mathbb{R}^m \times \mathbb{R} \mapsto \mathbb{R}^n$ and $\eta_y : \mathbb{R}^n \times \mathbb{R}^m \times \mathbb{R} \mapsto \mathbb{R}^p$.

The terms $\beta(k - k_0) \times \varphi_x(y(k), u(k), \vartheta_x)$ and $\beta(k - k_0) \times \varphi_y(x(k), \vartheta_y)$ represent the dynamic changes of the state and output equation, respectively, due to the occurrence of faults at the unknown time index k_0 , similarly to the case reported by Ferrari et al. [24].

In detail, a fault class $F = \{F_1, F_2\}$ consisting of 5 process and 6 output fault functions will be considered, with F_1 being addressed by the model-based scheme, and F_2 by the signal-based scheme in the proposed mixed FD architecture:

$$F \triangleq \left\{ \underbrace{\varphi_{y,1}, \dots, \varphi_{y,4}, \varphi_{y,7}, \varphi_{y,8}}_{F_1}, \underbrace{\varphi_{x,5}, \varphi_{x,6}, \varphi_{x,9}, \varphi_{x,10}, \varphi_{x,11}}_{F_2} \right\}. \quad (2)$$

The details of each fault function in F are described in Table 3.

The parameters $\vartheta_{y,l}$, $l \in \{1, 2, 4, 8\}$ denote the scaling error magnitude for sensors affected by the scaling type of faults, while

Table 2
Controlled and measured variables of the 10 MW FOWT.

Variable	Symbol	Units
Control signals		
Reference pitch angle	$\theta_r \equiv u_1$	deg
Reference generator torque	$T_{g,r} \equiv u_2$	Nm
Measurements		
Pitch angles	$\theta_s \equiv y_s, s = 1, \dots, 3$	deg
Generator torque	$T_g \equiv y_4$	Nm
Rotor angular speed	$\omega_r \equiv y_5$	rad/s
Generator angular speed	$\omega_g \equiv y_6$	rad/s
Generator power	$P_g \equiv y_7$	W
Blade root bending moments ^a	$M_{cm,s} \equiv y_{7+s}, s = 1, \dots, 3$	Nm
Tower top acceleration	$\ddot{a} \equiv y_{10}$	m/s ²

^a $M_{cm,s}$ is the transformed symmetric moment of the s -th ($s = 1, 2, 3$) blade root via the Coleman transformation [28], which transforms from a rotational coordinate frame to a fixed one where all periodic parts vanish.

$\vartheta_{y,7}$ and $\vartheta_{y,3}$ denote, respectively, the stuck and offset value for these kinds of sensor faults. Similarly, $\vartheta_{x,5}$ and $\vartheta_{x,6}$ denote the same for actuator type of faults.

The last three faults, described by $\varphi_{x,9}$ to $\varphi_{x,11}$, denote structural faults that affect the nonlinear dynamic function ρ . In order to describe such structural faults, the notations $\Delta\rho(x, u, \vartheta_{x,l}) \triangleq \rho(x, u, \vartheta_{x,l}) - \rho(x, u)$, with $l = 9, \dots, 11$, are introduced. They represent the change in the nonlinear part of the dynamics from its nominal behaviour to a faulty behaviour characterized by the parameter vectors of $\vartheta_{x,l}$. These vectors contain specific values of structural parameters which are caused by the structural faults.

In particular, the faulty blade stiffness $\vartheta_{x,9} = c \cdot \vartheta_{x,9}^0$ is used to describe the abrupt rotor blade faults due to the effects of cracking, debonding/delamination or fiber breakage [29]. In equations shown in Table 3, $0 \leq c < 1$ is a scale factor quantifying the reduction of the blade stiffness. Usually, the stiffness reduction of the blade fault can be divided into three stages [30]. The first two stages are attributed to non-severe blade faults with a local stiffness reduction of around 0%–30%. They are caused by transverse matrix cracks and debonding/delamination, respectively, which exert little effect on the global bending stiffness. The third stage is severe blade fault with a local stiffness reduction of at least 30%. It is mostly induced by the local damage progression and the fiber breaking, and may have a significant effect on the global dynamics of the blade. In this paper, only the severe blade fault in stage 3 is taken into account for investigations.

In order to properly simulate the abrupt rotor blade faults, the corresponding faulty mode shapes of the blades, which are dependent on $\vartheta_{x,9}$, are calculated using the tool Modes¹ and fed into the FAST simulator. Note that the last two functions describe two critical mooring line faults (see Fig. 1) that may occur during the FOWT operation process [31,32]. In detail, the top segment fault at the fairlead will cause the mooring line to fall away and reduce its tension $\vartheta_{x,10}$ to zero. In the case of bottom segment faults, the static friction forces from the seabed fail to keep the anchor in balance. As a result, the anchor moves into a new equilibrium position where the unstretched length $\vartheta_{x,11}$ of the mooring line increases.

Based on the benchmark described above, the 10 MW FOWT dynamics are simulated by the FAST simulator with Simulink. In particular, all the fault functions listed in Table 3, describing all the fault scenarios in F , are included into the 10 MW FOWT benchmark by extending the source code of the FAST simulator. More importantly, critical parameters of the fault functions, e.g. magnitude of the faults and changed mode shapes of the blades, can be determined by users through an interface in Simulink, and thereby fed into the FAST simulator for the fault generation. As presented in Fig. 2, the lower part of the block diagram illustrates the developed 10 MW FOWT benchmark. In addition, the well-known FAST numerical package [20] is customized to include all kinds of faults and then simulate the dynamics of a FOWT system containing specific faults. Furthermore, the control laws which are based on Linear Time Invariant (LTI) dynamical systems, are implemented in Simulink [25,26].

3. Mixed FD architecture for Floating Offshore Wind Turbines

In this section the overall structure of the mixed FD architecture is introduced, which is depicted in the upper part of Fig. 2.

The mixed FD architecture includes a model-based FD approach in the time domain, which follows the generalized observer scheme

¹ Modes: a simple mode-shape generator for towers and rotating blades. <https://nwtc.nrel.gov/Modes>.

Table 3
Fault types and functions.

Name	Type	Description	Function
Sensor			
f_1	scaling	Generator speed	$\varphi_{y,1} = \vartheta_{y,1} C_1^0 x$
f_2	scaling	Generator power	$\varphi_{y,2} = \vartheta_{y,2} C_2^0 x$
f_3	offset	Blade root bending moment	$\varphi_{y,3} = \vartheta_{y,3} e_3$
f_4	scaling	Rotor speed	$\varphi_{y,4} = \vartheta_{y,4} C_4^0 x$
f_7	stuck	Pitch sensor	$\varphi_{y,7} = \vartheta_{y,7} - C_5^0 x - \eta_{y,(5)}$
f_8	scaling	Torque sensor	$\varphi_{y,8} = \vartheta_{y,8} C_6^0 x$
Actuator			
f_5	stuck	Pitch actuator	$\varphi_{x,5} = -u + \vartheta_{x,5} e_5$
f_6	offset	Torque actuator	$\varphi_{x,6} = \vartheta_{x,6} e_6$
Structural			
f_9	parameter	Rotor blade sudden fault	$\varphi_{x,9} = \Delta\rho(x, u, \vartheta_{x,9})$
f_{10}	parameter	Mooring line (fairlead)	$\varphi_{x,10} = \Delta\rho(x, u, \vartheta_{x,10})$
f_{11}	parameter	Mooring line (anchor)	$\varphi_{x,11} = \Delta\rho(x, u, \vartheta_{x,11})$




Fig. 2. Block diagram of the 10 MW FOWT benchmark in the lower part and the overall structure of the mixed FD architecture (eqs. 4–16) in the upper part. A fault generator block is added to allow introducing faults (Table 3) in actuators, sensors, rotor blades and mooring lines.

[33]. In detail, a Fault Detection and Approximation Estimator (FDAE) is used to detect faults and activate a bank of N Fault Isolation Estimators (FIEs), with N being the number of the pre-defined faults. Fault decisions produced by the FDAE and the FIEs are evaluated by a detection and isolation logic in order to produce a final diagnosis.

For the purpose of coping with the faults associated with mooring lines, which proved to be elusive for estimator-based detectors, the proposed mixed FD architecture includes as well a signal-based FD scheme in the frequency domain. The signal-based scheme consists of a Short Time Fourier Transform (STFT) step

followed by a K-Nearest Neighbour (KNN) detection and isolation step.

3.1. Model-based fault diagnosis for the turbine system

To detect and isolate the $N = 9$ faults belonging to F_1 , a bank of $N + 1$ nonlinear adaptive estimators is designed and implemented, each one yielding an output estimate $\hat{y}_l \in \mathbb{R}^M$, $l = 0, \dots, N$, where M is the size of the output. The FDAE ($l = 0$) detects known faults and approximate unknown ones, while the FIEs ($l = 1, \dots, N$), each corresponding to one fault in F_1 , are designed to isolate the detected fault. For each l -th estimator a residual signal is defined as

$$r_{y,l}(k) = y_l(k) - \hat{y}_l(k). \quad (3)$$

The healthy hypothesis ($l = 0$) shall be rejected by the FDAE if the absolute value of at least one component $r_{y,l(i)}(k)$ of its residuals, with $i \in \{1, \dots, M\}$, exceeds the corresponding one of a suitable time-varying threshold, denoted as $\bar{r}_{y,l(i)}(k)$. The first such time will be indicated as the *detection instant* k_d . Similarly, each FIE ($l = 1, \dots, N$) will reject its own faulty hypothesis if a component of its residuals will cross its threshold. If at some time instant every hypothesis but the l -th one has been rejected by the FDAE and FIEs, then the detection and isolation logic will conclude that the l -th fault occurs.

3.1.1. FDAE and fault detection

The FDAE will be based on a linearized version of the nominal healthy FOWT dynamics introduced in eq. (1). For time instants $0 \leq k < k_d$, that is before detection, it will be described by the following LTI system

$$\begin{cases} \hat{x}(k+1) &= A\hat{x}(k) + Bu(k) + L(y(k) - \hat{y}(k)) \\ \hat{y}(k) &= C\hat{x}(k) + Du(k) \end{cases}, \quad (4)$$

where $\hat{x}(k)$ and $\hat{y}(k)$ are the predicted state vector and output, respectively, and the FDAE input and output correspond to the same variables described in Table 2. Following the block diagram introduced in the lower part of Fig. 2, the matrices A , B , C and D are obtained by cascading the LTI systems describing the actuator dynamics [25,26] with a linear model of the turbine. Such a linear model is obtained by applying subspace identification [34] techniques to simulation data produced by FAST. It should be noted that it is rather difficult to obtain a white-box model due to the nonlinear dynamics of the FOWT [35], as detailed in Section 4. The matrix $L \in \mathbb{R}^{K \times M}$ is the FDAE gain, which is chosen such that

$A_0 \triangleq A - LC$ is stable. The time-varying threshold $\bar{r}_{y,0}(k)$ is then designed to bound the healthy residual $r_{y,0}(k)$, in order to guarantee no false-positive alarms.

In detail, the i -th component $\bar{r}_{y,0,(i)}(k)$ is calculated as,

$$\bar{r}_{y,0,(i)}(k) \triangleq \sum_{h=0}^{k-1} \alpha_{(i)} \delta_{(i)}^{k-1-h} [\bar{\Delta\rho}(h) + \bar{\eta}_x(h)] + \alpha_{(i)} \delta_{(i)}^k \bar{\varepsilon}_x^0(0) + \bar{\eta}_{y,(i)}(k), i = 1, \dots, M, \tag{5}$$

where two scalar constants $\alpha_{(i)}$ and $\delta_{(i)}$ are obtained as in Ref. [36]. $\bar{\eta}_x$ and $\bar{\eta}_y$ are the bounding function of the uncertainties in the state and output equations of the FOWT. The function $\Delta\rho$ represents the difference between the nominal nonlinear healthy dynamics and the linear model:

$$\begin{cases} \Delta\rho(x(k), \hat{x}, u(k)) \triangleq \rho(x(k), u(k)) - \rho(\hat{x}(k), u(k)) \\ \bar{\Delta\rho}(\hat{x}(k), u(k)) \triangleq \max_{x \in \mathbb{R}^x} (\|\Delta\rho(x, \hat{x}, u(k))\|) \end{cases} \tag{6}$$

If the condition $|r_{y,0,(i)}(k)| > \bar{r}_{y,0,(i)}(k)$ holds for some component i at the time instant $k = k_d$, a fault is detected and the FDAE equation becomes

$$\begin{cases} \hat{x}(k+1) = A\hat{x}(k) + Bu(k) + L(y(k) - \hat{y}(k)) + \hat{\varphi}_{x,0}(y(k), u(k), \hat{\vartheta}_0(k)) \\ \hat{y}(k) = C\hat{x}(k) + Du(k), \end{cases} \tag{7}$$

where $\hat{\varphi}_{x,0}$ is a general online estimator to learn unknown or unstructured faults (such as the rotor blade sudden fault f_9). For instance, $\hat{\varphi}_{x,0}$ can be based on a Radial Basis Function (RBF) neural network, whose parameters are assumed to satisfy $\hat{\vartheta}_0 \in \hat{\Theta}^0$, where $\hat{\Theta}^0$ is a user designed parameters domain. In particular, $\hat{\Theta}^0$ is chosen here to be an origin-centered hyper-sphere with radius of $M_{\hat{\Theta}^0}$.

3.1.2. FIE and fault isolation

After a fault is detected at $k = k_d$, the bank of FIEs is activated. The actuator fault l -th FIE's dynamics, for the actuator faults $l = 5, 6$ are,

$$\begin{cases} \hat{x}^l(k+1) = A\hat{x}^l(k) + Bu(k) + L(y(k) - \hat{y}^l(k)) + \hat{\varphi}_{x,l}(y(k), u(k), \hat{\vartheta}_{x,l}(k)) \\ \hat{y}^l(k) = C\hat{x}^l(k) + Du(k) \end{cases}, \tag{8}$$

where $\hat{\varphi}_{x,l}(k) \triangleq \text{col}(\hat{\varphi}_{x,l,(i)}(k), i = 1, \dots, M)$ and $\hat{\vartheta}_{x,l}(k) \triangleq \text{col}(\hat{\vartheta}_{x,l,(i)}(k))$. Particularly, $\hat{\varphi}_{x,l,(i)}(y(k), u(k), \hat{\vartheta}_{x,l,(i)}(k)) \triangleq \hat{\vartheta}_{x,l,(i)}(k)^T g_{(i)}^l(y(k), u(k))$ is a linearly parameterized function. $\hat{\vartheta}_{x,l,(i)}(k) \in \hat{\Theta}_{(i)}^l$ denotes the parameter vector and $g_{(i)}^l$ is the fault-specific shape function. $\hat{\Theta}_{(i)}^l$ is assumed to be an origin-centered hyper-sphere with radius of $M_{\hat{\Theta}_{(i)}^l}$ as well.

In order to learn the fault function of $\varphi_{x,l}$, the parameters of $\hat{\varphi}_{x,l}$ are updated following the learning law,

$$\hat{\vartheta}_{x,l}(k+1) = P_{\hat{\Theta}}^{-l} \left(\hat{\vartheta}_{x,l}(k) + \gamma^l(k) g^l(k) C^T r_y^l(k+1) \right), \tag{9}$$

where $P_{\hat{\Theta}}^{-l}$ denotes the projection operator on $\hat{\Theta}^l$ as

$$P_{\hat{\Theta}}^{-l}(\hat{\vartheta}_{x,l}) \triangleq \begin{cases} \hat{\vartheta}_{x,l}, & \text{if } |\hat{\vartheta}_{x,l}| \leq M_{\hat{\Theta}}^{-l} \\ (M_{\hat{\Theta}}^{-l}/|\hat{\vartheta}_{x,l}|) \cdot \hat{\vartheta}_{x,l}, & \text{if } |\hat{\vartheta}_{x,l}| > M_{\hat{\Theta}}^{-l} \end{cases} \tag{10}$$

In addition, $\gamma_{(i)}^l(k)$ is calculated as,

$$\gamma^l(k) \triangleq \mu^l / (\varepsilon^l + g^l(k) C^T r_F^2), \varepsilon^l > 0, \quad 0 < \mu^l < 2. \tag{11}$$

Similarly, the dynamics of the l -th FIE corresponding to the sensor faults, $l \in \{1, 2, 3, 4, 7, 8\}$, are

$$\begin{cases} \hat{x}^l(k+1) = A\hat{x}^l(k) + Bu(k) + L(y(k) - \hat{y}^l(k)) \\ \hat{y}^l(k) = C\hat{x}^l(k) + Du(k) + \hat{\varphi}_{y,l}(x(k), \hat{\vartheta}_{y,l}(k)) \end{cases}, \tag{12}$$

where $\hat{\varphi}_{y,l}(k) \triangleq \text{col}(\hat{\varphi}_{y,l,(i)}(k), i = 1, \dots, M)$ and $\hat{\varphi}_{y,l,(i)}(x(k), \hat{\vartheta}_{y,l,(i)}(k)) \triangleq \hat{\vartheta}_{y,l,(i)}(k)^T g_{(i)}^l(x(k))$.

Table 4
Fault scenarios in the case study.

Number	Description	Parameter	Time
Fault case A			
f_1	Generator speed	0.95	210 s – 235 s
f_2	Generator power	1.1	305 s – 330 s
f_3	Blade root bending moment	10^4 kN m	400 s – 425 s
f_4	Rotor speed	1.1	495 s – 520 s
f_5	Pitch actuator	0.2 rad	590 s – 615 s
f_6	Torque actuator	20 kN m	685 s – 710 s
f_7	Pitch sensor	0.2 rad	780 s – 805 s
f_8	Torque sensor	0.9	875 s – 900 s
f_9	Rotor blade sudden fault	$c = 0.2$	970 s – 1000 s
Fault case B			
f_{10}	Mooring line (fairlead)	0 N	300 s – 1000 s
Fault case C			
f_{11}	Mooring line (anchor)	150 m	300 s – 1000 s

Table 5
Wind and wave conditions in seven LCs.

LC	Wind condition	U_m (m/s)	H_s (m)	T_p (s)
1	Laminar	12	2.66	7.42
4	Turbulent			
2	Laminar	16	3.78	7.80
5	Turbulent			
3	Laminar	20	5.13	8.47
6	Turbulent			
7	Laminar, below rated value	8	1.69	7.28




Fig. 3. Results of the subspace identification in LC1.(a) Generator speed, VAF: 86%, (b) Generator power, VAF: 96%, (c) Bending moment, VAF: 86%, (d) Rotor speed, VAF: 86%.

As each l -th FIE fault function matches the specific fault in F_1 , it is possible to compute a dynamic threshold $\bar{r}_{y,l}$ such that $|r_{y,l(i)}(k)| \leq \bar{r}_{y,l(i)}(k)$ under the hypothesis that the actual fault is the l -th one, for each i and k . The thresholds for actuator faults are designed as

$$\bar{r}_{y,l(i)}(k) = \bar{\eta}_{y,(i)}(k) + \alpha_{(i)} \left\{ \sum_{h=k_d}^{k-1} \delta_{(i)}^{k-1-h} \left\{ [\bar{\Delta}\rho(h) + \bar{\eta}_x(h)] + |g_{(i)}^l(h)| \right. \right. \\ \left. \left. \times \left[\kappa^l(h) + \left\| \hat{\vartheta}_{(i)}^l(h) \right\| \bar{b}^{-(h-k_d)} \right] \right\} + \delta_{(i)}^{k-k_d} \bar{\varepsilon}_x^l(k_d) \right\}, \quad (13)$$

where κ^l is the maximum possible parameter estimation error

$$\kappa^l \triangleq \max_{\vartheta_{x,l} \in \Theta} (\|\vartheta_{x,l} - \hat{\vartheta}_{x,l}(k)\|). \quad (14)$$

The threshold derivation for sensor faults is similar and will not be repeated here.

It is worth noting that the threshold equation of (13) guarantees that if the s -th fault $\varphi_{x,s} \in F_1$ occurs and is learned by its FIE successfully, that residual is guaranteed to be bounded by its threshold. If at least one component of all the other FIE residuals exceeds its corresponding threshold, then the s -th fault will be successfully isolated.

3.2. Signal-based fault diagnosis for the mooring lines

Detecting and isolating faults in F_2 which are associated with the mooring system may prove to be difficult using the model-based approach of previous subsection. In particular, it can be verified that for realistic values of the FOWT and mooring lines parameters, such faults do not fulfil the detectability and isolability conditions stated in Theorem 3.1 and Theorem 3.2 of Ferrari et al. [24]. To cope with the faults in the mooring system, a signal-based scheme is proposed, which takes advantage of the noticeable influence that such faults have on the spectrum of the tower-top acceleration $\ddot{\alpha}$.

Remark 1. Although the mooring line faults can be identified from the platform motions or mooring line tensions, the measurement of these signals are expensive. Furthermore, the accuracy of the floater motion measurement is still questionable, as it should be further validated [37].

In comparison, the measurement of the tower-top vibration is a proven technique, which has been widely used in wind farms. Based on the tower-top acceleration frequency analysis, two representative mooring line faults will be identified. Such a mixed model and signal-based architecture allows to detect and isolate all the considered faults, without requiring the installation of additional, platform-motions or mooring-lines specific sensors.

In the present study, STFT [38] is utilized to transform the time series of the tower-top acceleration $\ddot{\alpha}$ as

$$S_{\ddot{\alpha}}(\tau, w) = \sum_{k=-\infty}^{+\infty} \ddot{\alpha}(k)h(k-\tau)e^{-jwk}, \quad (15)$$

where $S_{\ddot{\alpha}}$ is the time-frequency spectrum of $\ddot{\alpha}$, while τ and w




Fig. 4. Results of the subspace identification in LC4.(a) Generator speed, VAF: 77%, (b) Generator power, VAF: 96%, (c) Bending moment, VAF: 74%, (d) Rotor speed, VAF: 75%.




Fig. 5. Residual generation and model-based fault detection in LC1. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) Generator speed, (b) Generator power, (c) Bending moment, (d) Rotor speed, (e) Pitch angle, (f) Generator torque.




Fig. 6. Residual generation and model-based fault detection in LC4. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) Generator speed, (b) Generator power, (c) Bending moment, (d) Rotor speed, (e) Pitch angle, (f) Generator torque.

Table 6
MRRT of the proposed FD architecture in seven LCs.

	LC1	LC2	LC3	LC4	LC5	LC6	LC7
f_1	24.7	1.5	6.7	2.4	1.1	1.1	25.9
f_2	50.5	7.5	7.9	20.2	8.1	1.9	16.7
f_3	21.3	1.7	3.2	1.0	1.5	1.0	5.9
f_4	11.1	3.2	12.5	3.4	1.6	1.2	50.5
f_5	26.1	3.4	44.9	11.7	14.8	34.3	61.4
f_6	2.7	9.6	5.0	4.0	1.8	1.5	58.9
f_7	6.5	1.7	6.7	6.0	2.7	11.9	10.9
f_8	1.5	1.8	4.0	1.2	1.2	1.2	0.8
f_9	32.6	1.7	5.9	2.0	1.0	1.0	7.3

denote, respectively, the transformed time and angular frequency coordinates. Furthermore, $h(k)$ is a window determining the time and frequency resolution.

Using either experimental or simulation data, several training spectra $S_{\alpha,q}^l(\tau, w)$ are obtained, with $q = 1, \dots, Q$. The quantity Q indicates the total number of training spectra for each hypothesis, the possible hypotheses being either healthy conditions ($l = 0$), a fairlead fault ($l = 10$) or an anchor fault ($l = 11$). In order to detect and isolate mooring lines faults, the KNN algorithm [39] is run on the distance between the training spectra $S_{\alpha,q}^l(\tau, w)$ and the actual one $S_{\alpha}(\tau, w)$ as

$$D_{K,q}^l(\tau) = \sqrt{\sum_{p=1}^P \left(S_{\alpha}(\tau, w_p) - S_{\alpha,q}^l(\tau, w_p) \right)^2}, \quad (16)$$

where w_p with $p = 1, \dots, P$ denotes one frequency bin.² After selecting the neighborhood size K , faults can be detected and

² As the STFT is computed using the discrete fast Fourier transform, only a discrete number of frequency bins are available.

isolated by the majority voting criterion [40], where the widely-used rule $K \leq \sqrt{Q}$ is employed following [40].

4. Case study and comparison

The effectiveness of the proposed mixed FD architecture is verified via a case study based on the newly developed 10 MW FOWT benchmark. Following the case study, the comparisons between the developed architecture and other two classical approaches reported in literature are carried out. The advantages and limitations of the proposed mixed FD architecture are discussed based on the comparison results.

4.1. Model configuration

The aero-hydro-structural dynamics of the 10 MW FOWT benchmark are simulated by a modified version of FAST v8.16 [20]. It is noted that the open-sourced code of FAST is extended by the authors to incorporate all the faults defined in Table 3. Such a customized FAST code is thus embedded in Simulink and connected to external blocks implementing the basic controllers, actuators and the turbine's sensors, as shown in the lower part of Fig. 2.

In total, seven Load Cases (LCs) considering laminar and turbulent wind conditions and irregular waves are simulated in the 10 MW FOWT benchmark, as shown in Table 5. In the first three LCs, a constant wind speed (U_m) of, respectively, 12 m/s, 16 m/s and 20 m/s is assumed at the hub height. Regarding LC4-LC6, a three-dimensional turbulent varying wind field, which is produced by the TurbSim³ tool, is considered. In addition to these cases above the rated wind speed (11.4 m/s), a wind condition of 8 m/s which is below the rated value, is considered in LC7. In details, it can be described as,

³ TurbSim: a stochastic inflow turbulence tool to generate realistic turbulent wind fields. <https://nwtc.nrel.gov/TurbSim>.




Fig. 7. Comparisons between measurements and FDAE outputs in LC1. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) Generator speed, (b) Generator power, (c) Bending moment, (d) Rotor speed.




Fig. 8. Approximation (first 6 outputs) of the RBF neural network in LC1. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) $\hat{\varphi}_0(1)$, (b) $\hat{\varphi}_0(2)$, (c) $\hat{\varphi}_0(3)$, (d) $\hat{\varphi}_0(4)$, (e) $\hat{\varphi}_0(5)$, (f) $\hat{\varphi}_0(6)$.

$$U_w(k) = U_m + U_f(k), \quad (17)$$

where the constant wind speed U_m is used to specify the normal wind profile and U_f is a fluctuating wind component calculated from the Normal Turbulence Model (NTM) [41]. NTM is based on the Kaimal turbulence model according to the turbulence

intensities specified in the IEC with class C.

In addition, the wave conditions are computed using the JONSWAP wave spectrum model. The significant wave height H_s and peak-spectral period T_p in all LCs are predicted by the conditional probabilistic distribution derived from the long-term observation campaigns in the North Sea [42]. In each LC, the simulation lasts 1000 s at a fixed discrete time step of $T_s = 0.01$ s. In




Fig. 9. Fault isolation for the sensor fault (f_2) in LC2. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) FIE #2, component 1, (b) FIE #3, component 1, (c) FIE #4, component 1, (d) FIE #5, component 1, (e) Approximated fault function, (f) Approximated parameter.




Fig. 10. Fault isolation for the actuator fault (f_6) in LC2. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) FIE #2, component 2, (b) FIE #3, component 2, (c) FIE #4, component 2, (d) FIE #6, component 1, (e) Approximated fault function, (f) Approximated parameter.

total, 11 faulty scenarios are simulated during each LC, as described in Table 4. In particular, the magnitude of $f_1 - f_8$ are extracted from the literature [16,27].

4.2. Model-based FD for the turbine system

For the purpose of developing the FDAE and FIEs in the model-based FD scheme, the linear model is obtained via the subspace identification.

The normal operating condition of the 10 MW FOWT benchmark, which is articulated in section 2, is simulated via the extended FAST code to produce data in healthy conditions for subspace identification at a reduced time step of $20 \times T_s = 0.2s$. In order to guarantee the persistent excitation of the system dynamics, the generalized binary noise [43] is added into the input pitch angle and generator torque (θ_{in} and $T_{g,in}$) corresponding to

steady state conditions at each of LCs. Then, the subspace identification procedure [34] is performed to obtain the linear model of the 10 MW FOWT benchmark.

Figs. 3 and 4 shows the results of the subspace identification run in laminar wind condition (LC1) and turbulent wind condition (LC4). The performance of the subspace identification is evaluated by checking the Variance-Accounted-For (VAF) [44]. It can be seen that all the VAFs of the identified system in LC1 and LC4 are higher than 86% and 74%, which indicate that the predicted value from the linear system is an acceptable match for the real signals. Compared to LC1, it shows that the VAFs of the generator speed, bending moment and rotor speed in LC4 are lower. One plausible explanation is that the high-frequency turbulence can not be fully captured by the linearized model. Despite of such a deviation in the high frequency region, it is considered that the performance of the subspace identification is acceptable in both laminar and turbulent




Fig. 11. Fault isolation for the actuator fault (f_4) in LC4. Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) FIE #2, component 4, (b) FIE #3, component 4, (c) FIE #4, component 4, (d) FIE #6, component 4, (e) Approximated fault function, (f) Approximated parameter.

wind conditions. Other plots of the subspace identifications in LCs 2–3 and 5–7 show similar patterns and are thereby omitted for the sake of brevity.

Based on the derived linear model and on a discrete time step of $20 \times T_s = 0.2s$, the simulation results of the FDAE in LC1 are presented in Fig. 5 for discussions. In general, it is noticeable that the faults f_1 – f_9 are detected successfully in LC1 as the residuals in faulty scenarios exceed the corresponding thresholds, which indicate the effectiveness of the proposed FDAE. In addition to these actuator and sensor faults, the structural fault, namely the rotor blade fault in the simulation time of 970s–1000s, is successfully detected by the proposed mixed FD architecture.

Compared to the laminar wind condition in LC1, a much more significant disturbance is found in the residuals of LC4 due to the turbulent wind, according to Fig. 6. In general, most of faults can be detected successfully by the proposed mixed FD architecture, except for some detection delay for f_3 and f_9 . One plausible explanation is such a bending moment fault is buried in the fluctuations in the output signals due to the drastic turbulence and high wind speeds, and as such is too small to be detected.

Similar results are obtained for other LCs, and are summarized in Table 6. In order to easily quantify detection robustness, an indicator called Maximum Ratio between Residuals and Thresholds (MRRT) is introduced. An MRRT is larger than 1 means that for at least one sample the residual exceeds the threshold: a higher MRRT implies that the FD architecture has a better fault detection capability as it is more likely to be able to detect and isolate smaller faults.

Compared to laminar wind conditions, it can be seen from Table 6 that MRRT in turbulent wind conditions (LC4–LC6) is much lower than in laminar ones. Particularly, the MRRT in LC4 is lower than LC1 by $\sim 49\%$, which can be explained by the fact that the wind turbulence will cause the FOWT to operate more frequently away from the operating point around which the dynamics used by the FDAE have been linearized. It induces significant nonlinear effects on the mixed FD architecture and reduces the fault detection capability. However, some values in LC4–LC6 are higher than in

corresponding laminar wind conditions, such as f_6 in LC4, f_2, f_5 and f_7 in LC5 and f_7 in LC6. One plausible explanation is that in some cases the additional uncertainty due to the wind turbulence may instead positively interfere with the other components affecting the residual and make it larger, thus easing detection. Regarding LC7 below the rated wind speed, the proposed FD architecture in general shows similar results as in LC1 above the value one. It is interesting to note that f_8 is hard to be detected in this case, which shows a lower MRRT in LC7. The reason for this is that the generator torque in this case is smaller than the rated value. This makes the scaling sensor fault of the torque too small to be detected.

After a successful fault detection, a bank of FIEs is activated for the isolation step. More specifically, 8 FIEs are employed to match the structured faults (f_1 – f_8) within F_1 , while fault f_9 , being unstructured, is learned by the general adaptive approximator of the FDAE.

In detail, the FDAE approximator $\hat{\varphi}_0$ in eq. (7) is enabled to approximate the unknown faults and unstructured component faults. It is based on a 6-input, 20-output RBF neural network with one hidden layer of 60 fixed neurons covering all the admissible values for state and input variables. $\hat{\varphi}_0$ will have $20 \cdot 60$ components containing the weights by which the hidden layer outputs are linearly combined to calculate the network output.

By including the approximation of the neural network, the results of FDAE in LC1 is presented in Fig. 7. It can be seen that such an unstructured blade fault in f_9 is eventually learned successfully by the online adaptive approximator $\hat{\varphi}_0$. Anyway, some deviations between the measurements and FDAE are observed during 970s–990s due to the oscillating behaviour of the neural network output, which is induced by the learning law and partially illustrated in Fig. 8.

In addition to f_9 , other faults (f_1 – f_8) are isolated by the designed FIEs. Fig. 9 shows the results of the fault isolation and the approximated fault function of the sensor fault (f_2) in LC2. It is worth nothing that f_2 is isolated at the early stage of the fault scenario (306s), since only the residuals produced by the FIE #2 are within the range specified by the corresponding thresholds. The residuals from other FIEs(#1, #3 and #4) exceed their thresholds




Fig. 12. Norm of the distance between the spectral patterns and the measurement output and KNN for the signal-based FD of the mooring line faults in LC3 ($K = 8$). Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) Top segment fault. (b) Bottom segment fault.

due to the mismatch between these FIEs and the fault function. After 330s, the residuals from FIEs (#1, #3 and #4) reduce gradually due to the recovered nominal healthy condition of the FOWT. In addition, the actual fault function of f_2 , which essentially is a multiplicative fault as shown in Table 3, is successfully approximated according to Fig. 9(e–f). It should be noted that FIE #2 slightly underestimates the actual fault function at the beginning (305s–311s) according to Fig. 9(e). After that, the real value of the fault is gradually approximated by FIE #2.

Similarly, the isolation results of the actuator fault (f_6) in LC2 and the sensor fault (f_4) in LC4 are presented in Figs. 10 and 11. It is concluded that both the additive fault function of the generator torque and multiplicative fault function of the rotor speed, are gradually learned by FIE#6 and FIE#4. This verifies the effectiveness of the fault isolation capability of the proposed mixed FD architecture.

4.3. Signal-based FD for the mooring lines

Regarding the signal-based FD for the two representative mooring line faults in F_2 , the Hamming window function [45] is used for computing STFT and obtain the training spectral pattern of $\tilde{\alpha}$ in healthy and faulty conditions. The length of the moving Hamming window is 1000 samples while the overlap between consecutive windows is 10 samples. The length of the fast Fourier transform, on the other hand, is 2000 samples. During the KNN classification, P , Q and K in eq. (16) are set to be 1000, 64 and 8, respectively.

Based on eqs. 15 and 16, some selected FD results of the mooring line faults are presented in Figs. 12 and 13 for discussion. In general, KNNs derived from the distance between the spectral patterns and the measurement output are able to indicate the state of the mooring lines. Both mooring line faults are successfully detected and isolated at around 310s when the neighbors of




Fig. 13. Norm of the distance between the spectral patterns and the measurement output and KNN for the signal-based FD of the mooring line faults in LC4 ($K = 8$). Light grey shadow indicates the fault scenarios corresponding to the fault time in Table 4. (a) Top segment fault. (b) Bottom segment fault.

Table 7

Fault detection results of three architectures, where \checkmark is accurate detection, \circ is delay detection with more than one sample, \times is missed detection).

LC	Mixed FD							PCA							DPCA						
	1	2	3	4	5	6	7	1	2	3	4	5	6	7	1	2	3	4	5	6	7
f_1	\checkmark	\circ	\checkmark	\checkmark	\circ	\circ	\checkmark	\checkmark	\circ	\times	\times	\times	\times	\checkmark	\checkmark	\circ	\times	\times	\times	\times	\times
f_2	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\checkmark	\checkmark	\times	\checkmark	\circ	\checkmark	\times	\checkmark	\checkmark	\times
f_3	\checkmark	\circ	\checkmark	\circ	\circ	\circ	\checkmark	\checkmark	\checkmark	\checkmark	\times	\circ	\times	\checkmark	\checkmark	\checkmark	\checkmark	\times	\circ	\times	\checkmark
f_4	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\checkmark	\checkmark	\checkmark	\times	\circ	\times	\checkmark	\checkmark	\checkmark	\circ	\times	\checkmark	\times	\checkmark
f_5	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\circ	\circ	\times	\checkmark	\checkmark	\times	\checkmark	\checkmark	\circ	\times	\checkmark	\checkmark
f_6	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\checkmark	\circ	\circ	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\times	\checkmark	\circ	\checkmark
f_7	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\times	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\times	\times	\times	\checkmark
f_8	\checkmark	\circ	\circ	\checkmark	\circ	\circ	\times	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\times	\checkmark	\circ	\times
f_9	\checkmark	\checkmark	\checkmark	\circ	\checkmark	\circ	\checkmark	\checkmark	\checkmark	\checkmark	\circ	\times	\times	\checkmark	\circ	\times	\checkmark	\circ	\times	\times	\checkmark
f_{10}	\circ	\circ	\circ	\circ	\circ	\circ	\circ	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times
f_{11}	\circ	\circ	\circ	\circ	\circ	\circ	\circ	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times	\times

the faulty signals indicate the FOWT benchmark violating nominal healthy conditions. Moreover, it is evident from Figs. 12 and 13 that the detection delay time [10] is around 10s, which is dependent on the moving Hamming window length utilized in

the Fourier transform. Considering the time windows utilized in the transform ($1000 \times T_s$), such a detection time is acceptable. It is worth noting that the FD results in the turbulent wind condition (LC4) show similar patterns as the laminar one (LC1), which

indicates the robustness of the signal-based scheme in the proposed mixed FD architecture.

4.4. Comparison to other approaches

In order to illustrate the advantages and limitations of the proposed mixed FD architecture, two classical approaches, which have been developed by previous researchers, are implemented for the 10 MW FOWT benchmark reported in the present study. Briefly, both of them are introduced here.

1. Principal Component Analysis (PCA): this well-known technique employs an orthogonal transformation to convert a series of correlated variables into linearly uncorrelated variables. Krüger et al. [46], Pozo et al. [47] and Wang et al. [48] employed such a PCA-based approach to detect and identify faults in wind turbines.
2. Dynamic Principal Component Analysis (DPCA): The DPCA approach uses the time-lagged version of the system input and output to develop a model for monitoring purposes, and has been widely used for the fault detection of dynamic systems [46,48]. Rato and Reis [49] established the DPCA model based on decorrelated residuals to detect several faults and illustrated the reliability of such an approach in the fault detection.

In order to provide detection data for comparisons, both of aforementioned two classical approaches, PCA [48] and DPCA [49] are implemented and applied to detect faults in the 10 MW FOWT benchmark. Comparisons between the mixed FD architecture developed in the present study and these two classical approaches are carried out. The FD results are summarized in Table 7.

It is discerned that the proposed mixed FD architecture detected most expected faults in laminar wind conditions (LC1-LC3 and LC7), except for some detection delay on f_1, f_3, f_8, f_{10} and f_{11} and missed detection on f_8 in the case below the rated wind speed. However, the classical PCA and DPCA have missed detection in LC2, LC3 and LC7 several times. Under turbulent wind conditions (LC4-LC6), the mixed FD architecture had more detection delay for $f_1, f_3 - f_4, f_6, f_8 - f_{11}$. PCA failed to detect $f_1, f_3 - f_4, f_{10} - f_{11}$ and was not always able to detect f_9 . DPCA instead failed to detect $f_1, f_3 - f_4, f_7, f_{10} - f_{11}$ and was inconsistent in detecting f_2, f_6 and $f_8 - f_9$, thus seeming the less reliable method for detecting faults in turbulent wind conditions.

Based on these comparisons, it is concluded that the proposed mixed FD architecture has the best performance in detecting the considered faults in all load cases, despite the fact it needs further improvement to detect f_8 in the wind case below the rated value (LC7) and to reduce detection delay in some fault scenarios.

5. Conclusions

FOWTs operate in the hostile marine environment with restricted accessibility and maintainability. Currently, there is no all-encompassing FD architecture deployed on FOWTs. Such an absence poses a big challenge to reliability engineers and may potentially lead to increased O&M costs. In this paper, a mixed FD architecture is established by integrating a model-based and a signal-based scheme to detect and isolate a mix of critical faults for FOWTs. In order to verify the developed mixed FD architecture, a 10 MW FOWT benchmark, including specific predefined faults, is developed by extending the widely-used FAST code. In particular, the structural faults of the rotor blades and of the mooring lines, for the first time, are taken into account for the FD purpose. While the model-based scheme is used to detect and isolate the actuator and sensor faults, the signal-based scheme is mainly used to detect the

faults associated with the mooring lines, using only existing available measurements.

In order to illustrate the advantages of the proposed mixed FD architecture, comparisons are drawn with the two other classic signal-based FD approaches: PCA and DPCA. When comparing the detection and isolation of faults, results show that the proposed mixed FD architecture is able to detect and isolate critical FOWT faults in different load cases effectively. Compared to two classical PCA and DPCA approaches, the proposed mixed FD architecture has the best performance in fault detection of FOWTs in realistic wind and wave conditions.

Even though this approach shows promising results, some limitations are still lingering. For instance, it does not take into account the isolation of the unstructured fault. In addition, the fault detection robustness, which is affected by the wind turbulence, should be further investigated.

Based on these discussions, it is suggested that in the future the architecture could be extended by including a reduced-order nonlinear physical model of the 10 MW FOWT benchmark, as well as a more general fault model and the capability to do fault isolation for unstructured faults. In addition, the proposed mixed FD architecture can be tailored to other types of FOWTs, such as Spar type, tension leg platform type of FOWTs. Furthermore, it can be also extended to bottom-fixed wind turbines. Moreover, fault tolerant control design for the 10 MW FOWT benchmark should be investigated by combining the proposed mixed FD architecture with fault accommodation techniques.

CRedit authorship contribution statement

Yichao Liu: Simulation, Data process, Visualization, Investigation, Writing - review & editing, Writing - original draft. **Riccardo Ferrari:** Methodology, Writing - review & editing, Supervision. **Ping Wu:** Data process. **Xiaoli Jiang:** Writing - review & editing, Supervision. **Sunwei Li:** Writing - review & editing. **Jan-Willem van Wingerden:** Supervision, Fault Diagnosis of the 10 MW Floating Offshore Wind Turbine Benchmark: a Mixed Model and Signal-based Approach.

Declaration of competing interest

The authors declare that they have no known competing financial interests or personal relationships that could have appeared to influence the work reported in this paper.

Acknowledgments

This work was supported by the European Union via a Marie Skłodowska-Curie Action (Project EDOWE, grant 835901).

References

- [1] M. deCastro, S. Salvador, M. Gómez-Gesteira, X. Costoya, D. Carvalho, F. Sanz-Larruga, L. Gimeno, Europe, China and the United States: three different approaches to the development of offshore wind energy, *Renew. Sustain. Energy Rev.* 109 (2019) 55–70.
- [2] F. Taveira-Pinto, P. Rosa-Santos, T. Fazerer-Ferradosa, *Marine renewable energy*, *Renew. Energy* 150 (2020) 1160–1164.
- [3] K. Ohlenforst, S. Sawyer, A. Dutton, B. Backwell, R. Fiestas, J. Lee, L. Qiao, F. Zhao, N. Balachandran, *Global Wind Report 2018, 2019. Report, GWEC*.
- [4] Y. Liu, S. Li, Q. Yi, D. Chen, Developments in semi-submersible floating foundations supporting wind turbines: a comprehensive review, *Renew. Sustain. Energy Rev.* 60 (2016) 433–449.
- [5] S. Cho, Z. Gao, T. Moan, Model-based fault detection, fault isolation and fault-tolerant control of a blade pitch system in floating wind turbines, *Renew. Energy* 120 (2018) 306–321.
- [6] S. Faulstich, B. Hahn, P.J. Tavner, Wind turbine downtime and its importance for offshore deployment, *Wind Energy* 14 (2011) 327–337.
- [7] A.C. Levitt, W. Kempton, A.P. Smith, W. Musial, J. Firestone, Pricing offshore

- wind power, *Energy Pol.* 39 (2011) 6408–6421.
- [8] I. Dinwoodie, D. McMillan, M. Revie, I. Lazakis, Y. Dalgic, Development of a combined operational and strategic decision support model for offshore wind, *Energy Procedia* 35 (2013) 157–166.
 - [9] C. Saha, A.K. Singh, A review article on fault-tolerant control (ftc) and fault detection isolation (fdi) schemes of wind turbine, in: V. Nath, J.K. Mandal (Eds.), *Proc. of the Second Int. Conf. on Microelectronics, Computing & Communication Systems (MCCS 2017)*, Springer Singapore, Singapore, 2019, pp. 87–95.
 - [10] S.X. Ding, *Model-based Fault Diagnosis Techniques*, Springer, 2008.
 - [11] P.F. Odgaard, J. Stoustrup, M. Kinnaert, Fault tolerant control of wind turbines – a benchmark model, *IFAC Proc.* 42 (2009) 155–160.
 - [12] W. Chen, S.X. Ding, A. Haghani, A. Naik, A.Q. Khan, S. Yin, Observer-based fdi schemes for wind turbine benchmark, *IFAC Proc.* 44 (2011) 7073–7078.
 - [13] A.A. Ozdemir, P. Seiler, G.J. Balas, Wind turbine fault detection using counter-based residual thresholding, *IFAC Proc.* 44 (2011) 8289–8294.
 - [14] N. Laouti, N. Sheibat-Othman, S. Othman, Support vector machines for fault detection in wind turbines, *IFAC Proc.* 44 (2011) 7067–7072, 18th IFAC World Congress.
 - [15] X. Zhang, Q. Zhang, S. Zhao, R. Ferrari, M.M. Polycarpou, T. Parisini, Fault detection and isolation of the wind turbine benchmark: an estimation-based approach, *IFAC Proc.* 44 (2011) 8295–8300, 18th IFAC World Congress.
 - [16] P.F. Odgaard, J. Stoustrup, M. Kinnaert, Fault-tolerant control of wind turbines: a benchmark model, *IEEE Trans. Contr. Syst. Technol.* 21 (2013) 1168–1182.
 - [17] H. Sanchez, T. Escobet, V. Puig, P.F. Odgaard, Fault diagnosis of an advanced wind turbine benchmark using interval-based arrs and observers, *IEEE Trans. Ind. Electron.* 62 (2015) 3783–3793.
 - [18] M. Hosseinzadeh, F. Rajaei Salmasi, Analysis and detection of a wind system failure in a micro-grid, *J. Renew. Sustain. Energy* 8 (2016), 043302.
 - [19] A. Mojallal, S. Lotfifard, Multi-physics graphical model-based fault detection and isolation in wind turbines, *IEEE Trans. Smart Grid* 9 (2018) 5599–5612.
 - [20] J.M. Jonkman, M.L. Buhl, *Fast User's Guide*, SciTech Connect: FAST User's Guide, 2005.
 - [21] J. Chen, Z. Hu, G. Liu, D. Wan, Coupled aero-hydro-servo-elastic methods for floating wind turbines, *Renew. Energy* 130 (2019) 139–153.
 - [22] M. Ghane, A. Rasekhi Nejad, M. Blanke, Z. Gao, T. Moan, Condition monitoring of spar-type floating wind turbine drivetrain using statistical fault diagnosis, *Wind Energy* 21 (2018) 575–589.
 - [23] D. Zhang, L. Qian, B. Mao, C. Huang, B. Huang, Y. Si, A data-driven design for fault detection of wind turbines using random forests and xgboost, *IEEE Access* 6 (2018) 21020–21031.
 - [24] R.M.G. Ferrari, T. Parisini, M.M. Polycarpou, A robust fault detection and isolation scheme for a class of uncertain input-output discrete-time nonlinear systems, *Am. Control Conf.* (2008) 2804–2809.
 - [25] A. Fontanella, I. Bayati, M. Belloli, Linear coupled model for floating wind turbine control, *Wind Eng.* 42 (2018) 115–127.
 - [26] A. Fontanella, I. Bayati, M. Belloli, Control of floating offshore wind turbines: reduced-order modeling and real-time implementation for wind tunnel tests, in: *ASME 2018 37th Int. Conf. on Ocean, Offshore and Arctic Eng.*, American Society of Mechanical Engineers, pp. V010T09A081–V010T09A081.
 - [27] H. Badihi, Y. Zhang, H. Hong, Wind turbine fault diagnosis and fault-tolerant torque load control against actuator faults, *IEEE Trans. Contr. Syst. Technol.* 23 (2015) 1351–1372.
 - [28] X. Wei, M. Verhaegen, T. van den Engelen, Sensor fault diagnosis of wind turbines for fault tolerant, *IFAC Proc.* 41 (2008) 3222–3227.
 - [29] P.M. Pawar, R. Ganguli, On the effect of progressive damage on composite helicopter rotor system behavior, *Compos. Struct.* 78 (2007) 410–423.
 - [30] J. Degrieck, W. Van Paepegem, Fatigue damage modeling of fibre-reinforced composite materials: Review, *Appl. Mech. Rev.* 54 (2001) 279–300.
 - [31] v.B. Thomas, *Mooring Line Failure Detection of a Single Point Mooring System: a Model-Based Approach*, Thesis, Faculty of Mechanical, Maritime and Materials Engineering, 2018, 3mE.
 - [32] Y. Liu, S. Li, P.W. Chan, D. Chen, On the failure probability of offshore wind turbines in the China coastal waters due to typhoons: a case study using the oc4-deepcwind semisubmersible, *IEEE Trans. Sustain. Energy* 10 (2019) 522–532.
 - [33] R.J. Patton, P.M. Frank, R.N. Clarke, *Fault Diagnosis in Dynamic Systems: Theory and Application*, Prentice-Hall, Inc., 1989.
 - [34] T.V. Gestel, J.A.K. Suykens, P.V. Dooren, B.D. Moor, Identification of stable models in subspace identification by using regularization, *IEEE Trans. Automat. Contr.* 46 (2001) 1416–1420.
 - [35] A. Bakdi, A. Kouadri, S. Mekhilef, A data-driven algorithm for online detection of component and system faults in modern wind turbines at different operating zones, *Renew. Sustain. Energy Rev.* 103 (2019) 546–555.
 - [36] X. Zhang, M. Polycarpou, T. Parisini, Robust fault isolation for a class of non-linear input/output systems, *Int. J. Contr.* 74 (2001) 1295–1310.
 - [37] A. Yamaguchi, T. Ishihara, A new motion compensation algorithm of floating lidar system for the assessment of turbulence intensity, *J. Phys. Conf.* 753 (2016), 072034.
 - [38] P. Flandrin, *Time-Frequency/Time-Scale Analysis*, Academic Press, 1998.
 - [39] T.M. Cover, P.E. Hart, Nearest neighbor pattern classification, *IEEE Trans. Inf. Theory* 13 (1953) 21–27.
 - [40] A.K. Ghosh, P. Chaudhuri, C.A. Murthy, On visualization and aggregation of nearest neighbor classifiers, *IEEE Trans. Pattern Anal. Mach. Intell.* 27 (2005) 1592–1602.
 - [41] T. Ishihara, A. Yamaguchi, M.W. Sarwar, A study of the normal turbulence model in IEC 61400-1, *Wind Eng.* 36 (2012) 759–765.
 - [42] L. Li, Z. Gao, T. Moan, Joint distribution of environmental condition at five european offshore sites for design of combined wind and wave energy devices, *J. Offshore Mech. Arctic Eng.* 137 (2015), 031901, 031901–16.
 - [43] H.J.A.F. Tulleken, Generalized binary noise test-signal concept for improved identification-experiment design, *Automatica* 26 (1990) 37–49.
 - [44] J.W. van Wingerden, A.W. Hulskamp, T. Barlas, B. Marrant, G.A.M. van Kuik, D.-P. Molenaar, M. Verhaegen, On the proof of concept of a 'smart' wind turbine rotor blade for load alleviation, *Wind Energy* 11 (2008) 265–280.
 - [45] E. H. Bouchikhi, V. Choqueuse, M. E. H. Benbouzid, J. F. Charpentier, G. Barakat, A comparative study of time-frequency representations for fault detection in wind turbine, in: *IECON 2011 - 37th Annual Conf. of the IEEE Ind. Electron. Society*, pp. 3584–3589.
 - [46] M. Krüger, S.X. Ding, A. Haghani, P. Engel, T. Jeinsch, A data-driven approach for fault diagnosis in gearbox of wind energy conversion system, in: *Conference on Control and Fault-Tolerant Systems (SysTol)*, 2013, pp. 359–364.
 - [47] F. Pozo, Y. Vidal, Wind turbine fault detection through principal component analysis and statistical hypothesis testing, *Energies* 9 (2016).
 - [48] Y. Wang, X. Ma, P. Qian, Wind turbine fault detection and identification through pca-based optimal variable selection, *IEEE Trans. Sustain. Energy* 9 (2018) 1627–1635.
 - [49] T.J. Rato, M.S. Reis, Fault detection in the Tennessee eastman benchmark process using dynamic principal components analysis based on decorrelated residuals (dpca-dr), *Chemometr. Intell. Lab. Syst.* 125 (2013) 101–108.