

SiNx/SiO₂-Based Fabry–Perot Interferometer on Sapphire for Near-UV Optical Gas Sensing of Formaldehyde in Air

Wolffenbuttel, R.F.; Winship, Declan ; Bilby, David ; Visser, Jaco; Qin, Yutao ; Gianchandani, Yogesh

DOI

[10.3390/s24113597](https://doi.org/10.3390/s24113597)

Publication date

2024

Document Version

Final published version

Published in

Sensors

Citation (APA)

Wolffenbuttel, R. F., Winship, D., Bilby, D., Visser, J., Qin, Y., & Gianchandani, Y. (2024). SiNx/SiO₂-Based Fabry–Perot Interferometer on Sapphire for Near-UV Optical Gas Sensing of Formaldehyde in Air. *Sensors*, 24(11), Article 3597. <https://doi.org/10.3390/s24113597>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.

Article

SiN_x/SiO₂-Based Fabry–Perot Interferometer on Sapphire for Near-UV Optical Gas Sensing of Formaldehyde in Air

Reinoud Wolffenbuttel ^{1,*}, Declan Winship ² , David Bilby ³, Jaco Visser ³, Yutao Qin ²  and Yogesh Gianchandani ² 

- ¹ Laboratory for Electronic Instrumentation, Department of Microelectronics, Faculty of Electrical Engineering, Mathematics and Computer Science, Delft University of Technology, 2628 CD Delft, The Netherlands
 - ² Center for Wireless Integrated MicroSensing and Systems (WIMS2) and the Department of Electrical Engineering and Computer Science, University of Michigan, Ann Arbor, MI 48109, USA; dejawin@umich.edu (D.W.); yutaoqin@umich.edu (Y.Q.); yogesh@umich.edu (Y.G.)
 - ³ Research and Advanced Engineering, Ford Motor Company, Dearborn, MI 48121, USA; dbilby@ford.com (D.B.); jvisser@ford.com (J.V.)
- * Correspondence: r.f.wolffenbuttel@tudelft.nl

Abstract: Fabry–Perot interferometers (FPIs), comprising foundry-compatible dielectric thin films on sapphire wafer substrates, were investigated for possible use in chemical sensing. Specifically, structures comprising two vertically stacked distributed Bragg reflectors (DBRs), with the lower DBR between a sapphire substrate and a silicon-oxide (SiO₂) resonator layer and the other DBR on top of this resonator layer, were investigated for operation in the near-ultraviolet (near-UV) range. The DBRs are composed of a stack of nitride-rich silicon-nitride (SiN_x) layers for the higher index and SiO₂ layers for the lower index. An exemplary application would be formaldehyde detection at sub-ppm concentrations in air, using UV absorption spectroscopy in the 300–360 nm band, while providing spectral selectivity against the main interfering gases, notably NO₂ and O₃. Although SiN_x thin films are conventionally used only for visible and near-infrared optical wavelengths (above 450 nm) because of high absorbance at lower wavelengths, this work shows that nitride-rich SiN_x is suitable for near-UV wavelengths. The interplay between spectral absorbance, transmittance and reflectance in a FPI is presented in a comparative study between one FPI design using stoichiometric material (Si₃N₄) and two designs based on N-rich compositions, SiN_{1.39} and SiN_{1.49}. Spectral measurements confirm that if the design accounts for phase penetration depth, sufficient performance can be achieved with the SiN_{1.49}-based FPI design for gas absorption spectroscopy in near-UV, with peak transmission at 330 nm of 64%, a free spectral range (FSR) of 20 nm and a full-width half-magnitude spectral resolution (FWHM) of 2 nm.

Keywords: optical MEMS; nitride-rich SiN_x; microspectrometer; absorption spectroscopy; CMOS-compatible optical sensors; near-UV optical sensor; optical gas sensor; Bragg reflector with lossy layers; Fabry–Perot resonator with lossy layers



Citation: Wolffenbuttel, R.; Winship, D.; Bilby, D.; Visser, J.; Qin, Y.; Gianchandani, Y. SiN_x/SiO₂-Based Fabry–Perot Interferometer on Sapphire for Near-UV Optical Gas Sensing of Formaldehyde in Air. *Sensors* **2024**, *24*, 3597. <https://doi.org/10.3390/s24113597>

Academic Editors: Francesco De Leonardis, Vanda Pereira, Marta S. Ferreira and João Micael Leça

Received: 29 March 2024

Revised: 26 May 2024

Accepted: 29 May 2024

Published: 3 June 2024



Copyright: © 2024 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

Formaldehyde (CH₂O) is a volatile organic compound (VOC) and is known as a major cause of sick building syndrome (SBS) [1,2]; more significantly, it is a cause of inflammation of lung epithelial cells and a potential human carcinogen [3]. The World Health Organization (WHO) has recognized formaldehyde as a health hazard and has set the permissible exposure limit (PEL) at 2 ppm for short-term (15 min) exposure [4]. The US National Institute for Occupational Safety and Health (NIOSH) focuses on long-term exposure with an emphasis on the effect of accumulated exposure at the workplace and, for instance, has set the maximum long-term PEL for formaldehyde at 0.75 ppm for an 8-hr exposure [5].

Formaldehyde is one of the components that are generated in combustion, but also results from wood processing [6,7]. Drying of wood results in formaldehyde emission of up to $350 \mu\text{g}$ per m^3 of wood (from spruce or chestnut when dried at 140°C [8]). Moreover, emission continues for years after newly placed timber panels have become part of the interior of a home (up to $70\text{--}80 \mu\text{g}\cdot\text{m}^{-2}\cdot\text{hr}^{-1}$ for spruce and beech) [8,9]. The possible indoor exposure levels during a vacation in a recently built all-timber cabin can be significant. Consider a simplified analysis of a family cabin with a floor area of $8 \times 6 \text{ m}^2$ and a roof at 2.5 m height. Assume the cabin floorplan results in an inside volume of 120 m^3 and a total inside area of wood surface of 300 m^2 . Using a realistic value for emission from timber of $50 \mu\text{g}\cdot\text{m}^{-2}\cdot\text{hr}^{-1}$ results in a total hourly formaldehyde generation of 15 mg. The accumulated formaldehyde concentration after an 8-h sleep amounts to $8 \times 15,000/120 = 1000 \mu\text{g}/\text{m}^3 = 33.3 \times 10^{-6} \text{ moles}/\text{m}^3$ (note that the molecular weight of formaldehyde (CH_2O) is 30). Consequently, in the case of no ventilation, the formaldehyde exposure at wake-up is equal to $33.3 \times 22.4 \times 10^{-3} = 0.75 \text{ ppm}$ (note that at standard temperature and pressure (STP) conditions, one mole of an ideal gas has a volume of $22.4 \times 10^{-3} \text{ m}^3$). Arguably, in the case of no ventilation, the formaldehyde exposure at wake-up could be close to the long-term PEL. In terms of the acute impact of the detection of a particular gas on health and safety, formaldehyde sensors can be classified alongside CO_2 sensors [10,11].

A selective gas detection limit better than 1 ppb can be achieved using professional equipment for multi-component gas composition measurement. However, traditional instrumentation for multi-component gas composition measurement is bulky, with operation based on established laboratory equipment, such as gas chromatography, differential optical absorption spectroscopy (DOAS) [12,13] and laser induced fluorescence [14]. Miniaturized versions of traditional instruments, such as the gas chromatograph, have been fabricated and a detection limit at the ppb level was demonstrated [15].

Gas optical absorption spectroscopy generally makes use of an absorption line in the mid-IR wavelength. The advantages are non-contact gas sensing and the fact that a sampler is not required. In principle, the gas detectivity can be increased by increasing the path length of the light beam traveling through the gas, and high detectivity has been demonstrated [16]. Miniaturized systems are commercially available for the selective detection of CO_2 (with characteristic absorption features in the $4.5\text{--}4.6 \mu\text{m}$ band), CO ($4.5\text{--}4.6 \mu\text{m}$ band) and N_2O ($4.5\text{--}4.6 \mu\text{m}$ band) [17,18]. A low-cost implementation, the non-dispersive Infrared NDIR, is based on a heated membrane for use as a thermal emitter; in combination with a thermal detector and an absorption path length of a few cm, it is sufficient for application in air quality monitoring. However, these gases provide no usable absorption spectra in the visible/near-UV ranges. This constraint does not generally apply to a VOC such as formaldehyde, which has characteristic spectral absorption features in both the mid-IR (at $3.5 \mu\text{m}$) and near-UV (in the $300\text{--}360 \text{ nm}$ band) wavelengths [19,20].

Although the emphasis in optical detection of formaldehyde has traditionally also been on the use of mid-infrared spectral lines, there is a growing interest in joining the general trend towards using near-UV gas absorption spectra for the selective detection of various components of a gas [20]. Absorption spectroscopy in mid-IR is based on measuring the energy levels (wave numbers) of the various atomic vibration modes, while in UV the energy levels of the different transitions of electron states are measured. One of the consequences is the less pronounced gas spectral absorption features in UV as compared to the absorption lines in mid-IR, and the magnitude of the absorption coefficient is also lower. The advantage of measurement in near-UV is the limited overlap between the spectra of gases of interest, as compared to the relatively crowded mid-IR. Moreover, UV absorption spectroscopy in ambient air is not affected by water absorption bands, and the lower limit of the wavelength range is at about 220 nm due to oxygen absorption. In mid-IR practical operation is limited to several spectral windows in between water absorption bands. An enabling factor for miniaturized systems for absorption spectroscopy in near-UV is the availability of efficient UV LEDs, which bring significant advantages relative to heated

membrane thermal emitters, which are micromachined in a silicon wafer, in terms of optical output, power consumption and costs [21].

The optical absorption cross-section, σ , of a formaldehyde molecule in near-UV is shown in Figure 1a, in combination with that of the main interfering gases, NO₂ and O₃ [22,23]. The essential spectral information for the detection of formaldehyde is in the 300–360 nm band. However, this absorption spectrum overlaps with those of O₃ and NO₂, which are present in the lower atmosphere partly due to our collective legacy of past emissions [24]. A significant part of the concentrations of NO₂ and NO originates from NO_x emissions and is associated with the generation of ozone [25]. The molecular absorption cross-section of NO in UV is in the 185–225 nm band and thus outside the part of the spectrum that is relevant to the detection of formaldehyde. The concentration of NO₂ in air depends on amount of traffic and time of the day, but a typical value at sea level is about $Conc(NO_2) = 0.045$ ppm [26]. Similarly, the concentration of ozone at sea level is about $Conc(O_3) = 0.025$ ppm [27]. Combining these concentrations with the respective molecular cross sections results in the spectral absorption coefficients as shown in Figure 1b (note that: $Conc [\text{molecules}/\text{cm}^3] = Conc [\text{ppm}] \times 10^{-6} \times N_{STP} = Conc [\text{ppm}] \times 2.687 \cdot 10^{13}$ and $\alpha [\text{cm}^{-1}] = \sigma [\text{cm}^2/\text{molecule}] \times Conc [\text{molecules}/\text{cm}^3]$).




Figure 1. (a) Absorption cross-sections of formaldehyde (H₂CO) and the two main interfering gases in near-UV: NO₂ and O₃; (b) Absorption coefficient of formaldehyde at 0.1 ppm and 1 ppm concentrations in the presence of NO₂ and O₃ in their concentrations in the lower atmosphere.

The absorption coefficient for formaldehyde, α_{H_2CO} , at several concentrations is also included, which provides a basis for the assessment of the detection limit that is constrained by selectivity. Although the spectra of NO₂, O₃ and H₂CO are overlapping, differences in the detail of the spectral information can be used to resolve the three components using data processing of the full spectral information, which is the main incentive for using high-resolution absorption spectroscopy. A concentration $Conc(H_2CO) = 0.1$ ppm is at the threshold of being detectable and requires such optical data processing for selective detection. The objective of this work is to present N-rich SiN_x as a suitable material in a system realized on sapphire for achieving such a level of gas detectivity; it does not include the fabrication and testing of the actual optical gas sensor. The gas detectivity requirement is imposed by the application, and it can be concluded that UV absorption spectroscopy can be used. However, the instrument ultimately measures the change in light intensity at the optical detector due to optical absorption in a column of gas, which is set by the capability

for reproducibly measuring the minimum (variation in) absorbance $A = \alpha L$ (with α the spectral absorption coefficient and L the length of the absorption path) and determines the gas detection limit depending on instrument specifications.

Although a full instrument design is not the goal of this investigation, it is worth noting that using established techniques, such as a chopped/AC-operated light source, a DOAS set-up and coherent detection at the detector as shown in Figure 2, the gas detection limit can be improved to the point that it is limited primarily by the equivalent detection limit of the optical system, $A_{\text{det,eq}}$, most notably by the short-term light source instability and detector noise. Typical values are from $A_{\text{det,eq}} \sim 10^{-6}$ in high-end professional instrumentation to $A_{\text{det,eq}} \sim 10^{-5}$ in a commercially viable consumer product. A dedicated CMOS circuit with a detector is designed for implementation in a commercially viable consumer product, and the optical detection limit is unlikely to be much better than $A_{\text{det,eq}} \sim 10^{-5}$. Consequently, for the measurement of spectral absorbance with a detection limit at $\alpha_{\text{det}} = 10^{-7} \text{ cm}^{-1}$, as shown in Figure 1b, an absorption path length $L_{\text{min}} = A_{\text{det,eq}}/\alpha_{\text{det}} = 100 \text{ cm}$ is required.




Figure 2. Setup of the dual-channel configuration that can be used for gas absorption spectroscopy.

The absorption path length is one of the aspects that determines the system implementation. This path length can be realistically implemented in a system for operation in a home, but is not compatible with the dimensions of a lithographically microfabricated chip. Another system aspect that would be difficult to combine with on-chip integration is a UV LED, which usually comes as a commercial-off-the-shelf (COTS) component. Therefore, in this work a hybrid implementation is envisioned: FPIs are fabricated on sapphire wafers through PECVD of layers of SiN_x and SiO_2 , maintaining the low-cost advantage in high-volume batch production, while using equipment that is available in a commercial microfabrication foundry.

2. Materials and Methods

2.1. Using Silicon Nitride as an Optical Material in Near-UV

The FPI is composed of a relatively thick optical resonator layer between two distributed Bragg reflectors (DBRs) acting as mirrors. DBRs are based on a stack of alternating dielectric layers of two different materials, with the first referred to as the high-index dielectric material (n_H) and the second as the material of low index (n_L). The spectral selectivity of the DBR depends on the ratio between n_H and n_L , which should be maximized, and the number of layer pairs [26]. SiO_2 is very suitable as a low-index material ($n_L = 1.46\text{--}1.51$) and it offers very low optical loss over most of the near-UV, visible and near-IR spectral ranges.

In a microfabrication facility, a variety of options are available for the deposition of SiO_2 , as it is widely used in electronics and MEMS. One option that is attractive for this work is plasma-enhanced chemical vapor deposition (PECVD), which is suitable for both deposition rate and film quality, with the additional benefit that it has a low thermal budget (thus, does not cause an appreciable change in the performance of active components already integrated in the substrate), which makes it attractive for back-end processes on a variety of substrates. Because of its slow deposition rate, sputtering is not a candidate if the entire FPI, including the resonator later, must be deposited in a single tool.

The selection of a microfabrication-compatible high-index DBR material presents a greater challenge. TiO_2 is often used, because of its relatively high index $n_H \sim 2.8$ and low loss in the visible spectral range, which makes it a very suitable material for use in the visible wavelength; however its $k > 0.5$ for $\lambda < 400 \text{ nm}$ makes it generally not acceptable for use in near-UV [26]. In the 250–400 nm band, HfO_2 is usually considered a very suitable

candidate for n_H [27–29], and the $\text{HfO}_2/\text{SiO}_2$ combination has actually been used for realization of a microspectrometer based on a linearly variable optical filter (LVOF) [30]. Ta_2O_5 is in principle also a candidate [31]. In all these cases SiO_2 remains the material of choice for n_L . Combinations of fluorides, such as LaF_3 for n_H and MgF_2 for n_L , can in principle also be considered, despite their limited CMOS fabrication compatibility, but their achievable optical index contrast with SiO_2 is small [32–34].

Because of the attractiveness of PECVD as a practical, foundry-compatible micro-fabrication tool for the entire FPI, it is important to consider a high-index material that can be easily deposited by this tool. In this work, we focus on PECVD nitride-rich SiN_x for n_H [35,36]. The choice of N-rich SiN_x is not obvious. Much has been published on Si-rich SiN_x , which is a low-stress material that has excellent properties for optical design in near-IR and is and has been used for waveguides operated at 1550 nm [37]. However, its optical loss for wavelengths shorter than 450 nm makes the Si-rich material unsuitable for optical design in near-UV. The near-UV application presents an additional challenge: unlike the case for the IR range, where Si-rich SiN_x can be adjusted to maximize n by minimizing x without concern for optical loss, in near-UV design the adjustment of N-rich SiN_x requires a carefully tuned compromise for a composition that stays above the necessary threshold of the optical index to serve as a high-index material, while staying below the threshold of the extinction coefficient for unacceptable optical loss.

In our earlier work we found N-rich SiN_x with $x \sim 1.49$ to be an optimum composition when also considering the repeatability of the deposition rate [36]. This material provides good optical performance in the near UV (300–400 nm), with $n \sim 2.02$ and $k < 10^{-2}$ at the design wavelength $\lambda_0 = 330$ nm. The spectral dependence of n and k for the different compositions of SiN_x used in this work is shown in Figure 3.




Figure 3. (a) Index of refraction, n , and (b) extinction coefficient, k , for PECVD Si_3N_4 , $\text{SiN}_{1.39}$ and $\text{SiN}_{1.49}$ considered here, in the spectral range 200–450 nm. These curves are extracted from ellipsometry data (Woollam M-2000) using the Tauc–Lorentz model with mean squared error (MSE) of 3.10, 1.93 and 3.83 respectively.

2.2. Fabry–Perot Interferometer Design

In its most generic representation, an FPI is composed of a resonator in between two identical reflectors, each with a transmission coefficient t (transmittance $T = t \cdot t^*$) and reflection coefficient r (reflectance $R = r \cdot r^*$). The overall transmittance through the FPI, T_{FPI} , is the transmitted optical irradiance I_t relative to the incident intensity I_i , and can be

derived by collecting all transmitted wave components after (multiple) reflection at the two mirrors, and results at normal light incidence in [38]:

$$T_{FPI} = \frac{I_t}{I_i} = \frac{T^2}{R^2 - 2R\cos(\delta) + 1} = \frac{T^2}{(1-R)^2} \times \frac{1}{1 + \left(\frac{4R}{(1-R)^2}\right) \sin^2\left(\frac{\delta}{2}\right)} \quad (1)$$

$$= \frac{T^2}{(1-R)^2} \times \frac{1}{1 + F\sin^2\left(\frac{\delta}{2}\right)}$$

with δ the round-trip phase delay, $\delta = 4\pi n_{\text{res}}(\lambda) t_{\text{res}}/\lambda$ for a light beam after traveling from the mirror of entrance into the resonator layer, being reflected at the second mirror and returning to the mirror of incidence, and $F = 4R/(1 - R)^2$ the coefficient of finesse. The peak transmission is at $\sin^2(\delta/2) = 0$, which is equivalent to $\delta_{\text{max},m}/2 = 2m \times \pi/2 \rightarrow \delta_{\text{max},m} = m \times 2\pi$ with m the order of the resonance. Consequently:

$$\lambda_{\text{max},m} = \frac{4\pi n_{\text{res}} t_{\text{res}}}{\delta_{\text{max},m}} = \frac{2n_{\text{res}} t_{\text{res}}}{m}, \quad (2)$$

Designing for operation at a high-order mode is advantageous, because the selectivity of the filter is defined by the spectral resolution (the full-width half magnitude bandwidth at order m , $FWHM_m$), which can be expressed as:

$$FWHM_m \sim \lambda_{\text{max},m} \times \frac{2}{m \times \pi \sqrt{F}}, \quad (3)$$

Therefore, $FWHM_m$ scales down with order m . The minimum usable mode results from the specifications and a reasonably achievable value for F when considering the fabrication technology. The near-UV spectral absorption characteristics of formaldehyde, as presented in Figure 1, result in a mid-band resonance wavelength at about $\lambda_{\text{max},m} = 330$ nm and $FWHM_m \sim 1$ –2 nm. For $F_{\text{max}} \sim 200$ ($R \sim 0.86$) the minimum operating order required for meeting the specification on spectral resolution $m_{\text{min}} = (\lambda_{\text{max},m}/FWHM_m)_{\text{spec}} \times (2/\pi\sqrt{F_{\text{max}}}) = (330/1) \times (0.045) \sim 15$. However, FPI optical design should also meet the required spectral spacing between peak transmissions, the free spectral range at order m FSR_m :

$$FSR_m = \lambda_{\text{max},m} - \lambda_{\text{max},m+1} = 2n_{\text{res}} t_{\text{res}} \left(\frac{1}{m} - \frac{1}{m+1} \right) = \frac{\lambda_{\text{max},m}}{m+1}, \quad (4)$$

As a consequence, $m = 15$ results in $FSR_{15} = 330/16 = 20.6$ nm, which is smaller than the full band containing relevant information about formaldehyde, but at this stage can be considered adequate for its selective detection by capturing the gas-specific spectral signature. It should be noted that the ratio $FSR_m/FWHM_m = (\pi/2)(m+1)\sqrt{F_{\text{max}}}/m$, which for $m \gg 1$ primarily depends on F . Obviously, more demanding specifications can be met in a design or technology that provides higher mirror reflectance and thus higher F .

In the most-conventional configuration, a distributed Bragg reflector (DBR) is used as the implementation of each of the mirrors, which results in the FPI structure shown in Figure 4. The FPI design presented is composed of a 19-layer structure, with the 9-layer lower DBR directly on top of the sapphire substrate and the same 9-layer DBR design forming the top of the structure and facing the medium of incidence (air) with a thick resonator layer in between. A DBR is generally composed of a stack of layers of alternately high-index material of thickness t_H and low-index material of thickness t_L , while the resonator, with thickness t_{res} , is of the low-index material. In this work SiN_x was used as the high-index material ($t_H = t_N$) and SiO_2 as the low-index material ($t_L = t_O$) and the layer thicknesses are referred to in the following as t_N and t_O .




Figure 4. Structure of a Fabry–Perot interferometer using 9-layer distributed Bragg reflectors with SiN_x ($t_H = t_N$) as the high-index material and SiO_2 as the low-index material ($t_L = t_O$).

The input admittance of the overall optical system composed of the stack of thin films on a substrate can be defined as $y_{\text{sys}} = n_{\text{sys}} \times y_{\text{fs}} = C/B$, with $y_{\text{fs}} = (\epsilon_o/\mu_o)^{1/2}$ the admittance of air (free space), parameter B the ratio between the electric field component at the incident side of the thin film (at the interface between the medium of incidence and the film) and that at the exit side of the thin film (at the interface between the film and the substrate), and C as the ratio between the magnetic field component at the incident side of the thin film and that at the exit side of the thin film. The notation in terms of admittances can be used to derive the generalized expression for the coefficient of reflectance of the overall system, r_{sys} [38]:

$$r_{\text{sys}} = \frac{y_{\text{fs}} - C/B}{y_{\text{fs}} + C/B} = \frac{y_{\text{fs}} - y_{\text{sys}}}{y_{\text{fs}} + y_{\text{sys}}}. \quad (5)$$

For a system comprising a single film, B and C can be calculated by considering the continuity requirements of the tangential (in-plane) components of the incident and reflected fields at the optical interface of incidence (between air and the film). For a single film with admittance y_2 , on a substrate with admittance y_{sub} [38]:

$$\begin{bmatrix} B \\ C \end{bmatrix} = [M] \cdot \begin{bmatrix} 1 \\ y_{\text{sub}} \end{bmatrix} = \begin{bmatrix} \cos(\delta/2) & j \frac{\sin(\delta/2)}{y_2} \\ jy_2 \sin(\delta/2) & \cos(\delta/2) \end{bmatrix} \cdot \begin{bmatrix} 1 \\ y_{\text{sub}} \end{bmatrix}, \quad (6)$$

with M the characteristic matrix of the single-layer system and $(\delta/2) = 2\pi n_2(\lambda)t_2/\lambda$ the one-way phase shift upon traversal of the film (half the round-trip phase delay δ for light traveling through the layer). In the FPI design only two materials were used: SiO_2 with $n_L = n_O$ and admittance y_{2L} , and SiN_x with $n_H = n_N$ and admittance y_{2H} . Their respective characteristic matrices are:

$$[M_L] = \begin{bmatrix} \cos(\delta/2) & j \frac{\sin(\delta/2)}{y_{2L}} \\ jy_{2L} \sin(\delta/2) & \cos(\delta/2) \end{bmatrix}; [M_H] = \begin{bmatrix} \cos(\delta/2) & j \frac{\sin(\delta/2)}{y_{2H}} \\ jy_{2H} \sin(\delta/2) & \cos(\delta/2) \end{bmatrix}. \quad (7)$$

For an effective DBR, each layer in the stack should be at the resonance for the design wavelength: $\delta/2 = \pi/2$. Therefore, the layer thickness is tuned $n_H(\lambda_o)t_N = n_L(\lambda_o)t_O = \lambda_o/4$, which is referred to as the quarter-wavelength optical thickness (QWOT), t_{QWOT} . In conventional optical filter design, materials are usually selected for which optical losses in the targeted spectral operating range can be disregarded ($k = 0$ and δ depends on $n^* = n$) and the diagonal elements in M_L and M_H are zero. This results in a significant simplification and enables the derivation of analytical expressions for the peak reflectance.

The loss in near-UV is explicitly not disregarded and is accounted for in the extinction coefficient, k , of the complex index of refraction, $n^* = n - jk$. Therefore, the admittance of a layer is also a complex number. The diagonal matrix elements are non-zero complex

numbers and calculation of the spectral reflectance of the 9-layer DBR and the transmittance of the 19-layer FPI requires numerical matrix multiplication:

$$\begin{bmatrix} B \\ C \end{bmatrix} = [M_{DBR}] \cdot [M_{res}] \cdot [M_{DBR}] \cdot \begin{bmatrix} 1 \\ y_{sub} \end{bmatrix}, \text{ with} \quad (8)$$

$$[M_{DBR}] = [M_H] \cdot [M_L] \cdot [M_H] \cdot [M_L] \cdot [M_H] \cdot [M_L] \cdot [M_H] \cdot [M_L] \cdot [M_H]$$

with M_H and M_L the characteristic matrix of a QWOT layer of the high-index material and low-index material, respectively, and M_{res} the characteristic matrix of the resonator layer with its optical thickness tuned in principle to the 15th-order resonance: $n_L(\lambda_o)t_{res} = m\lambda_{\max,m}/2 = 7.5\lambda_{\max,m}$. The layer thickness for a DBR with lossy layers is set to t_{QWOT} , which provides resonance at λ_o , but the actual layers do in addition result in a loss component. From Equation (8) the reflection coefficient $r_{sys} = r_{FPI}$ can be calculated, from which the expressions for spectral reflectance $R_{FPI}(\lambda)$, transmittance $T_{FPI}(\lambda)$, and absorbance $A_{FPI}(\lambda)$ of the FPI result. These are presented in the literature and are not reproduced here [38] (p. 56).

The approach used for simulations of the spectral response of the various options for a FPI is based on the direct implementation in Matlab of a routine for solving Equations (7) and (8) over a user-defined wavelength range and with a database of the extracted indexes of refraction and extinction coefficients of the different SiN_x compositions used (as shown in Figure 3 and listed in Table 1). Literature data on sapphire was used: $n_{\text{Al}_2\text{O}_3} = 1.81 \pm 0.04$ in the range 250 nm to 800 nm, while the extinction coefficient $k_{\text{Al}_2\text{O}_3}$ in that range can be disregarded [39]. This customized software allows the simultaneous presentation of spectral reflectance $R_{FPI}(\lambda)$, transmittance $T_{FPI}(\lambda)$, and absorbance $A_{FPI}(\lambda)$, which provides essential insight into their interplay, especially between transmittance and absorbance, at different material compositions; this information cannot be easily extracted when using commercially available software packages for optical design.

Table 1. Thickness of layers used in the final designs.

Symbol	Si_3N_4	$\text{SiN}_{1.39}$	$\text{SiN}_{1.49}$	SiO_2
$n_H(\lambda_o)$ ¹	2.213	2.136	2.021	
$n_L(\lambda_o)$				1.492
t_H [nm]	37.3	38.6	40.8	
t_L [nm]				55.2
$t_{res}(m = 14)$ ²				1200 (1216)
$t_{res}(m = 15)$ ²				1320 (1327)
$t_{res}(m = 16)$ ²				1440 (1438)

¹ Note that the number of digits used for presenting n indicates the resolution used in the calculation. The measurement inaccuracy is about 1% and the number of significant digits is limited to three. ² In brackets is the result from calculation with the effect of the phase penetration depth on resonance included, while the rounded values are used as the nominal values for simulations and layer deposition.

A complication in specifying the actual operating mode of the resonator is the fact that the mirroring plane of a DBR is not the inner front surface of the DBR, as is often assumed in FPI design, but instead a position deeper in the stack due to phase penetration [40–42]. Consequently, the FPI is actually operated at a higher mode than anticipated and incorrect conclusions are drawn from device performance when verifying the measured properties with Equations (3) and (4). Research on the position of the mirror plane within the DBR in terms of effective phase penetration depth, L_{pp} , demonstrates a dependence on the refraction index contrast of the materials used for the QWOT layers, the number of layer pairs in the DBR, and the design wavelength. From literature and the materials and dimensions used in our design, the equivalent mirror position is estimated at a distance $0.6 \times \lambda_o < L_{pp} < 0.8 \times \lambda_o$ from the interface between the resonator layer and the first inner n_H layer of the DBR. In the designs presented, we assume $L_{pp} = 0.75 \times \lambda_o = 3t_{QWOT}$ and we attempt to derive actual data from our experimental results.

As a consequence, the nominal optical resonator thickness $n_L t_{\text{res}}$ should be reduced from $15 \times \lambda_0/2 = 2475$ nm to $15 \times \lambda_0/2 - 2 \times 0.75 \times \lambda_0 = 1980$ nm for operation at $m = 15$ at $\lambda_0 = 330$ nm. The physical thicknesses of the layers used in the final FPI designs are listed in Table 1. The performance of the FPI strongly depends on the DBR design, which should provide a sufficiently high peak reflectance at the design wavelength while the bandwidth of the reflectance band should be sufficiently wide to capture the band that contains the specific information on formaldehyde. As indicated, the starting point is a 9-layer DBR. Figure 5a shows the spectral reflectance, transmittance and absorbance for a stack of Si_3N_4 based n_{H} QWOT layers alternating with SiO_2 QWOT layers for n_{L} . Similarly, Figure 5b shows these spectral responses for N-rich SiN_x -based QWOT layers for n_{H} .




Figure 5. Calculated spectral reflectance, transmittance and absorbance for the 9-layer DBR in the near-UV to short-wavelength visible spectral range (250–500 nm) for: (a) Stoichiometric SiN_x (Si_3N_4) and (b) N-rich SiN_x with $x = 1.49$.

The half-peak reflection band $\Delta\lambda(\text{SiN}_{1.49}) = 380.3 - 91.0 = 89.3$ nm is sufficiently wide for spectrally covering the three resonance modes of the FPI. In a final design, the DBR reflectance band should preferably be designed for narrowly containing one resonance band to minimize out-of-band detection, but in this work a wider band is preferred for analyzing the effect of lossy layers using the transmittance peaks at several modes. The peak reflectance of the N-rich design is slightly higher compared to the stoichiometric material ($R(330 \text{ nm}) = 0.839$ instead of 0.793), but the differences in transmittance and absorbance are more significant. While the absorbance at the design wavelength $A(330 \text{ nm}) \sim 2\%$ for $\text{SiN}_{1.49}$, $A(330 \text{ nm}) > 15\%$ for Si_3N_4 . The lower absorbance, combined with the higher reflectance of the N-rich material, is clearly an advantage and results in a DBR of higher performance. However, the peak reflectance of 0.84 is not impressive.

The compromise between high reflectance and low absorbance is very subtle, which becomes apparent when also considering SiN_x of intermediate composition ($x = 1.39$). The spectral reflectance, transmittance and absorbance of $\text{SiN}_{1.39}$ is shown in Figure 6a. The half-peak reflection band $\Delta\lambda(\text{SiN}_{1.39}) = 387.1 - 288.3 = 98.8$ nm and, as expected, is wider compared to that of $\text{SiN}_{1.49}$. However, peak reflectance is also slightly higher ($R(330 \text{ nm}) = 0.848$ for $\text{SiN}_{1.39}$ versus 0.839 for $\text{SiN}_{1.49}$), which is not obvious. As shown in Figure 6b, the in-band absorbance for $\text{SiN}_{1.39}$ decreases to about the same value as the transmittance (8%), which implies that the advantage of its higher refractive index starts to outweigh the adverse effect of absorbance on the DBR reflectance for $\lambda > \lambda_0$. The compromise between refraction index contrast and layer absorbance is skewed toward

favoring the former in the second-order reflectance peak at 450 nm, because absorbance does not play a significant role in that spectral range. Consequently, the overall specifications of a 9-layer DBR reflector in a $\text{SiN}_{1.39}$ -based design are slightly superior to those of a $\text{SiN}_{1.49}$ -based design. However, the next simulations show that the performance metrics of the 19-layer FPI design are not well served by DBRs based on $\text{SiN}_{1.39}$ and the N-rich composition, $\text{SiN}_{1.49}$, should be used for n_H .




Figure 6. (a) Calculated spectral reflectance, transmittance and absorbance for 9-layer DBR in the near-UV to short-wavelength visible spectral range (250–500 nm) for SiN_x with $x = 1.39$ and (b) spectral reflectance and absorbance for different SiN_x compositions.

The optical performance of the DBR strongly depends on the number of stacked QWOT layers, as is confirmed in Figure 7.




Figure 7. Effect of the number of n_H layers of $\text{SiN}_{1.49}$ in the stacked QWOT layer stack on (a) DBR spectral reflectance and (b) Finesse.

As expected, the peak reflectance and the associated Finesse increase with the number of layers in the DBR. The 9-layer DBR design is taken as the basis for simulations of the FPI spectral response. The following simulations all target a design with a resonator thickness $t_{\text{res}} = 1320$ nm and $m = 15$. The spectral reflectance, transmittance and absorbance of the 19-layer FPI with Si_3N_4 used for the n_{H} layers are shown in Figure 8a and those for $\text{SiN}_{1.49}$ in Figure 8b.




Figure 8. Calculated spectral reflectance, transmittance and absorbance for 19-layer FPI in the near-UV to short-wavelength visible spectral range (250–500 nm) for: (a) Stoichiometric SiN_x (Si_3N_4) and (b) N-rich SiN_x with $x = 1.49$.

Figure 8 confirms the three modes of resonance within the DBR bandwidth and the superior spectral performance of the N-rich implementation of the n_{H} layers. The peak transmission improves from $T_{\text{FPI}}(328.6 \text{ nm}) = 0.028$ for Si_3N_4 to $T_{\text{FPI}}(328.8 \text{ nm}) = 0.623$ for $\text{SiN}_{1.49}$. The peak transmission for Si_3N_4 is obviously of little practical use, because of the significant absorbance $A_{\text{FPI}}(328.6 \text{ nm}) = 0.359$, while $A_{\text{FPI}}(328.8 \text{ nm}) = 0.222$ for $\text{SiN}_{1.49}$. The $\text{SiN}_{1.49}$ -based FPI features an FWHM(328.8 nm) = 1.4 nm. The peak transmission $T_{\text{FPI}}(351.2 \text{ nm}) = 0.860$ is even higher compared to that at the primary design wavelength, which is due to the reduction in absorbance to $A_{\text{FPI}}(351.2 \text{ nm}) = 0.059$. The envelope of the spectral reflectance is in good agreement with the DBR spectral reflectance, as shown in Figure 5. However, the FWHMs of the two additional transmission peaks within the DBR bandwidth are larger, FWHM(309.0 nm) = 1.7 nm and FWHM(351.2 nm) = 2.2 nm, which is the result of fall-off of the spectral reflectance of the DBR at these wavelengths.

For validation, the spectral response of the FPI with $\text{SiN}_{1.39}$ used for the n_{H} layers was also computed and the result is shown in Figure 9a. The spectral performance of the $\text{SiN}_{1.39}$ -based FPI is, as expected, clearly in between that of the Si_3N_4 -based implementation and the one based on $\text{SiN}_{1.49}$. The peak transmission $T_{\text{FPI}}(328.8 \text{ nm}) = 0.170$. Although the FWHM(328.8 nm) = 1.5 nm is very close to that of $\text{SiN}_{1.49}$, the in-band absorbance $A(328.8 \text{ nm}) = 0.409$ exceeds even that of the Si_3N_4 -based FPI. These are remarkable aspects and result from the higher reflectance of the $\text{SiN}_{1.39}$ -based DBR, which outweighs the effect of the higher loss.




Figure 9. (a) Calculated spectral reflectance, transmittance and absorbance for 19-layer FPI in the near-UV to short-wavelength visible spectral range (250–500 nm) for SiN_x with $x= 1.39$ and (b) spectral transmittance and absorbance for the different SiN_x compositions.

The curves are combined in Figure 9b for enabling a comparison and confirm that, despite the higher $R_{\text{DBR}}(328.8 \text{ nm})$ of the $\text{SiN}_{1.39}$ -based DBR compared to its $\text{SiN}_{1.39}$ -based counterpart, this advantage does not outweigh the adverse effect of loss in the layers in the respective FPI realizations.

The spectral responses shown in Figures 8 and 9 refer to an FPI operated at $m = 15$ with a physical resonator thickness of 1320 nm. The transmission curves for the three operating modes considered here are shown in Figure 10.




Figure 10. Calculated spectral transmittance for the 19-layer FPI with $\text{SiN}_{1.49}$ used for n_H : (a) Full near-UV spectral range and (b) zoom in around the design wavelength.

The magnitude of the peak transmittance varies with the reflectance of the DBR. The transmittance in the 330 nm band ranges from $T(326.8) = 0.600$ and $T(328.8) = 0.623$ to $T(330.6) = 0.639$,

with $\text{FWHM}(326.8) = 1.6$ nm, $\text{FWHM}(328.8) = 1.4$ nm and $\text{FWHM}(330.6) = 1.3$ nm. The improved resolution of the FPI with a thicker resonator is consistent with operation at a higher mode number. This conclusion is also confirmed by the differences in spectral spacing between the transmittance peaks (their respective free-spectral ranges), for instance, from 18.8 nm between the 330 nm band and the 309 nm band for a 1440 nm resonator, to 20.8 nm for a 1200 nm resonator. Equation (3) can be applied to confirm that the differences are due to the different modes of operation of these resonators in the various bands, leading to the gradual encroachment of the transmittance curves in the 350 nm band and ultimately in the reversal of the relative spectral positions in the 375 nm band.

These simulations all target a design with a resonator thickness $t_{\text{res}} = 1320$ nm and $m = 15$. For validation purposes, designs with $t_{\text{res}} = 1200$ nm and $t_{\text{res}} = 1440$ nm were considered as limiting cases; only these two designs, as specified in Table 1, were actually fabricated and subjected to tests.

2.3. Fabrication and Measurement Setup

Plasma-enhanced chemical vapor deposition (PECVD), with silane and ammonia as the precursor gases, was used for fabrication. The deposition tool used was the GSI ULTRADEP 2000, which was operated at 350 °C and was configured as a single chamber with a load lock [34]. The ammonia gas flow was set to 550 sccm and three different recipes were used for setting the silane flow to the appropriate values to result in the different SiNx compositions. The silane flow was set to 84 sccm for Si₃N₄, 70 sccm for SiN_{1.39} and 45 sccm for SiN_{1.49}. It should be noted that the total gas flow was not kept constant between the different recipes. The resulting materials were optically characterized using an ellipsometer setup, as already described and with results shown in Figure 3. The recipes for deposition were fully characterized [36]. The spectral transmittance and reflectance of the different fabricated versions of the FPI were measured.

In the setup for transmission measurement, shown in Figure 11a, a fiber-based probe was used for illuminating the sample with light from a wideband light source (Newport Corporation) and for directing the transmitted light to a spectrometer (Flame, Ocean Optics). Tilt and rotation stages were used for selecting a suitable position on the wafer and for adjusting the angle of incidence for normal incidence. The lamp spectral radiation was measured separately before and after a separate spectral transmittance measurement for reducing the effect of any non-reproducibility due to the lamp, using normalization in software. Although sequential measurements do introduce uncertainty compared to direct measurement using a beam splitter, this approach is preferred for practical reasons and the uncertainty is mitigated by systematically checking the consistency of subsequent lamp spectral radiation measurements.

The transmittance through a sample was measured, which included the exitance of the sapphire–air interface at the backside of the sapphire wafer. However, the transmittance of the simulations presented refer to the radiance entering the sapphire substrate. The difference is mainly because no detector was yet integrated into the substrate. This effect was accounted for by a calibration measurement of the transmittance through a sapphire prime wafer (which basically served as the reference element). The transmittance through such a single sapphire wafer (lossless and without roughness on frontside and backside) surrounded by air is described by $T_{\text{air,Al}_2\text{O}_3,\text{air}} = (1 - \text{reflectance at the air-sapphire incidence}) \times (1 - \text{exitance at the sapphire–air interface})$. This results in a transmittance equal to $(1 - R_{\text{air,Al}_2\text{O}_3}) \times (1 - R_{\text{Al}_2\text{O}_3,\text{air}}) = 0.841$ for $n_{\text{Al}_2\text{O}_3} = 1.81$ and $k_{\text{Al}_2\text{O}_3} = 0$ (approximation based on [39]). As frontside reflectance and backside exitance can be assumed to be equal, the square root of the measured spectral transmittance through this prime sapphire prime wafer, $(T_{\text{air,Al}_2\text{O}_3,\text{air}})^{1/2}$, can be used as a normalization factor and can be applied to the results on FPI samples.




Figure 11. Setup used for FPI optical characterization: (a) Measurement of transmittance: Tilt and rotation stages were used for selecting a suitable position on the wafer and for adjusting the angle of incidence to normal incidence; (b) Reflectance measurement setup using a reflection probe with the reflected light guided in the inner fiber and the illuminating light in the surrounding fibers. The tilt and rotation stages were used for selecting a suitable position on the wafer and for setting the angle of incidence.

With minor modifications the measurement setup was also used for FPI spectral reflectance measurement, as shown in Figure 11b. The most significant difference was the use of the reflection probe (Thorlabs) with a special multi-fiber probe for illuminating the sample and for transferring the reflected light. A translation stage was used for selecting a suitable location on the wafer for measurement, while a rotation stage was used to ensure normal incidence. A 20D10AL.2 UV/visible reference reflector was used for calibration (Newport Corporation). The transmittance and reflectance measurements were taken sequentially, which does in principle introduce uncertainty in the exact testing location on the wafer to be illuminated and deviations in the angle of incidence. However, this limitation had no apparent effect on our results. Therefore, these are not addressed here in more detail, but are avoidable in a more advanced setup.

3. Results

The measured spectral reflectance and transmittance of nitride rich $\text{SiN}_{1.49}$ with $t_{\text{res}} = 1440$ nm are shown in Figure 12 in comparison with simulation results.

The absorbance was not measured, but is derived from the measured transmittance and reflectance by implication using $A_{\text{impl}} = 1 - T_{\text{meas}} - R_{\text{meas}}$. The spectral measurements are in reasonable agreement with simulations. The in-band peak transmission in the primary design band $\lambda_0 = 320\text{--}330$ nm is $T(330.8 \text{ nm}) = 63.1\%$, which is adequate for practical use. The spectral resolution $\text{FWHM}(331 \text{ nm}) = 1.9 \text{ nm}$ is slightly inferior to the theoretical prediction of $\text{FWHM} = 1.4 \text{ nm}$. The comparison of theory and results suggest a high accuracy in the settings of the deposition parameters, as the actual resonator thickness was very close to the nominal value.

However, the results on the same nitride-rich $\text{SiN}_{1.49}$ with resonator thickness at nominal value $t_{\text{res}} = 1200$ nm, as shown in Figure 13a, give reason for a more cautious conclusion. These measurements are also presented in Figure 13b in comparison to simulations with the resonator thickness adjusted for best fit. The results suggest an actual resonator thickness $t_{\text{res}} = 1191$ nm. The deviation of 9 nm ($<1\%$) due to tolerances in the equipment remains fully acceptable. The in-band peak transmission of the FPI with thickness $t_{\text{res}} = 1191$ nm is $T(324.9 \text{ nm}) = 64.1\%$. The $\text{FWHM}(324.9 \text{ nm}) = 2.2 \text{ nm}$, which is slightly inferior to the predicted simulation value of 1.5 nm. The reduced spectral resolution

(higher value of the *FWHM*) is consistent with the lower resonance mode *m* in an FPI with shorter resonator thickness.




Figure 12. Measured spectral reflectance and transmittance with implied absorbance in comparison with simulated responses for 19-layer FPI with $\text{SiN}_{1.49}$ used for n_H and a nominal resonator width $t_{\text{res}} = 1440$ nm in the range (a) 250–500 nm, (b) 280–360 nm.




Figure 13. Measured spectral reflectance and transmittance with implied absorbance in the range 280–360 nm, in comparison with simulated responses, for 19-layer FPI with $\text{SiN}_{1.49}$ used for n_H for: (a) the nominal resonator width $t_{\text{res}} = 1200$ nm and (b) the adjusted resonator width $t_{\text{res}} = 1191$ nm for best fit between measurement and simulation.

Figure 13a reveals flattening of the peak as a source of uncertainty in the measured magnitude of the peak transmission at a resonance wavelength (for instance at $\lambda = 304.2$ nm and $\lambda = 348.7$ nm). This is the result of the step size in the spectrometer used, which basically results in an occasional pass over of the precise value of the peak wavelength. The effect is considered acceptable within the framework of this study and can be reduced in an improved measurement setup.

The measured spectral reflectance and transmittance of SiN_x with a medium nitride composition ($\text{SiN}_{1.39}$) is shown for nominal resonator thickness $t_{\text{res}} = 1200$ nm and $t_{\text{res}} = 1440$ nm in Figure 14a and 14b, respectively. The results within the spectral range up to 340 nm show peak transmittance in the range 0.13–0.16, while the peak transmittance at 348 nm is about 0.38. This is a rather marginal optical performance for practical application.




Figure 14. Measured spectral reflectance and transmittance with implied absorbance in the range 280–360 nm, in comparison with the simulated responses for 19-layer FPI with $\text{SiN}_{1.39}$ used for n_H for (a) $t_{\text{res}} = 1185$ nm and (b) $t_{\text{res}} = 1425$ nm.

Finally, the measured spectral reflectance and transmittance of stoichiometric silicon nitride (Si_3N_4) is shown for nominal resonator thickness $t_{\text{res}} = 1200$ nm and $t_{\text{res}} = 1440$ nm in Figure 15a and 15b, respectively. As expected, the low transmittance (<5%) and high in-band absorbance (up to 50%) of the FPIs based on Si_3N_4 makes these unsuitable for a design operating at a design wavelength lower than 400 nm. The results also confirm the reduced out-of-band reflectance due to layer absorption.




Figure 15. Measured spectral reflectance and transmittance with implied absorbance in the range 280–360 nm, in comparison with simulated responses, for the 19-layer FPI with Si_3N_4 used for n_H for (a) $t_{\text{res}} = 1179$ nm and (b) $t_{\text{res}} = 1418$ nm.

4. Discussion

The results clearly confirm the superior performance of an FPI operating in near-UV with nitride-rich SiN_x used for higher-index layers in the DBRs, in comparison to Si₃N₄. The in-band peak transmission for $\lambda_0 = 320\text{--}340\text{ nm}$ improves from $T < 5\%$ in Si₃N₄ to $T > 60\%$ for SiN_{1.49}, while the out-of-band peak reflectance increases from $R < 70\%$ in Si₃N₄ to $R > 85\%$ for SiN_{1.49}. The spectral characteristics within the DBR reflectance band of the FPI designs fabricated and tested in this work are summarized in Table 2.

Table 2. Characteristics of the two SiN_{1.49}-based designs (also shown in Figures 12b and 13b).

Design	Measured			Simulated			Mode	
	λ_{peak} [nm]	T_{peak}	λ_{FWHM} [nm]	λ_{peak} [nm]	T_{peak}	λ_{FWHM} [nm]	FSR_m [nm]	$m_{\text{der.}}^1$
$t_{\text{res}} = 1192\text{ nm}$, 300–320 nm band	304.1	0.595	2.6	304.3	0.507	2.2		
320–340 nm band	324.9	0.641	2.2	324.7	0.593	1.5	20.8	14.62
340–360 nm band	348.7	0.779	3.5	348.9	0.843	2.4	23.8	13.65
$t_{\text{res}} = 1440\text{ nm}$, 300–320 nm band	312.2	0.565	2.0	312.1	0.565	1.4		
320–340 nm band	330.8	0.631	1.9	330.6	0.639	1.4	18.6	16.77
340–360 nm band	351.8	0.772	3.1	351.8	0.862	2.1	21.0	15.75

¹ Calculation of m_{der} is based on Equation (4): $m_{\text{der}} = (\lambda_{\text{peak},m} - \lambda_{\text{peak},m+1}) / FSR_m$.

The measured spectral positions of the peak in-band transmission are in good agreement with simulations. It should be noted, of course, that this does not come as a surprise, as the estimated thickness of the resonator layer is adapted for best fit. From comparison between measurement and simulation, the actual thickness of the thick resonator is considered equal to the nominal value, $t_{\text{res}} = 1440\text{ nm}$ (see also Figure 12), while the estimation of the thin resonator is $t_{\text{res}} = 1191\text{ nm}$ (see also Figure 13). The table confirms a remaining uncertainty $\varepsilon < 0.7\%$. Note the increased minimum transmission in between resonance peaks. This baseline increases in the $t_{\text{res}} = 1192\text{ nm}$ design from the simulated $T = 0.009$ to $T = 0.020$ in the measurements and is due to parasitic transmission paths.

The measured spectral resolution is systematically smaller than the simulation results ($FWHM_m(\text{meas}) > FWHM_m(\text{sim})$), which is due to limiting aspects of the device and the measurement setup. The theory of the FPI is based on two opposing mirrors that are positioned perfectly parallel and have no surface roughness. Practical device limitations have an adverse effect on Finesse [43,44]. The significance of these imperfections is related to wavelength and thus increases with a smaller design wavelength. As a consequence, this effect is more significant in near-UV compared to microfabricated devices reported in the literature, which are typically designed for application in visible or near-IR spectra. The alternative reason for the reduced spectral resolution in measurements is the use of a spectrometer in the setup. The spectrometer is used with a slit of $5\text{ }\mu\text{m}$ width, which is the minimum value available and results in a measurement resolution of 0.95 nm (grating range 650 nm , detector array with 2048 pixels and a pixel resolution of 3 pixels [45], p. 38). The FPI presented in this work is based on an all solid-state design, rather than an airgap for use as the resonator, and we do not expect mirror parallelism or surface roughness to be the most significant limitation. The reduced spectral resolution observed is mainly due to the measurement setup and better matching with the simulations should be possible in an improved setup. Although improved consistency between simulation and experiment would of course be useful for device characterization, we would like to emphasize that the FPI is intended for use in an optical system with similar specifications as those of this measurement setup. Therefore, we tend to conclude that an FWHM of about 2 nm would be the ultimate final performance of this FPI design, which is sufficient for the intended application.

In the absence of rounding, the derived resonance mode, m_{der} , and FSR can be calculated from the data in Table 2. The FSR is defined in Equation (4) as a function of the resonance wavelength (and thus of the optical width of the resonator), but also as the

spectral difference between two subsequent resonant peaks. The actual values listed in Table 2 provide the information needed to verify the validity of the assumed position of the equivalent mirror within the DBR stack, which accounts for the penetration depth, by validation of resonator mode m . Of course, the actual value of m is an integer number. The spectral separation of the resonance peaks is in good agreement with theory, which confirms the correct operating order, but the derived order m_{der} is systematically larger than the target value. This implies that the resonance wavelength is slightly shifted to longer wavelengths, which suggests that the assumption of a mirror at $3 \times t_{\text{QWOT}} = 0.75 \times \lambda_0$ is a slight overestimation and a position at about $2.6 \times t_{\text{QWOT}} = 0.65 \times \lambda_0$ would be more appropriate. It should be noted that the actual operating mode at a given design wavelength results from device design and is not due to the characteristics of the light source used for exciting resonance. The higher-than-expected resonance mode often goes unnoticed and the discrepancy between theoretical and experimental values of the FSR is often attributed to loss mechanisms that were not taken into account in the design phase, rather than to disregarding the phase penetration depth. The results presented do support the conclusion that the effect of phase penetration at the DBRs needs to be included in an accurate FPI design.

The detrimental effects discussed can be attributed to the loss in the SiN_x layers. This conclusion triggers the question whether a further improvement would be possible by a further reduction of the nitride composition in SiN_x . In principle, reduced optical loss in near-UV with a larger nitride composition should be feasible; however, there are two practical constraints to consider. The first is the deposition uniformity. An increase in nitride content beyond $x \sim 1.5$ would, in principle, enable a push of the lower wavelength limit of the design window deeper into the UV. However, this ambition would be ultimately constrained by the manufacturing repeatability of the deposition rate and the resulting uncertainties in the composition of the deposited material. This limitation depends on the specifics of the equipment used. In our setup the silane/ammonia flow ratio that resulted in $x = 1.49$ was set to 45 sccm/550 sccm and a further reduction of silane flow resulted in unacceptable run-to-run non-repeatability. This is a practical limitation and equipment may be feasible for depositing stable materials at a very small ammonia/silane ratio.

The second constraint is more fundamental and concerns the diminishing potential for additional gains at $x > 1.49$. The increase in the optical bandgap of SiN_x with x saturates at about $E_g \sim 5.5$ eV, which would imply a spectral position of the onset of the associated spectral shift of the slope of exponentially increasing k in the range 260–280 nm. This limitation would make applications for the detection of, for instance, BTEX gases with gas-specific absorption spectra in the 240–280 nm band unlikely. Moreover, as shown in Figure 3, any shift in application window towards the shorter-wavelength UV enabled by a reduced k should be assessed relative to the associated reduction in index n , and thus reduced refraction index contrast between n_H and n_L . Consequently, increasing the nitride composition beyond $x \sim 1.5$ is unlikely to bring significant benefits in DBR design beyond those presented here.

The main achievements of the work presented are the validation of the suitability of nitride-rich SiN_x as an optical material with a relatively high index of refraction and low optical loss in near-UV, the establishment of an accurate optical database for SiN_x , and an accurate design procedure for a $\text{SiN}_x/\text{SiO}_2$ -based FPI with favorable optical properties in near-UV. The performance of the FPI with $m = 15$ and $\lambda_0 = 330$ nm can be directly extracted from Table 2 and result for a $\text{SiN}_{1.49}$ -based design in a peak transmission of 64%, with $\text{FSR}_{15} = 20$ nm and $\text{FWHM}_{15} = 2$ nm. Future research includes the use of this material in practical applications.

Author Contributions: Conceptualization, R.W., D.W. and Y.G.; software, R.W. and D.B.; validation, D.W. and D.B.; formal analysis, R.W.; investigation, R.W., D.W., D.B., J.V., Y.Q. and Y.G.; resources, J.V. and Y.G.; data curation, D.B.; writing—original draft preparation, R.W.; writing—review and editing, R.W., D.W., D.B., J.V., Y.Q. and Y.G. All authors have read and agreed to the published version of the manuscript.

Funding: Financial support for this project was provided in part by a Ford university research project grant (URP), project number 1661.

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: Data can be made available by contacting the corresponding author.

Acknowledgments: Fabrication was carried out at the Lurie Nanofabrication Facility of the University of Michigan and optical characterization at the Ford Center for Research and Advanced Engineering.

Conflicts of Interest: Dr. David Bilby and Dr. Jacobus H Visser are employed in Ford Motor Company. The other authors declare no conflicts of interest.

References

- Kim, W.J.; Terada, N.; Nomura, T.; Takahashi, R.; Lee, S.D.; Park, J.H.; Konno, A. Effect on formaldehyde on the expression of adhesion molecule in nasal microvascular endothelial cells: The role of formaldehyde in the pathogenesis of sick building syndrome. *Clin. Exp. Allergy* **2002**, *32*, 287–295. [CrossRef] [PubMed]
- Kawamura, K.; Kerman, K.; Fujihara, M.; Nagatani, N.; Hashiba, T.; Tamiya, E. Development of a novel hand-held formaldehyde gas sensor for the rapid detection of sick building syndrome. *Sens. Actuators B Chem.* **2005**, *105*, 495–501. [CrossRef]
- Persoz, C.; Achard, S.; Leleu, C.; Momas, I.; Seta, N. An in vitro model to evaluate the inflammatory response after gaseous formaldehyde exposure of lung epithelial cells. *Toxicol. Lett.* **2010**, *195*, 99–105. [CrossRef] [PubMed]
- WHO. *Air Quality Guidelines*, 2nd ed.; WHO Regional Office for Europe: Copenhagen, Denmark, 2001.
- Occupational Safety and Health Guideline for Formaldehyde Potential Human Carcinogen*; U.S. Department of Health and Human Services: Washington, DC, USA, 1988.
- Kim, S. Control of formaldehyde and TVOC emission from wood-based flooring composites at various manufacturing processes by surface finishing. *J. Hazard. Mater.* **2010**, *176*, 14–19. [CrossRef] [PubMed]
- Nielsen, G.D.; Wolkoff, P. Cancer effects of formaldehyde: A proposal for an indoor air guideline value. *Arch. Toxicol.* **2010**, *84*, 423–446. [CrossRef] [PubMed]
- Salem, M.Z.M.; Böhm, M. Understanding of formaldehyde emissions from solid wood: An overview. *BioResources* **2013**, *8*, 4775–4790. [CrossRef]
- Salthammer, T.; Mentese, S.; Marutzky, R. Formaldehyde in the indoor environment. *Chem. Rev.* **2010**, *110*, 2536–2572. [CrossRef] [PubMed]
- SHG-Health-02.00, FSIS Environmental, Safety and Health Group. Available online: <https://www.dhs.wisconsin.gov/chemical/carbondioxide.htm> (accessed on 25 January 2024).
- Fan, X.; Sakamoto, M.; Shao, H.; Kuga, K.; Ito, K.; Lan, L.; Wargock, P. Emission rate of carbon dioxide while sleeping. *Build. Environ.* **2023**, *236*, 110299. [CrossRef] [PubMed]
- Winer, A.M. Long pathlength differential optical absorption spectroscopy (DOAS) measurements of gaseous HONO, NO₂ and HCHO in the California South coast air basin. *Res. Chem. Intermed.* **1994**, *20*, 423–445. [CrossRef]
- Wysocki, G.; Bakhirkin, Y.; So, S.; Tittel, F.K.; Hill, C.J.; Yang, R.Q.; Fraser, M.P. Dual interband cascade laser-based trace-gas sensor for environmental monitoring. *Appl. Opt.* **2007**, *46*, 8202–8210. [CrossRef]
- Mohimann, G.R. Formaldehyde detection in air by laser induced fluorescence. *Appl. Spectrosc.* **1985**, *39*, 98–101. [CrossRef]
- Liao, W.; Winship, D.; Lara-Ibeas, I.; Zhao, X.; Xu, Q.; Lu, H.-T.; Qian, T.; Gordenker, R.; Qin, Y.; Gianchandani, Y.B. Highly integrated μ GC based on a multisensing progressive cellular architecture with a valveless sample inlet. *Anal. Chem.* **2023**, *95*, 2157–2167. [CrossRef]
- Tanaka, K.; Miyamura, K.; Akishima, K.; Tonokura, K.; Konno, M. Sensitive measurements of trace gas of formaldehyde using a mid-infrared laser spectrometer with a compact multi-pass cell. *Infrared Phys. Technol.* **2016**, *79*, 1–5. [CrossRef]
- Flueckiger, J.; Ko, F.K.; Cheung, K.C. Microfabricated formaldehyde gas sensors. *Sensors* **2009**, *9*, 9196–9215. [CrossRef]
- Hodgkinson, J.; Tatam, R.P. Optical gas sensing: A review. *Meas. Sci. Technol.* **2013**, *24*, 012004. [CrossRef]
- Chung, P.R.; Tzeng, C.T.; Ke, M.T.; Lee, C.Y. Formaldehyde Gas Sensors: A Review. *Sensors* **2013**, *13*, 4468–4484. [CrossRef]
- Davenport, J.J.; Hodgkinson, J.; Saffell, J.R.; Tatam, R.P. A measurement strategy for non-dispersive ultra-violet detection of formaldehyde in indoor air: Spectral analysis and interferent gases. *Meas. Sci. Technol.* **2016**, *27*, 015802. [CrossRef]
- Nyangaresi, P.O.; Qin, Y.; Chen, G.; Zhang, B.; Lu, Y.; Shen, L. Effects of single and combined UV-LEDs on inactivation and subsequent reactivation of E. coli in water disinfection. *Water Res.* **2018**, *147*, 331–341. [CrossRef]
- Gordon, I.E.; Rothman, L.S.; Hill, S.; Kochanov, R.V.; Tan, Y.; Bernath, P.F.; Birk, M.; Boudon, V.; Campargue, A.; Chance, K.V.; et al. The HITRAN2016 Molecular Spectroscopic Database. *J. Quant. Spectrosc. Radiat. Transf.* **2017**, *203*, 3–69. Available online: <https://hitran.org/> (accessed on 15 June 2021). [CrossRef]
- Keller-Rudek, H.; Moortgat, G.K.; Sander, R.; Sörensen, R. The MPI-Mainz UV/VIS spectral atlas of gaseous molecules of atmospheric interest. *Earth Syst. Sci. Data* **2013**, *5*, 365–373. Available online: www.uv-vis-spectral-atlas-mainz.org (accessed on 18 June 2021). [CrossRef]

24. Seinfeld, J.H.; Pandis, S.N. Atmospheric composition, global cycles, and lifetimes. In *Atmospheric Chemistry and Physics: From Air Pollution to Climate Change*; John Wiley and Sons: Hoboken, NJ, USA, 1998; pp. 49–124.
25. Available online: https://www.euro.who.int/__data/assets/pdf_file/0017/123083/AQG2ndEd_7_1nitrogendioxide.pdf (accessed on 9 June 2021).
26. Emadi, A.; Wu, H.; de Graaf, G.; Wolffenbuttel, R.F. Design and implementation of a sub-nm resolution microspectrometer based on a Linear-Variable Optical Filter. *Opt. Express* **2012**, *20*, 489–507. [[CrossRef](#)]
27. Martínez, F.L.; Toledano-Luque, M.; Gandía, J.J.; Cárabe, J.; Bohne, W.; Röhrich, J.; Strub, E.; Mártel, I. Optical properties and structure of HfO₂ thin films grown by high pressure reactive sputtering. *J. Phys. D Appl. Phys.* **2007**, *40*, 5256–5265. [[CrossRef](#)]
28. Pellicori, S.F.; Martinez, C.L. UV optical properties of thin-film oxide layers deposited by different processes. *Appl. Optics* **2011**, *50*, 5559–5566. [[CrossRef](#)] [[PubMed](#)]
29. Thielsch, R.; Gatto, A.; Heber, J.; Kaiser, N. A comparative study of the UV optical and structural properties of SiO₂, Al₂O₃, and HfO₂ single layers deposited by reactive evaporation, ion-assisted deposition and plasma ion-assisted deposition. *Thin Solid Film.* **2002**, *410*, 86–93. [[CrossRef](#)]
30. Emadi, A.; Wu, H.; de Graaf, G.; Enoksson, P.; Correia, J.H.; Wolffenbuttel, R.F. Linear variable optical filter-based ultraviolet microspectrometer. *Appl. Opt.* **2012**, *51*, 4308–4315. [[CrossRef](#)]
31. Gao, L.; Lemarchand, F.; Lequime, M. Exploitation of multiple incidences spectrometric measurements for thin film reverse engineering. *Opt. Express* **2012**, *20*, 15734–15751. [[CrossRef](#)]
32. Bridou, F.; Cuniot-Ponsard, M.; Desvignes, J.M.; Richter, M.; Kroth, U.; Gottwald, A. Experimental determination of optical constants of MgF₂ and AlF₃ thin films in the vacuum ultra-violet wavelength region (60–124 nm) and its application to optical designs. *Opt. Commun.* **2010**, *283*, 1351–1358. [[CrossRef](#)]
33. Iwahori, K.; Furuta, M.; Taki, Y.; Yamamura, T.; Tanaka, A. Optical properties of fluoride thin films deposited by RF magnetron sputtering. *Appl. Opt.* **2006**, *45*, 4598–4602. [[CrossRef](#)]
34. Bischoff, M.; Gäbler, D.; Kaiser, N.; Chuvilin, A.; Kaiser, U.; Tünnermann, A. Optical and structural properties of LaF₃ thin films. *Appl. Opt.* **2008**, *47*, 157–161.
35. Wright, D.N.; Marstein, E.S.; Rognmo, A.; Holt, A. Plasma-enhanced chemical vapour-deposited silicon nitride films; The effect of annealing on optical properties and etch rates. *Sol. Energy Mater. Sol. Cells* **2008**, *92*, 1091–1098. [[CrossRef](#)]
36. Winship, D. Arrayed Integrated Photoionization Detectors for Highly Integrated Microscale Gas Chromatography Systems. Ph.D. Dissertation, University of Michigan, Ann Arbor, MI, USA, January 2024; pp. 99–122.
37. Xiang, C.; Jin, W.; Bowers, J.E. Silicon nitride passive and active photonic integrated circuits: Trends and prospects. *Photonics Res.* **2022**, *10*, A82–A96. [[CrossRef](#)]
38. Macleod, H.A. *Thin-Film Optical Filters*, 3rd ed.; Institute of Physics Publishing: Bristol, UK, 2001.
39. Malitson, I.H.; Dodge, M.J. Refractive index and birefringence of synthetic sapphire. *J. Opt. Soc. Am.* **1972**, *62*, 1405. Available online: <https://refractiveindex.info/tmp/data/main/Al2O3/Malitson-o.txt> (accessed on 8 June 2021).
40. Koks, C.; van Exter, M.P. Microcavity resonance condition, quality factor, and mode volume are determined by different penetration depths. *Opt. Express* **2021**, *29*, 6879–6889. [[CrossRef](#)]
41. Babic, D.I.; Corzine, S.W. Analytic expressions for the reflection delay, penetration depth, and absorptance of quarter-wave dielectric mirrors. *IEEE J. Quantum Electron.* **1992**, *28*, 514–524. [[CrossRef](#)]
42. Garmire, E. Theory of quarter-wave-stack dielectric mirrors used in a thin Fabry–Perot filter. *Appl. Opt.* **2003**, *42*, 5442–5449. [[CrossRef](#)]
43. Palik, E.D.; Boukari, H.; Gammon, R.W. Experimental study on the effect of surface defects on the finesse and contrast of a Fabry–Perot interferometer. *Appl. Opt.* **1995**, *35*, 38–50. [[CrossRef](#)]
44. Neumann, N.; Ebermann, M.; Hiller, K.; Kurth, S. Tunable infrared detector with integrated micromachined Fabry–Perot filter. In *MOEMS and Miniaturized Systems VI*; SPIE: Cergy-Pontoise, France, 2007; Volume 6466.
45. Available online: <https://www.oceaninsight.com/globalassets/catalog-blocks-and-images/manuals--instruction-ocean-optics/spectrometer/flameio.pdf> (accessed on 8 June 2021).

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.