

Appendices

Table of Contents

Number	Title	Page
1	Ammonia Mass in Ammonia Heat Pump	1
2	Preliminary Estimation for Ammonia Cycle	10
3	Economic Evaluation of Ammonia Heat Pump	14
4	Basis for The Compressors Simulation	33
5	Compressor Scheme	34
6	Piping Calculations	35
7	Estimation of The Enthalpy and Entropy of The Hot Tap Water at 137 °C and 13 bar	39
8	Tera Joules Calculation	43
9	Overall Heat Transfer Coefficient	50
10	Estimation of The Natural Gas and Air Consumption in The Fired Heater	51
11	Process Flow Scheme	54
12	Process Streams Summary	55
13	Equipment Summary and Specification Sheet	59
14	Demand Fluctuation	78
15	Streams to The District	84
16	District Piping System Block Scheme	87
17	Hazard and Operability Study	88
18	Fire and Explosion Index Calculation	101
19	Heat Losses Calculation (Way In and Return)	103
20	Exergy Analysis of The Process	116
21	Exergy Losses Calculation	120
22	COP Calculation	128
23	Ammonia Heat Pump Aspen Flowsheet	130
24	District Pipeline Aspen Flowsheet	131
25	Total Investment of Ammonia Heat Pump	132
26	Production Cost of Ammonia Heat Pump	134
27	Production Cost of Furnace	135
28	Total Product Cost	136
29	Revenues	137
30	Chemical Heat Pump Simulation	138
31	Economic Evaluation of Chemical Heat Pump	142
32	Total Investment of Chemical Heat Pump	160
33	Production Cost of Chemical Heat Pump	162
34	T-xy Diagram for Acetone-Isopropanol	163
35	Utility Cost	164
36	Team Photograph	165

Appendix 1 Ammonia Mass in Ammonia Heat Pump

An estimative value for the inventory of ammonia in the cycle (equipment + pipes) is calculated here. The exact ammonia inventory should be provided in the detailed design.

Evaporator

Area of the evaporator:

$$AEVP := 7.927 \times 10^3 \text{ ft}^2$$

The cost of this piece of equipment was calculated based on 3/4-in. or 1-in. O.D. 12ft long tubes on square or triangular pitch, thus:

$$D_{\text{tube}} := 1 \text{ in}$$

$$L_{\text{tube}} := 12 \text{ ft}$$

$$A_{\text{outtube}} := \pi \cdot D_{\text{tube}} \cdot L_{\text{tube}} \cdot 0.083$$

Heat transfer area for one tube is:

$$A_{\text{outtube}} = 3.129 \text{ ft}^2$$

The number of tubes is:

$$N_{\text{tube}} := \frac{AEVP}{A_{\text{outtube}}}$$

$$N_{\text{tube}} = 2.533 \times 10^3$$

According to Table 13.6 of "Product and Process Design Principles" [1], the shell inner diameter is:

$$D_{\text{shell}} := 58 \text{ in}$$

$$L_{\text{shell}} := 12 \text{ ft}$$

In order to find the amount of ammonia in shell side:

$$V_{\text{tube}} := N_{\text{tube}} \cdot \frac{\pi \cdot D_{\text{tube}}^2 \cdot L_{\text{tube}} \cdot 0.083^2}{4}$$

$$V_{\text{shell}} := \frac{\pi \cdot D_{\text{shell}}^2 \cdot L_{\text{shell}} \cdot 0.083^2}{4}$$

$$V_{\text{shell}} = 218.415 \text{ ft}^3$$

$$V_{\text{tube}} = 164.485 \text{ ft}^3$$

$$V_{\text{ammoniaEVP}} := V_{\text{shell}} - V_{\text{tube}}$$

$$V_{\text{ammoniaEVP}} = 53.93 \text{ ft}^3$$

$$\text{densityEVP} := 0.062 \cdot 18.0 \frac{\text{lb}}{\text{ft}^3}$$

$$\text{MammoniaEVP} := \text{VammoniaEVP} \cdot \text{densityEVP}$$

$$\text{MammoniaEVP} = 60.286 \text{ lb}$$

It is assumed that the volume of the vapor part in the kettle type evaporator is equivalent to the 1/2 of total shell volume in the evaporator, thus:

$$\text{VvaporammoniaEVP} := 0.5 \cdot \text{Vshell}$$

$$\text{VvaporammoniaEVP} = 109.208 \text{ ft}^3$$

$$\text{densityEVP} := 0.062 \cdot (4.989) \frac{\text{lb}}{\text{ft}^3}$$

$$\text{MvaporammoniaEVP} := \text{VvaporammoniaEVP} \cdot \text{densityEVP}$$

$$\text{MvaporammoniaEVP} = 33.78 \text{ lb}$$

Condenser

Area of the condenser:

$$\text{ACOND} := 2.496 \times 10^3 \text{ ft}^2$$

The cost of this piece of equipment was calculated based on 3/4-in. or 1-in. O.D. 12ft long tubes on square or triangular pitch, thus:

$$\text{Dtube} := 1 \text{ in}$$

$$\text{Ltube} := 12 \text{ ft}$$

$$\text{Aouttube} := \pi \cdot \text{Dtube} \cdot \text{Ltube} \cdot 0.08$$

Heat transfer area for one tube is:

$$\text{Aouttube} = 3.129 \text{ ft}^2$$

The number of tubes is:

$$\text{Ntube} := \frac{\text{ACOND}}{\text{Aouttube}}$$

$$\text{Ntube} = 797.692$$

According to Table 13.6 of "Product and Process Design Principles" [1], the shell inner diameter is:

$$\text{Dshell} := 37 \text{ in}$$

$$\text{Lshell} := 12 \text{ ft}$$

In order to find the amount of ammonia in shell side:

$$V_{\text{tube}} := N_{\text{tube}} \cdot \frac{\pi \cdot D_{\text{tube}}^2 \cdot L_{\text{tube}} \cdot 0.083^2}{4}$$

$$V_{\text{shell}} := \frac{\pi \cdot D_{\text{shell}}^2 \cdot L_{\text{shell}} \cdot 0.083^2}{4}$$

$$V_{\text{ammoniaCOND}} := V_{\text{shell}} - V_{\text{tube}}$$

$$V_{\text{ammoniaCOND}} = 37.093 \quad \text{ft}^3$$

$$\text{densityCOND} := 0.06251339 \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaCOND}} := V_{\text{ammoniaCOND}} \cdot \text{densityCOND}$$

$$M_{\text{ammoniaCOND}} = 1.181 \times 10^3 \quad \text{lb}$$

It is assumed that the volume of the vapor part of the kettle type condenser is equivalent to the 1/2 of total shell volume in the condenser, thus:

$$V_{\text{vaporammoniaCOND}} = 0.5 \cdot V_{\text{shell}}$$

$$V_{\text{vaporammoniaCOND}} = 44.443 \quad \text{ft}^3$$

$$\text{densityCOND} := 0.062(18.95) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{vaporammoniaCOND}} = V_{\text{vaporammoniaCOND}} \cdot \text{densityCOND}$$

$$M_{\text{vaporammoniaCOND}} = 52.23 \quad \text{lb}$$

Intercooler

Area of the intercooler:

$$A_{\text{HEX}} := 2.828 \times 10^3 \quad \text{ft}^2$$

The cost of this piece of equipment was calculated based on 3/4-in. or 1-in. O.D. 12ft long tubes on square or triangular pitch, thus:

$$D_{\text{tube}} := 1 \quad \text{in}$$

$$L_{\text{tube}} := 12 \quad \text{ft}$$

$$A_{\text{outtube}} := \pi \cdot D_{\text{tube}} \cdot L_{\text{tube}} \cdot 0.083$$

Heat transfer area for one tube is:

$$A_{\text{outtube}} = 3.129 \text{ ft}^2$$

The number of tubes is:

$$N_{\text{tube}} := \frac{A_{\text{HEX}}}{A_{\text{outtube}}}$$

$$N_{\text{tube}} = 903.796$$

According to Table 13.6 of "Product and Process Design Principles" [1], the shell inner diameter is:

$$D_{\text{shell}} := 37 \text{ in}$$

$$L_{\text{shell}} := 12 \text{ ft}$$

In order to find the amount of ammonia in shell side:

$$V_{\text{tube}} := N_{\text{tube}} \cdot \frac{\pi \cdot D_{\text{tube}}^2 \cdot L_{\text{tube}} \cdot 0.083^2}{4}$$

$$V_{\text{shell}} := \frac{\pi \cdot D_{\text{shell}}^2 \cdot L_{\text{shell}} \cdot 0.083^2}{4}$$

$$V_{\text{ammoniaHEX}} := V_{\text{shell}} - V_{\text{tube}}$$

$$V_{\text{ammoniaHEX}} = 30.204 \text{ ft}^3$$

$$\text{densityHEX} := 0.062 (9.432) \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaHEX}} := V_{\text{ammoniaHEX}} \cdot \text{densityHEX}$$

$$M_{\text{ammoniaHEX}} = 17.663 \text{ lb}$$

Low Pressure Compressor

The net volume for ammonia vapor in the compressor is assumed to be 0.7*2.0 m³:

$$V_{\text{compressor1}} := 0.7 \cdot 2.0 \cdot 3.28^3$$

$$V_{\text{compressor1}} = 49.403 \text{ ft}^3$$

$$\text{densityCOMP1} := 0.062 (9.034) \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaCOMP1}} := V_{\text{compressor1}} \cdot \text{densityCOMP1}$$

$$M_{\text{ammoniaCOMP1}} = 27.671 \text{ lb}$$

High Pressure Compressor

The net volume for ammonia vapor in the compressor is assumed to be 0.7*2.0 m³:

$$V_{\text{compressor2}} := 0.7 \cdot 2.0 \cdot 3.28^3$$

$$V_{\text{compressor2}} = 49.403 \quad \text{ft}^3$$

$$\text{densityCOMP2} := 0.062 (18.955) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaCOMP2}} := V_{\text{compressor2}} \cdot \text{densityCOMP2}$$

$$M_{\text{ammoniaCOMP2}} = 58.058 \quad \text{lb}$$

Pipe1

Pipe between condenser and evaporator is assumed to have the following length and diameter:

$$L_p := 20 \quad \text{ft}$$

$$D_p := 5 \quad \text{in}$$

To cross check the above figures, the velocity is calculated and then it is compared to the typical values for velocity according to rules of thumb:

$$A_{\text{pipe}} := \frac{\pi \cdot D_p^2 \cdot (6.944 \times 10^{-3})}{4}$$

$$A_{\text{pipe}} = 0.136 \quad \text{ft}^2$$

Volumetric flow in pipe:

$$Q := 7.575 \times 10^{-3} \cdot (35.288)$$

$$Q = 0.267 \quad \frac{\text{ft}^3}{\text{sec}}$$

$$V_{\text{pipe}} := \frac{Q}{A_{\text{pipe}}}$$

$$V_{\text{pipe}} = 1.961 \quad \frac{\text{ft}}{\text{sec}}$$

This velocity complies with the range of medium viscosity liquid velocity. Therefore the ammonia inventory in this pipe is calculated as follows:

$$V_{\text{ammoniaPIPE1}} := A_{\text{pipe}} \cdot L_p$$

$$V_{\text{ammoniaPIPE1}} = 2.727 \quad \text{ft}^3$$

$$\text{densitypipe1} := 513.3950.062 \quad \frac{\text{lb}}{\text{ft}^3}$$

$$\text{MammoniaPIPE1} := \text{densitypipe1} \cdot \text{VammoniaPIPE}$$

$$\text{MammoniaPIPE1} = 86.799 \quad \text{lb}$$

Pipe2

Pipe between evaporator and Compressor1 is assumed to have the following length and diameter :

$$L_p := 20 \quad \text{ft}$$

$$D_p := 7 \quad \text{in}$$

To cross check the above figures, the velocity is calculated and then it is compared to the rules of thumb for velocity:

$$A_{\text{pipe}} := \frac{\pi \cdot D_p^2 \cdot (6.944 \times 10^{-3})}{4}$$

$$A_{\text{pipe}} = 0.267 \quad \text{ft}^2$$

Volumetric flow in pipe:

$$Q := 0.779(35.288)$$

$$Q = 27.489 \quad \frac{\text{ft}^3}{\text{sec}}$$

$$V_{\text{pipe}} := \frac{Q}{A_{\text{pipe}}}$$

$$V_{\text{pipe}} = 102.865 \quad \frac{\text{ft}}{\text{sec}}$$

This velocity is within the range for a medium pressure vapor. Therefore the ammonia inventory in this pipe is calculated as follows:

$$\text{VammoniaPIPE2} := A_{\text{pipe}} \cdot L_p$$

$$\text{VammoniaPIPE2} = 5.345 \quad \text{ft}^3$$

$$\text{densityPIPE2} := 0.062(4.989) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$\text{MammoniaPIPE2} := \text{VammoniaPIPE2} \cdot \text{densityPIPE2}$$

$$\text{MammoniaPIPE2} = 1.653 \quad \text{lb}$$

Pipe3

Pipe between Compressor1 and intercooler is assumed to have the following length and diameter:

$$L_p := 6.56 \quad \text{ft}$$

$$D_p := 7 \quad \text{in}$$

To cross check the above figures, the velocity is calculated and then it is compared to the rules of thumb for velocity:

$$A_{\text{pipe}} := \frac{\pi \cdot D_p^2 \cdot (6.944 \times 10^{-3})}{4}$$

$$A_{\text{pipe}} = 0.267 \quad \text{ft}^2$$

Volumetric flow in pipe:

$$Q := 0.43 (35.288)$$

$$Q = 15.174 \quad \frac{\text{ft}^3}{\text{sec}}$$

$$V_{\text{pipe}} := \frac{Q}{A_{\text{pipe}}}$$

$$V_{\text{pipe}} = 56.781 \quad \frac{\text{ft}}{\text{sec}}$$

This velocity is within the range for a medium pressure vapor. Therefore the ammonia inventory in this pipe is calculated as follows:

$$V_{\text{ammoniaPIPE3}} := A_{\text{pipe}} \cdot L_p$$

$$V_{\text{ammoniaPIPE3}} = 1.753 \quad \text{ft}^3$$

$$\text{densityPIPE3} := 0.062 (9.034) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaPIPE3}} := V_{\text{ammoniaPIPE3}} \cdot \text{densityPIPE3}$$

$$M_{\text{ammoniaPIPE3}} = 0.982 \quad \text{lb}$$

Pipe4

Pipe between intercooler and Compressor2 is assumed to have the following length and diameter:

$$L_p := 6.56 \quad \text{ft}$$

$$D_p := 7$$

To cross check the above figures, the velocity is calculated and then it is compared to the rule of thumb for velocity:

$$A_{\text{pipe}} := \frac{\pi \cdot D_p^2 \cdot (6.944 \times 10^{-3})}{4}$$

$$A_{\text{pipe}} = 0.267 \quad \text{ft}^2$$

Volumetric flow in pipe:

$$Q := 0.412 (35.288)$$

$$Q = 14.539 \quad \frac{\text{ft}^3}{\text{sec}}$$

$$V_{\text{pipe}} := \frac{Q}{A_{\text{pipe}}}$$

$$V_{\text{pipe}} = 54.404 \quad \frac{\text{ft}}{\text{sec}}$$

This velocity is within the range for a medium pressure vapor. Therefore the ammonia inventory in this pipe is calculated as follows:

$$V_{\text{ammoniaPIPE4}} := A_{\text{pipe}} \cdot L_p$$

$$V_{\text{ammoniaPIPE4}} = 1.753 \quad \text{ft}^3$$

$$\text{densityPIPE4} := 0.062 (9.432) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaPIPE4}} := V_{\text{ammoniaPIPE4}} \cdot \text{densityPIPE4}$$

$$M_{\text{ammoniaPIPE4}} = 1.025 \quad \text{lb}$$

Pipe5

Pipe between Compressor2 and condenser is assumed to have the following length and diameter:

$$L_p := 20 \quad \text{ft}$$

$$D_p := 5 \quad \text{in}$$

To cross check the above figures, the velocity is calculated and then it is compared to the rule of thumb for velocity:

$$A_{\text{pipe}} := \frac{\pi \cdot D_p^2 \cdot (6.944 \times 10^{-3})}{4}$$

$$A_{\text{pipe}} = 0.136 \quad \text{ft}^2$$

Volumetric flow in pipe:

$$Q := 0.205 (35.288)$$

$$Q = 7.234 \quad \frac{\text{ft}^3}{\text{sec}}$$

$$V_{\text{pipe}} := \frac{Q}{A_{\text{pipe}}}$$

$$V_{\text{pipe}} = 53.057 \quad \frac{\text{ft}}{\text{sec}}$$

This velocity is within the range for a medium pressure vapor. Therefore the ammonia inventory in this pipe is calculated as follows:

$$V_{\text{ammoniaPIPE5}} := A_{\text{pipe}} \cdot L_p$$

$$V_{\text{ammoniaPIPE5}} = 2.727 \quad \text{ft}^3$$

$$\text{densityPIPE5} := 0.062 (18.955) \quad \frac{\text{lb}}{\text{ft}^3}$$

$$M_{\text{ammoniaPIPE5}} := V_{\text{ammoniaPIPE5}} \text{densityPIPE5}$$

$$M_{\text{ammoniaPIPE5}} = 3.205 \quad \text{lb}$$

Total amount of ammonia in the cycle:

$$\text{SUM1} := M_{\text{ammoniaPIPE1}} + M_{\text{ammoniaPIPE2}} + M_{\text{ammoniaPIPE3}} + M_{\text{ammoniaPIPE4}}$$

$$\text{SUM2} := M_{\text{ammoniaPIPE5}} + M_{\text{ammoniaEVP}} + M_{\text{ammoniaCOND}} + M_{\text{vaporammoniaEVP}}$$

$$\text{SUM3} := M_{\text{vaporammoniaCOND}} + M_{\text{ammoniaCOMP1}} + M_{\text{ammoniaCOMP2}} + M_{\text{ammoniaHEX}}$$

$$M_{\text{total}} := \text{SUM1} + \text{SUM2} + \text{SUM3}$$

$$M_{\text{total}} = 1.524 \times 10^3 \quad \text{lb}$$

$$M_{\text{total}} := 0.454 M_{\text{total}}$$

The rough amount of ammonia inventory in the cycle is:

$$M_{\text{total}} = 691.921 \quad \text{kg}$$

References

W. D. Seider, J.D. Seader, D.R. Lewin, "Product & Process Design Principles", John Wiley and Sons, Inc., 2004.

Appendix 2 Preliminary Estimation for Ammonia Cycle

Estimating the vapor pressure of ammonia

(Ref: RPP, The properties of Gases and Liquids, 4th Edition)

Parameters for Wagner equation:

$$VPA := 45.327 \quad VPB := 4104.6 \quad VPC := -5.146 \quad VPD := 615$$

$$t := 15 \quad C$$

pvap := 8 Initial guess to solve the nonlinear equation below (t in C and Ps in bar)

$$Ps(T) := \text{root} \left[\ln(\text{pvap}) - \left[(VPA) - \frac{VPB}{t + 273} + VPC \ln(t + 273) + \frac{VPD \text{pvap}}{(t + 273)^2} \right], \text{pvap} \right]$$


$$Ps(T) = 7.297 \quad \text{bar} \quad \text{Saturation pressure at 15C}$$

t := 15, 16..95 Temperature range (C) to construct the curve Pvap (bar) versus t (C)

pvap := 8 Initial guess to solve the nonlinear equation for all points

$$Ps(t) := \text{root} \left[\ln(\text{pvap}) - \left[(VPA) - \frac{VPB}{t + 273} + VPC \ln(t + 273) + \frac{VPD \text{pvap}}{(t + 273)^2} \right], \text{pvap} \right]$$

Ps(t) =	t =
7.297	15
7.539	16
7.786	17
8.045	18
8.302	19
8.577	20
8.851	21
9.131	22
9.416	23
9.722	24
10.025	25
10.335	26
10.653	27
10.977	28
11.309	29
11.647	30



Calculating the mass flow rate of ammonia: energy balance in the ammonia evaporator:

$$m_{\text{wastewater}} := 29180 \quad \text{kg/h} \quad T_{\text{wastewaterin}} := 25 + 273 \quad T_{\text{wastewaterout}} := 18 + 273$$

Heuristics for heat exchangers: Considering minimum approach temperature of 3 C between water out and ammonia in, the vaporization of ammonia should occur at 15 C. The vapor pressure of ammonia at 15 C is 7.3 bar.

$$h_{\text{vap}} := 627.3 \frac{0.252}{0.454} \quad h_{\text{vap}} = 348.193 \quad \text{kcal/kg} \quad \text{Ref : Smith \& van Ness, 4th edition, Page 285, Table 9.2, Thermodynamic Properties of saturated ammonia}$$

$$h_{\text{liq}} := 109.2 \frac{0.252}{0.454} \quad h_{\text{liq}} = 60.613 \quad \text{kcal/kg} \quad \text{Values taken at 15.5C and 7.4 bar}$$

Using a correlation CP(T) for water and ammonia

Constants for water liquid

Ref : Smith & van Ness, 4th edition,
Page 114, Table 4.3, Heat capacity of liquids
(Validity: T from 273.15 to 373.15 K)

$$CP_{Awliq} := 8.712 \quad CP_{Bwliq} := 1.25 \cdot 10^{-3} \quad CP_{Cwliq} := -0.18 \cdot 10^{-6}$$

Constants for ammonia liquid

$$CP_{Amliq} := 22.626 \quad CP_{Bamliq} := -100.75 \cdot 10^{-3} \quad CP_{Camliq} := 192.71 \cdot 10^{-6}$$

$$R := 8.314 \quad \text{J}/(\text{mol} \cdot \text{K})$$

$$CP_w(T) := R \cdot \frac{1000}{18} \cdot (CP_{Awliq} + CP_{Bwliq}T + CP_{Cwliq}T^2) \quad \text{J}/(\text{kg} \cdot \text{K})$$

$$cp_{wastewater} := \frac{\int_{T_{wastewaterin}}^{T_{wastewaterout}} CP_w(T) dT}{T_{wastewaterout} - T_{wastewaterin}}$$

$$cp_{wastewater} = 4.187 \times 10^3 \quad \text{J}/(\text{kg} \cdot \text{K})$$

$$m_{ammonia} := \frac{m_{wastewater} \cdot cp_{wastewater} \cdot (T_{wastewaterin} - T_{wastewaterout})}{(h_{vap} - h_{liq}) \cdot 1000 \cdot 4.18}$$

$$m_{ammonia} = 7.114 \times 10^3 \quad \text{kg/h}$$

This is the amount of ammonia that must be circulating in the heat pump cycle. This data serve as input for a tear stream required by Aspen for the simulation of the whole system.

Ammonia will be vaporizing at ~15 C and 7.4 bar and removing heat from the waste heat stream.

The clean water (tap water) will be upgraded in the ammonia condenser.
 Heuristic for the condenser: Minimum approach of ~3C. Therefore the condensation temperature will be 93-95C. Therefore the ammonia compressor must operate at a discharge pressure, which is correspondent to 93C(~200F) via isentropic compression. According to Figure 9.4 - Pressure/enthalpy for ammonia (Smith & van Ness, 4th edition, Page 284), the pressure at the compressor discharge should be ~17.22 bar.

Preliminary calculation the mass flow rate of clean water: energy balance in the ammonia condenser (this value serves only as preliminary guess).

$$h_g := 685 \frac{0.252}{0.454} \quad h_g = 380.22 \quad \text{kcal/kg} \quad \text{Ref : Smith \& van Ness, 4th edition, Page 284, Table 9.4 Pressure/enthalpy diagram for ammonia}$$

$$h_L := 170 \frac{0.252}{0.454} \quad h_L = 94.361 \quad \text{kcal/kg} \quad \text{Values taken at ~17 bar}$$

$$T_{\text{cleanwaterin}} := 60 \quad \text{C} \quad T_{\text{cleanwaterout}} := 90 \quad \text{C}$$

Using the same correlation CP(T) for water as above

$$c_{p\text{cleanwater}} := \frac{\int_{T_{\text{cleanwaterin}}}^{T_{\text{cleanwaterout}}} C_{Pw}(T) dT}{T_{\text{cleanwaterout}} - T_{\text{cleanwaterin}}} \quad c_{p\text{cleanwater}} = 4.067 \times 10^3 \quad \text{J/(kg.K)}$$

$$m_{\text{cleanwater}} := \frac{m_{\text{ammonia}} (h_g - h_L) \cdot 1000 \cdot 4.18}{c_{p\text{cleanwater}} \cdot (T_{\text{cleanwaterout}} - T_{\text{cleanwaterin}})} \quad \text{kg/h}$$

$$m_{\text{cleanwater}} = 6.968 \times 10^4 \quad \text{kg/h}$$

Appendix 3 Economic Evaluation of Ammonia Heat Pump

The Main Design

All the costs have been evaluated based on "Product and Process Design Principles" [1].

According to Chemical engineering Magazine (2), the Annual CE Plant Cost Index for 2000 (Base Case):

$$CE1 := 394.1$$

The Annual CE Plant Cost Index for 2004:

$$CE2 := 444.2$$

The cost of equipments are calculated, as follows:

Basis of Compressor Design:

1. Maximum discharge pressure of the compressor corresponds to a maximum temperature of 375 F (190 C) (heuristics #35, page 186 [1]).
2. Maximum compression ratio = 4 for each stage (Heuristics #36, page 186 [1]).

$$P_{\text{suction}} := 6.5 \text{ bar} \quad P_{\text{discharge}} := 38 \text{ bar}$$

These values are just initial guess for the simulation. Final values will be calculated via Aspen Simulation.

$$\text{Ratio} := \frac{P_{\text{discharge}}}{P_{\text{suction}}}$$

$$\text{Ratio} = 5.846 \quad \text{Ratio} > 4, 4 < \text{Ratio} < 16, \text{ from the table, page 186, the number of stages must be 2.}$$

$$n_{\text{stages}} := 2$$

For equal compression ratios, yields:

$$\text{ratio per stage} := \text{Ratio}^{\frac{1}{n_{\text{stages}}}}$$

$$\text{ratio per stage} = 2.418$$

The pressure ratio in each compression stage will be 2.32

There will be two compression stages with an inter-stage receiver between them. The initial guess pressure profile will be as follows:

$$\begin{aligned} P_{\text{suction 1}} &= 6.5 \text{ bar} & P_{\text{discharge 1}} &= 14.6 \text{ bar} \\ P_{\text{receiver inlet}} &= 14.6 \text{ bar} \\ P_{\text{suction 2}} &= 14.6 \text{ bar} & P_{\text{discharge 2}} &= 38 \text{ bar} \end{aligned}$$

According to heuristics #31, the following applies:

ΔP for condenser and evaporator = 1.5 psi (0.103 bar) for boiling and condensing fluids

Inter-stage receiver outlet temperature should be higher than 100 F (38C), according to heuristics #35 [1].

Low Pressure Compressor:

Reciprocating compressor has been selected. The points to be considered with regard to this type of compressor are:

- 1- High efficiency (80%-90%)
- 2-More expensive
- 3-Larger in size
- 4-More flexible in operation
- 5-Large foundation and more maintenance are required
- 6-Less noisy
- 7-Must be protected by a knock-out drum

It should be mentioned that the compressor type is in compliance with reference [3]

The compressor is driven by a electric motor with a typical efficiency of 95% for 1000 hp. Thus, the driven factor for electric motor is:

$$FD := 1$$

Carbon Steel material factor has been applied:

$$FM := 1.0$$

Low pressure compressor Break HorsePower is:

$$hp1 := 924.76 \text{ hp}$$

$$CB1 := \exp(7.6084 + 0.80 \ln(hp1))$$

Capital Cost for low pressure compressor:

$$CpCOMP1 := FD \cdot FM \cdot CB1 \cdot \left(\frac{CE2}{CE1} \right)$$

$$CpCOMP1 = 5.359 \times 10^5 \quad \$$$

High Pressure Compressor :

Reciprocating compressor has been selected. The points to be considered with regard to this type of compressor are:

- 1- High efficiency (80%-90%)
- 2-More expensive
- 3-Larger in size
- 4-More flexible in operation
- 5-Large foundation and more maintenance are required
- 6-Less noisy
- 7-Must be protected by a knock-out drum

It should be mentioned that the compressor type is in compliance with reference [3].

The compressor is driven by a electric motor with a typical efficiency of 95% for 1000 hp. Thus, the driven factor for electric motor is:

$$FD := 1$$

Carbon Steel material factor has been applied:

$$FM := 1.0$$

High pressure compressor Break HorsePower is:

$$hp2 := 1.268 \times 10^3 \text{ hp}$$

$$CB2 := \exp(7.6084 + 0.80 \ln(hp2))$$

Capital Cost for high pressure compressor :

$$CpCOMP2 := FD \cdot FM \cdot CB2 \left(\frac{CE2}{CE1} \right)$$

$$CpCOMP2 = 6.898 \times 10^5 \quad \$$$

Air Blower:

This blower is oversized to cope with the fluctuations in the winter time.

$$hpBLOWER := 3.017 \times 10^3 \text{ hp}$$

$$CBLOWER := \exp(6.6547 + 0.79 \ln(hpBLOWER))$$

For cast iron, the material factor is:

$$FM := 0.6$$

Capital Cost for air blower:

$$C_{pBLOWER} := FM \cdot CBLOWER \left(\frac{CE2}{CE1} \right)$$

$$C_{pBLOWER} = 2.945 \times 10^5 \quad \$$$

Evaporator :

Area of the evaporator: $AEVP := 7.927 \times 10^3 \quad \text{ft}^2$

The material of construction of the shell and tube sides is carbon steel, thus:

$$FM := 0 + \left(\frac{AEVP}{100} \right)^0$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PEVP_{Shell} := 81.025 \quad \text{psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PEVP_{Shell}}{100} \right) + 0.0017 \left(\frac{PEVP_{Shell}}{100} \right)^2$$

$$FP = 0.996$$

The evaporator is of Kettle Vaporizer type:

$$CBEVP := \exp \left[11.967 - 0.8709 \ln(AEVP) + 0.09005 (\ln(AEVP))^2 \right]$$

The purchase cost of the evaporator is:

$$C_{pEVP} := FP \cdot FM \cdot FL \cdot CBEVP \left(\frac{CE2}{CE1} \right)$$

$$C_{pEVP} = 1.13 \times 10^5 \quad \$$$

Condenser:

Area of the condenser: $ACOND := 2.36 \times 10^3 \text{ ft}^2$

The material of construction of the shell and tube sides is carbon steel, thus:

$$FM := 0 + \left(\frac{ACOND}{100} \right)^0$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PCONDS_{shell} := 536.44 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PCONDS_{shell}}{100} \right) + 0.0017 \left(\frac{PCONDS_{shell}}{100} \right)^2$$

$$FP = 1.126$$

The condenser is of Kettle Vaporizer type:

$$CBCOND := \exp \left[11.967 - 0.8709 \cdot \ln(ACOND) + 0.09005 \cdot (\ln(ACOND))^2 \right]$$

The purchase cost of the condenser is:

$$C_pCOND := FP \cdot FM \cdot FL \cdot CBCOND \left(\frac{CE2}{CE1} \right)$$

$$C_pCOND = 5.906 \times 10^4 \text{ \$}$$

Fired Heater:

The cost of the fired heater depends on absorbed heat. Since the operational pressure is not too high and the material of construction is carbon steel, there is no need to apply any correction factor.

This fired heater is designed in such a way to cope with the fluctuations in the winter time. Furthermore, the flue gas heat exchanger and the furnace are combined:

$$Q_{\text{Furnace}} := 3.554 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$Q_{\text{FGHX}} := 1.449 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$Q_{\text{duty}} := Q_{\text{FGHX}} + Q_{\text{Furnace}}$$

$$Q_{\text{duty}} = 5.003 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$\text{Pressure factor: } FP := 1$$

$$\text{Material Factor: } FM := 1$$

$$CB_{\text{FIRHEAT}} := 0.512(Q_{\text{duty}})^{0.81}$$

$$Cp_{\text{FIRHEAT}} := FP \cdot FM \cdot CB_{\text{FIRHEAT}} \left(\frac{CE2}{CE1} \right)$$

$$Cp_{\text{FIRHEAT}} = 6.421 \times 10^6 \text{ \$}$$

Pump:

Centrifugal pump is selected because all the requirements in terms of volumetric flow rate, developed head and NPSH are met.

$$Q := 7.91 \times 10^3 \text{ gpm}$$

$$NPSH := 116.28 \text{ ft}$$

$$H := 259.04 \text{ ft}$$

$$S := Q \cdot (H)^{0.5}$$

$$S = 1.273 \times 10^5 \text{ gpm} \cdot \text{ft}^{0.5}$$

The material of construction is cast iron, thus:

$$FM := 1.0$$

The type of pump is 1 stage radial centrifugal pump (HSC) with 3600 shaft rpm, thus:

$$FT := 1.70$$

$$CB_{\text{PUMP}} := \exp(9.2951 - 0.6019 \ln(S) + 0.0519 \ln(S)^2)$$

$$Cp_{\text{Pump}} := FT \cdot FM \cdot CB_{\text{PUMP}} \left(\frac{CE2}{CE1} \right)$$

The cost of electric motor for pump is calculated as follows:

Pump brake horsepower: $PB := 650.08$ hp

$$\eta_m := 0.80 + 0.0319 \ln(PB) - 0.00182 (\ln(PB))^2$$

$$PC := \frac{PB}{\eta_m}$$

The motor type of "Totally enclosed, fan-cooled enclosure" with 3600 rpm is selected, thus the type factor for the electric motor is:

$$FT_{\text{motor}} := 1.4$$

$$CBMOTOR := \exp \left[5.4866 + 0.13141 \ln(PC) + 0.053255 (\ln(PC))^2 + 0.028628 (\ln(PC))^3 - 0.0035549 (\ln(PC))^4 \right]$$

$$Cp_{\text{Motor}} := FT_{\text{motor}} \cdot CBMOTOR \cdot \left(\frac{CE2}{CE1} \right)$$

$$Cp_{\text{PumpTotal}} := Cp_{\text{Pump}} + Cp_{\text{Motor}}$$

$$Cp_{\text{PumpTotal}} = 6.267 \times 10^4 \quad \$$$

A spare pump needs to be added.

Heat Exchanger Inter-Cooler:

Area of the inter-cooler: $AHXINCOOLER := 2.828 \times 10^3$ ft²

The material of construction of the shell and tube sides is carbon steel, thus:

$$FM := 0 + \left(\frac{AHXINCOOLER}{100} \right)^0$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PHXINCOOLERS_{\text{Shell}} = 202.86 \quad \text{psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHXINCOOLERS_{Shell}}{100} \right) + 0.0017 \left(\frac{PHXINCOOLERS_{Shell}}{100} \right)^2$$

$$FP = 1.024$$

The heat exchanger is of floating head type:

$$CBHXINCOOLER = \exp \left[11.667 - 0.8709 \ln(AHXINCOOLER) + 0.09005 (\ln(AHXINCOOLER))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXINCOOLER} = FP \cdot FM \cdot FL \cdot CBHXINCOOLER \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXINCOOLER} = 4.39 \times 10^4 \quad \$$$

Ammonia Collector Vessel:

The amount of ammonia in the cycle is calculated to be:

$$m_{ammonia} := 700 \quad \text{kg}$$

Therefore, considering an over design factor of 0.15, the volume of the collector vessel is calculated as follows:

$$\text{density}_{ammonia} := 513.4 \quad \frac{\text{kg}}{\text{m}^3}$$

$$\text{vol} := \frac{m_{ammonia} \cdot 1.15}{\text{density}_{ammonia}}$$

$$\text{vol} = 1.568 \quad \text{m}^3$$

The ratio of length to diameter is assumed to be 2.5:

$$D := 1 \quad L := 2.5$$

Given

$$L = 2.5D$$

$$\text{vol} = \frac{\pi \cdot D^2 \cdot L}{4}$$

$$y := \text{Find}(D, L)$$

$$y = \begin{pmatrix} 0.928 \\ 2.319 \end{pmatrix}$$

Therefore vessel's dimensions are as follows:

$$D := 0.9283.28 \quad \text{ft}$$

$$L := 2.3193.28 \quad \text{ft}$$

Density of carbon steel:

$$\text{density} := 490 \frac{\text{lb}}{\text{ft}^3}$$

Since the operating pressure of vessel is 37.5 bar, the design pressure is calculated as:

$$P := 537 \quad \text{psig}$$

$$P_d := \exp\left[0.60608 + 0.91615 \ln(P) + 0.0015655 (\ln(P))^2\right]$$

$$P_d = 618.227 \quad \text{psig}$$

The operating temperature of vessel is 160 F, thus the design temperature is:

$$T_d := 230 \quad \text{F}$$

For SA-387B which is a commonly used low-alloy (1%Cr and 0.5% Mo) steel for non-corrosive environment including the presence of hydrogen, operating at this design temperature the maximum allowable stress is:

$$S := 15000 \quad \text{psi}$$

For carbon steel the value of welding efficiency is:

$$E := 0.85$$

Based on the above values, the cylindrical shell wall thickness is computed from ASME pressure-vessel code as follows:

$$t_p := \frac{P_d \cdot D \cdot 12}{2 \cdot S \cdot E - 1.2 \cdot P_d}$$

$$t_p = 0.912 \quad \text{inch}$$

The weight of the shell and the two heads is approximately:

$$W := \pi \cdot \left(D + \frac{t_p}{12}\right) \cdot (L + 0.8 \cdot D) \cdot \frac{t_p \cdot \text{density}}{12}$$

$$W = 3.665 \times 10^3 \quad \text{lb}$$

The material of construction is carbon steel:

$$FM := 1.0$$

The cost of horizontal vessels are estimated by:

$$C_v := \exp\left[(8.717 - 0.2330 \ln(W)) + 0.0433 (\ln(W))^2\right]$$

The added cost for platforms and ladders is given by:

$$C_p := 1580 D^{0.20294}$$

Therefore the cost of this vessel is;

$$C_{pVESSEL} := FM \cdot C_v + C_p$$

$$C_{pVESSEL} = 1.865 \times 10^4 \quad \$$$

Heat Exchanger District 1:

Area of the HXDIS1: $A_{HXDIS1} := 1.676 \times 10^4 \quad \text{ft}^2$

The material of construction of the shell side and the tube side is carbon steel, thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS1}}{100}\right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PHXDIS1_{Shell} := 170.98 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHXDIS1_{Shell}}{100}\right) + 0.0017 \left(\frac{PHXDIS1_{Shell}}{100}\right)^2$$

$$FP = 1.016$$

The heat exchanger is of floating head type:

$$C_{BHDXDIS1} := \exp\left[11.667 - 0.8709 \ln(A_{HXDIS1}) + 0.09005 (\ln(A_{HXDIS1}))^2\right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS1} := FP \cdot FM \cdot FL \cdot CBHXDIS1 \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS1} = 1.571 \times 10^5 \text{ \$}$$

Heat Exchanger District 2:

Area of the HXDIS2: $AHXDIS2 := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel, thus:

$$FM := 0.00 + \left(\frac{AHXDIS2}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PHXDIS2Shell := 168.11 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHXDIS2Shell}{100} \right) + 0.0017 \left(\frac{PHXDIS2Shell}{100} \right)^2$$

$$FP = 1.015$$

The heat exchanger is of floating head type:

$$CBHXDIS2 := \exp \left[11.667 - 0.8709 \ln(AHXDIS2) + 0.09005 (\ln(AHXDIS2))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS2} := FP \cdot FM \cdot FL \cdot CBHXDIS2 \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS2} = 1.57 \times 10^5 \text{ \$}$$

Heat Exchanger District 3:

Area of the HXDIS3: $A_{HXDIS3} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS3}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$P_{HXDIS3Shell} := 127.73 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HXDIS3Shell}}{100} \right) + 0.0017 \left(\frac{P_{HXDIS3Shell}}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CB_{HXDIS3} := \exp \left[11.667 - 0.8709 \ln(A_{HXDIS3}) + 0.09005 (\ln(A_{HXDIS3}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS3} := FP \cdot FM \cdot FL \cdot CB_{HXDIS3} \left(\frac{CE2}{CE1} \right) \text{ ft}^2$$

$$C_{pHXDIS3} = 1.555 \times 10^5 \$$$

Heat Exchanger District 4:

Area of the HXDIS4: $A_{HXDIS4} := 1.676 \times 10^4$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS4}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PHXDIS4Shell := 127.101 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHXDIS4Shell}{100} \right) + 0.0017 \left(\frac{PHXDIS4Shell}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CBHXDIS4 := \exp \left[11.667 - 0.8709 \ln(AHXDIS4) + 0.09005 (\ln(AHXDIS4))^2 \right]$$

The purchase cost of the heat exchanger is:

$$CpHXDIS4 := FP \cdot FM \cdot FL \cdot CBHXDIS4 \left(\frac{CE2}{CE1} \right)$$

$$CpHXDIS4 = 1.555 \times 10^5 \text{ \$}$$

Heat Exchanger District 5:

Area of the HXDIS5: $AHXDIS5 := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{AHXDIS5}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PHXDIS5Shell := 127.42 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHXDIS5Shell}{100} \right) + 0.0017 \left(\frac{PHXDIS5Shell}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CBHXDIS5 := \exp\left[11.667 - 0.8709 \ln(AHXDIS5) + 0.09005 (\ln(AHXDIS5))^2\right]$$

The purchase cost of the heat exchanger is:

$$CpHXDIS5 := FP \cdot FM \cdot FL \cdot CBHXDIS5 \left(\frac{CE2}{CE1}\right)$$

$$CpHXDIS5 = 1.555 \times 10^5 \text{ \$}$$

Total Purchase Cost (The main case):

$$SUM1 := CpCOMP1 + CpCOMP2 + CpEVP + CpCOND + CpHXINCOOLEF$$

$$SUM2 := CpFIRHEAT + CpBLOWER + 2 \cdot CpPumpTotal + CpVESSEI$$

$$SUM3 := CpHXDIS1 + CpHXDIS2 + CpHXDIS3 + CpHXDIS4 + CpHXDIS5$$

$$\text{capitalcost} := SUM1 + SUM2 + SUM3$$

$$\text{capitalcost} = 9.082 \times 10^6 \text{ \$}$$

Costs of the Alternative Design

The costs were also calculated for an alternative case in which two tanks and a smaller furnace were used to cope with the demand fluctuations.

Air Blower:

This blower is oversized to cope with the fluctuations in the winter time.

$$\text{hpBLOWER} := 1.81 \times 10^3 \text{ hp}$$

$$\text{CBLOWER} := \exp(6.6547 + 0.79 \ln(\text{hpBLOWER}))$$

Capital Cost for air blower:

$$\text{FM} := 0.6$$

$$\text{CpBLOWER} := \text{FM} \cdot \text{CBLOWER} \left(\frac{\text{CE2}}{\text{CE1}} \right)$$

$$\text{CpBLOWER} = 1.967 \times 10^5 \text{ \$}$$

Fired Heater:

The cost of the fired heater depends on absorbed heat. Since the operational pressure is not too high and the material of construction is carbon steel, there is no need to apply any correction factor.

The flue gas heat exchanger and the furnace are combined:

$$\text{QFurnace} := 2.132 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$\text{QFGHX} := 1.449 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$\text{Qduty} := \text{QFGHX} + \text{QFurnace}$$

$$\text{Qduty} = 3.581 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$\text{Pressure factor: } \text{FP} := 1$$

$$\text{Material Factor: } \text{FM} := 1$$

$$\text{CBFIRHEAT} := 0.512 (\text{Qduty})^{0.81}$$

$$\text{CpFIRHEAT} := \text{FP} \cdot \text{FM} \cdot \text{CBFIRHEAT} \left(\frac{\text{CE2}}{\text{CE1}} \right)$$

$$\text{CpFIRHEAT} = 4.898 \times 10^6 \text{ \$}$$

Tank 1 (Before Condenser) :

The volume of the tank was calculated to be as follows (10% overdesign):

$$V_{\text{tank}} := 4200 \quad \text{m}^3$$

According to rules of thumb the length and diameter ratio is 2.5. For a vertical tank:

$$\text{initial values:} \quad D := 1 \quad L := 3$$

Given

$$L = 2.5 \cdot D$$

$$V_{\text{tank}} = \frac{\pi \cdot D^2 \cdot L}{4}$$

$$\text{dim} := \text{Find}(D, L)$$

$$\text{dim} = \begin{pmatrix} 12.885 \\ 32.212 \end{pmatrix}$$

thus the diameter and length of the tank are:

$$D := 12.8853.281 \quad \text{ft}$$

$$L := 32.2123.281 \quad \text{ft}$$

In order to evaluate the cost of this tank, first the weight of the tank should be found:

$$\text{Density of carbon steel:} \quad \text{density} := 490 \quad \frac{\text{lb}}{\text{ft}^3}$$

Since the operating pressure of the tank is approximately 6 atm (adjusted by a valve before the tank), the design pressure is calculated as follows:

$$P := 73.5 \quad \text{psig}$$

$$P_d := \exp\left[0.60608 + 0.91615 \ln(P) + 0.0015655 (\ln(P))^2\right]$$

$$P_d = 96.732 \quad \text{psig}$$

The operating temperature of the column is approximately 150.8 F, thus the design temperature is:

$$T_d := 200 \quad \text{F}$$

For SA-387B which is a commonly used low-alloy (1%Cr and 0.5% Mo) steel for non-corrosive environment including the presence of hydrogen, operating at this design temperature the maximum allowable stress is:

$$S := 15000 \quad \text{psi}$$

For carbon steel the value of welding efficiency is:

$$E := 0.85$$

Based on the above values, the cylindrical shell wall thickness is computed from ASME pressure-vessel code as follows:

$$t_p := \frac{P_d \cdot D \cdot 12}{2 \cdot S \cdot E - 1.2 \cdot P_d}$$

$$t_p = 1.933 \quad \text{inch}$$

The weight of the shell and the two heads is approximately:

$$W_1 := \pi \cdot \left(D + \frac{t_p}{12} \right) \cdot (L + 0.8 \cdot D) \cdot \frac{t_p \cdot \text{density}}{12}$$

$$W_1 = 1.468 \times 10^6 \quad \text{lb}$$

The cost of the tank is:

$$C_v\text{TANK1} := \exp(6.775 + 0.18255 \ln(W_1) + 0.02297 \ln(W_1)^2)$$

$$C_v\text{TANK1} = 1.201 \times 10^6 \quad \$$$

The cost of ladders and platforms is:

$$C_{p1}\text{TANK} := 285.1 \cdot D^{0.73960} \cdot L^{0.70684}$$

$$C_{p1}\text{TANK} = 1.226 \times 10^5 \quad \$$$

For material of construction of carbon steel:

$$F_m := 1.0$$

thus the total cost of this tank is:

$$C_{p}\text{TANK1} := (F_m \cdot C_v\text{TANK1} + C_{p1}\text{TANK}) \cdot \left(\frac{CE_2}{CE_1} \right)$$

$$C_{p}\text{TANK1} = 1.492 \times 10^6 \quad \$$$

Tank 2 (Before Furnace) :

The volume of the tank was calculated to be as follows (10% overdesign):

$$V_{\text{tank}} := 420 \quad \text{m}^3$$

According to rules of thumb the length and diameter ratio is 2.5. For a vertical tank:

initial values: $D := 1$ $L := 3$

Given

$$L = 2.5 \cdot D$$

$$V_{\text{tank}} = \frac{\pi \cdot D^2 \cdot L}{4}$$

$$\text{dim} := \text{Find}(D, L)$$

$$\text{dim} = \begin{pmatrix} 12.885 \\ 32.212 \end{pmatrix}$$

thus the diameter and length of the tank are:

$$D := 12.8853.281 \quad \text{ft}$$

$$L := 32.2123.281 \quad \text{ft}$$

In order to evaluate the cost of this tank, first the weight of the tank should be found:

Density of carbon steel: density := 490 $\frac{\text{lb}}{\text{ft}^3}$

Since the operating pressure of the tank is approximately 3.5 atm (adjusted by a valve before the tank), the design pressure is calculated as follows:

$$P := 36.75 \quad \text{psig}$$

$$P_d := \exp\left[0.60608 + 0.91615 \ln(P) + 0.0015655 (\ln(P)^2)\right]$$

$$P_d = 50.823 \quad \text{psig}$$

The operating temperature of the column is approximately 280 F, thus the design temperature is:

$$T_d := 320 \quad \text{F}$$

For SA-387B which is a commonly used low-alloy (1%Cr and 0.5% Mo) steel for non-corrosive environment including the presence of hydrogen, operating at this design temperature the maximum allowable stress is:

$$S := 15000 \quad \text{psi}$$

For carbon steel the value of welding efficiency is:

$$E := 0.85$$

Based on the above values, the cylindrical shell wall thickness is computed from ASME pressure-vessel code as follows:

$$t_p := \frac{P_d \cdot D \cdot 12}{2 \cdot S \cdot E - 1.2 \cdot P_d}$$

$$t_p = 1.014 \quad \text{inch}$$

The weight of the shell and the two heads is approximately:

$$W2 := \pi \cdot \left(D + \frac{tp}{12} \right) \cdot (L + 0.8 \cdot D) \cdot \frac{tp \cdot \text{density}}{12}$$

$$W2 = 7.683 \times 10^5 \quad \text{lb}$$

The cost of the tank is:

$$CvTANK2 := \exp\left(6.775 + 0.18255 \ln(W2) + 0.02297 \ln(W2)^2\right)$$

$$CvTANK2 = 7.061 \times 10^5 \quad \$$$

The cost of ladders and platforms is:

$$Cp2TANK := 285.1 \cdot D^{0.73960} \cdot L^{0.70684}$$

$$Cp2TANK = 1.226 \times 10^5 \quad \$$$

For material of construction of carbon steel:

$$Fm := 1.C$$

thus the total cost of this tank is:

$$CpTANK2 := (Fm \cdot CvTANK2 + Cp2TANK) \cdot \left(\frac{CE2}{CE1} \right)$$

$$CpTANK2 = 9.34 \times 10^5 \quad \$$$

Total Purchase Cost (The alternative case):

$$SUM1 := CpCOMP1 + CpCOMP2 + CpEVP + CpCOND + CpHXINCOOLER + CpVESSEI$$

$$SUM2 := CpFIRHEAT + CpBLOWER + 2 \cdot CpPumpTotal + CpTANK1 + CpTANK2$$

$$SUM3 := CpHXDIS1 + CpHXDIS2 + CpHXDIS3 + CpHXDIS4 + CpHXDIS4$$

$$\text{capitalcost} := SUM1 + SUM2 + SUM3$$

$$\text{capitalcost} = 9.886 \times 10^6 \quad \$$$

References

- 1- W. D. Seider, J.D. Seader, D.R. Lewin, "Product & Process Design Principles", John Wiley and Sons, Inc., 2004.
- 2- Economic Indicators (July 2005): www.CHE.COM
- 3- W. Dimoplou, "What process engineers need to know about compressors", Hydrocrabon Processing, May 1978.

Appendix 4 Basis for The Compressors Simulation

Reference: Seider, W.D., Seader, J.D., Lewin, D. R., Product and Process Design Principles

1. Maximum discharge pressure of the compressor corresponds to a maximum temperature of 375 F (190 C) (heuristics #35, page 186, from the reference mentioned above).
2. Maximum compression ratio = 4 for each stage (Heuristics #36, page 186, from the reference mentioned above).

$$P_{\text{suction}} := 6.5 \quad \text{bar} \qquad P_{\text{discharge}} := 35 \quad \text{bar}$$

These values are just initial guess for the simulation. Final values will be calculated via Aspen Simulation.

$$\text{Ratio} := \frac{P_{\text{discharge}}}{P_{\text{suction}}} \qquad \text{Ratio} = 5.385 \qquad \text{Ratio} > 4, 4 < \text{Ratio} < 16, \text{ from the table, page 186, the number of stages must be 2.}$$

$$n_{\text{stages}} := 2$$

For equal compression ratios, yields:

$$\text{ratio per stage} := \text{Ratio}^{\frac{1}{n_{\text{stages}}}} \qquad \text{ratio per stage} = 2.32 \qquad \text{The pressure ratio in each compression stage will be 2.32}$$

There will be two compression stages with an inter-stage receiver between them. The initial guess pressure profile will be as follows:

$$\begin{aligned} P_{\text{suction 1}} &= 6.5 \text{ bar} & P_{\text{discharge 1}} &= 14.6 \text{ bar} \\ P_{\text{receiver inlet}} &= 14.6 \text{ bar} \\ P_{\text{suction 2}} &= 14.6 \text{ bar} & P_{\text{discharge 2}} &= 38 \text{ bar} \end{aligned}$$

According to heuristics #31, the following applies:

ΔP for condenser and evaporator = 1.5 psi (0.103 bar) for boiling and condensing fluids

Inter-stage receiver outlet temperature should be higher than 100 F (38C), according to heuristics #35.

Appendix 5 Compressor Scheme

An illustration of a two-stage compressor unit with intermediate cooling system is shown in Figures A5.1 and Figure A5.2




Figure A5.1 Simplified scheme of two-stage compressor with intermediate gas cooling




Figure A5.2 Two stage compressor unit model TSMC 108 with intermediate cooling system

Reference :

http://www.mmrefrigeration.com/mmsite/recip_cooling.html

Appendix 6 Piping Calculations

References:

1. Crane, Flow of Fluids Through Valves, Fittings and Pipe - Technical Paper No. 410, 25th Printing, Technical 1988- Crane Co.
2. Coulson, J.M., Richardson, J.F., Chemical Engineering; Volume 6 (SI Units), BPC Wheatons Ltd. Exeter: 1991
3. Coulson, J.M., Richardson, J.F., Chemical Engineering; Volume 1; Flow, Heat Transfer and Mass Transfer, Sixth edition The Bath Press, Bath: 1999
4. Walas, Stanley M., *Chemical Process Equipment*, Butterworth-Heinemann, Series in Chemical Engineering, USA, 1983

Preliminary Assumptions :

1. Total pipe length from the Upgrading Unit to districts (**main header of hot tap water pipe**) : 10 km (taking into consideration the distribution of districts to be connected over the area shown in the maps of Delft available on the net [<http://www.map24.nl>]).
2. Total pipe length from the districts to the Upgrading Unit (**main header of cold tap water pipe**) : 10 km.
3. This calculation does not take into consideration the branching for pipes inside the districts. Further detailed calculations in this regard must be carried during the detailed design phase.
4. Maximum tap water flow rate $5.32 \cdot 10^6$ kg/h. Calculated based on the worst case scenario (two furnaces operating in winter time)
5. Minimum tap water flow rate $2.13 \cdot 10^5$ kg/h. Calculated based on the highest demand peak in the summer.

Piping calculations for the maximum capacity:

Estimating the piping diameter for hot tap water:

$W_{mflowrate} := 5.32 \times 10^6$	kg/h	Water mass flow rate
$\rho_{hotwaterin} := 963.68$	kg/m^3	Density of water at 92 C = 963 kg/m ³
	$92 \cdot 1.8 + 32 = 197.6$	$60.107 \frac{0.454}{0.3048^3} = 963.687$
$\rho_{hotwaterout} := 967.519$	kg/m^3	Density of water at 90 C = 967.519 kg/m ³
	$90 \cdot 1.8 + 32 = 194$	$60.343 \frac{0.454}{0.3048^3} = 967.471$

Data gathered from Crane:

$$\rho_{\text{hotwater}} := \frac{\rho_{\text{hotwaterin}} + \rho_{\text{hotwaterout}}}{2} \quad \rho_{\text{hotwater}} = 965.603 \quad \text{kg/m}^3$$

$$Q_{\text{hotwater}} := \frac{W_{\text{flowrate}}}{\rho_{\text{hotwater}}} \quad Q_{\text{hotwater}} = 5.51 \times 10^3 \quad \text{m}^3/\text{h}$$

$$\text{waterflowrate} := W_{\text{flowrate}} \cdot \frac{1}{3600} \quad \text{waterflowrate} = 1.478 \times 10^3 \quad \text{kg/s}$$

$$d := 260(\text{waterflowrate})^{0.52} \cdot \rho_{\text{hotwater}}^{-0.3} \quad d = 1.471 \times 10^3 \quad \text{mm}$$

The first estimation for internal diameter of the hot tap water header is 1471 mm (58 inch). This diameter exceeds the maximum commercial pipe dimension available in the PIPE data bank from Crane [1]. According to this databank, the maximum commercial diameter is 36" (894.1mm or 35.2in).

$$\frac{1.471 \times 10^3}{25.4} = 57.913 \quad \text{inch}$$

$$35.2 \cdot 25.4 = 894.08 \quad \text{mm}$$

$$\text{velocity} := \frac{Q_{\text{hotwater}}}{\left[\frac{\pi \cdot (641.4 \cdot 10^{-3})^2}{4} \right] \cdot 3600}$$

$$\text{velocity} = 4.737 \quad \text{m/s}$$

$$4.737 \cdot 0.3048 = 1.332 \quad \text{ft/s}$$

Rule of thumb: for water (pump discharge line - long line), velocity ranging from 4-7 ft/s (1.22 - 2.13 m/s). Let's calculate the diameter for 7 ft/s (2.134m/s).

$$\text{velocity} := 2.134 \quad \text{m/s}$$

$$D := 1000 \sqrt{\frac{4 \cdot \text{waterflowrate}}{\pi \cdot \rho_{\text{hotwater}} \cdot \text{velocity}}} \quad D = 955.571 \quad \text{mm} \quad \frac{955}{25.4} = 37.598 \quad \text{inch}$$

This diameter is also higher than the maximum available in Crane [1] databank.
Let's use the maximum diameter, i.e., 36" (914.4mm).

Rule of thumb. Ref: Chemical Process Equipment, Schedule number = 1000 * PSIG / St

Psig is the internal pressure, in psig, St is the allowable working stress ~10000 psig for A120 carbon steel at 500F (932 C)

Psig := 7.14.7 Psig = 102.9 psig Considering the pressure in the pipeline ~8 bara

St := 10000 psig

$$\text{Schedulenumber} := \frac{1000 \text{Psig}}{\text{St}} \qquad \text{Schedulenumber} = 10.29$$

The chosen commercial external diameter is: 914.4 mm (36 in), Schedule 10, with internal diameter of 898.6 mm (35.376 in), wall thickness 7.92 mm (0.312 in)

Estimating the piping diameter for cold tap water:

Wmflowrate := 5.32×10^6 kg/h Water mass flow rate

$\rho_{\text{coldwaterin}}$:= 977.84 kg/m³ Density of water at 70 C = 977.8 kg/m³

$$70 \cdot 1.8 + 32 = 158 \qquad 60.99 \frac{0.454}{0.3048^3} = 977.844$$

$\rho_{\text{coldwaterout}}$:= 981.2 kg/m³ Density of water at 68 C = 981.2 kg/m³

$$68 \cdot 1.8 + 32 = 154.4 \qquad 61.2 \frac{0.454}{0.3048^3} = 981.211$$

Data gathered from Crane:

$$\rho_{\text{coldwater}} := \frac{\rho_{\text{coldwaterin}} + \rho_{\text{coldwaterout}}}{2} \qquad \rho_{\text{coldwater}} = 979.522 \quad \text{kg/m}^3$$

$$Q_{\text{coldwater}} := \frac{W_{\text{mflowrate}}}{\rho_{\text{coldwater}}} \qquad Q_{\text{coldwater}} = 5.431 \times 10^3 \quad \text{m}^3/\text{h}$$

$$\text{waterflowrate} := W_{\text{mflowrate}} \cdot \frac{1}{3600} \qquad \text{waterflowrate} = 1.478 \times 10^3 \quad \text{kg/s}$$

$$d := 260 (\text{waterflowrate})^{0.52} \cdot \rho_{\text{coldwater}}^{-0.3} \qquad d = 1.465 \times 10^3 \quad \text{mm}$$

The first estimation for internal diameter of the cold tap water header is 1465 mm (57.7 inch). This diameter exceeds the maximum commercial pipe dimension available in the PIPE data bank from Crane [1]. According to this databank, the maximum commercial diameter is 36" (894.1mm or 35.2in).

$$\frac{1465}{25.4} = 57.677 \quad \text{inch}$$

$$35.2 \cdot 25.4 = 894.08 \quad \text{mm}$$

$$\text{velocity} := \frac{Q_{\text{coldwater}}}{\frac{\pi \cdot (894.08 \cdot 10^{-3})^2}{4} \cdot 3600}$$

$$\text{velocity} = 2.403 \quad \text{m/s}$$

$$4.6690 \cdot 3048 = 1.423 \quad \text{ft/s}$$

Rule of thumb: for water (pump discharge line - long line), velocity ranging from 4-7 ft/s (1.22 - 2.13 m/s). Let's calculate the diameter for 7 ft/s (2.134m/s).

$$\text{velocity} := 2.134 \quad \text{m/s}$$

$$D := 1000 \sqrt{\frac{4 \cdot \text{waterflowrate}}{\pi \cdot \rho_{\text{coldwater}} \cdot \text{velocity}}}$$

$$D = 948.758 \quad \text{mm}$$

$$\frac{948.758}{25.4} = 37.353 \quad \text{inch}$$

This diameter is also higher than the maximum available in Crane [1] databank. Let's use the maximum diameter, i.e., 36" (914.4mm).

Rule of thumb. Ref : Chemical Process Equipment, Schedule number = 1000 * PSIG / St

Psig is the internal pressure, in psig, St is the allowable working stress ~10000 psig for A120 carbon steel at 500F (932 C)

$$\text{Psig} := 7 \cdot 14.7 \quad \text{Psig} = 102.9 \quad \text{psig} \quad \text{Considering the pressure in the pipeline } \sim 8 \text{ bara}$$

$$\text{St} := 10000 \quad \text{psig}$$

$$\text{Schedulenum} := \frac{1000 \text{Psig}}{\text{St}}$$

$$\text{Schedulenum} = 10.29$$

The chosen commercial external diameter is: 914.4 mm (36 in), Schedule 10, with internal diameter of 898.6 mm (35.376 in), wall thickness 7.92 mm (0.312 in)

Appendix 7 Estimation of The Enthalpy and Entropy of The Hot Tap Water at 137 °C and 13 bar

Ref: Program termoprop1 from Sandler
<http://www.che.udel.edu/thermo>

The program was adapted with respect to the input data entry method, which here uses a matrix other than a data file as in the original program.

THERMODYNAMIC PROPERTIES CALCULATION USING THE PENG-ROBINSON EQUATION OF STATE FOR A GIVEN T AND P

Property Data given in the matrix M.
 Tc (in K), Pc (in bar), omega, Tb
 Cp1, Cp2, Cp3, Cp4
 Tref (in K), Pref (in bar), Tref, Pref

The matrix should be as follows
 (last entry is not used, but must be there)
 (In eqn $Cp=Cp0+Cp1*T+Cp2*T^2+Cp3*T^4$)
 (reference conditions, last two entries are there because MATHCAD requires all matrix elements to be filled.)

$$M := \begin{pmatrix} 647.3 & 220.5 & 0.344 & 373.2 \\ 32.24 & 0.001924 & 1.055 \cdot 10^{-5} & -3.596 \cdot 10^{-9} \\ 298.15 & 1 & 298.15 & 1 \end{pmatrix}$$

$$i := 0..3 \quad j := 0..3$$

$$\begin{aligned} Tc &:= M_{0,0} & Pc &:= M_{0,1} & om &:= M_{0,2} \\ Cp_i &:= M_{1,i} & Trs &:= M_{2,0} & Prs &:= M_{2,1} \end{aligned}$$

$$kap := 0.37464 + 1.54226om - 0.26992om^2$$

Peng-Robinson Constants: $R := 0.0000831$ $b := 0.07780 \frac{R \cdot Tc}{Pc}$ $ac := 0.45724 \frac{R^2 \cdot Tc^2}{Pc}$

Note that these are being defined as a function of temperature since we will need to iterate on temperature.

$$alf(T) := 1 \cdot \left[1 + kap \cdot \left(1 - \sqrt{\frac{T}{Tc}} \right) \right]^2 \quad a(T) := ac \cdot alf(T)$$

$$CA(T,P) := \frac{a(T) \cdot P}{(R \cdot T)^2}$$

$$CB(T,P) := \frac{P \cdot b}{R \cdot T}$$

$$Da(T) := \frac{d}{dT} a(T)$$

$Z(T, P) :=$

$$\begin{cases} A \leftarrow CA(T, P) \\ B \leftarrow CB(T, P) \\ V \leftarrow \begin{bmatrix} -(A \cdot B - B^2 - B^3) \\ A - 3 \cdot B^2 - 2 \cdot B \\ -(1 - B) \\ 1 \end{bmatrix} \\ ZZ \leftarrow \text{polyroots}(V) \\ \text{for } i \in 0..2 \\ \quad (ZZ_i \leftarrow 0) \text{ if } (\text{Im}(ZZ_i) \neq 0) \\ ZZ \leftarrow \text{sort}(ZZ) \\ ZZ_0 \leftarrow ZZ_2 \text{ if } (|ZZ_0| < 10^{-5}) \\ ZZ_2 \leftarrow ZZ_0 \text{ if } (|ZZ_2| < 10^{-5}) \\ ZZ \end{cases}$$

Subroutine for solving the cubic equation of state.

Vector of coefficients in the PR equation in the form
 $0 = -(A \cdot B - B^2 - B^3) + (A - 3 \cdot B^2 - 2 \cdot B) \cdot Z - (1 - B) \cdot Z^2 + Z^3$

Solution to the cubic

Set any imaginary roots to zero
Sort the roots

Set the value of any imaginary roots to value of the real root

Enter temperature T, and pressure P for thermodynamic properties calculation.

T := 137 C

T := 273.15 + T K P := 13 bar

Fugacity expressions [actually $\ln(f/P)$] for the liquid fl and vapor fv

$$fl(T, P) := (Z(T, P)_0 - 1) - \ln(Z(T, P)_0 - CB(T, P)) - \frac{CA(T, P)}{2 \cdot \sqrt{2} \cdot CB(T, P)} \cdot \ln \left[\frac{Z(T, P)_0 + (1 + \sqrt{2}) \cdot CB(T, P)}{Z(T, P)_0 + (1 - \sqrt{2}) \cdot CB(T, P)} \right]$$

$$fv(T, P) := (Z(T, P)_2 - 1) - \ln(Z(T, P)_2 - CB(T, P)) - \frac{CA(T, P)}{2 \cdot \sqrt{2} \cdot CB(T, P)} \cdot \ln \left[\frac{Z(T, P)_2 + (1 + \sqrt{2}) \cdot CB(T, P)}{Z(T, P)_2 + (1 - \sqrt{2}) \cdot CB(T, P)} \right]$$

Fugacity		Fugacity coefficient	
$fugl := P \cdot \exp(fl(T, P))$	$fugl = 3.18716$	$fl(T, P) = -1.40582$	$phil := \frac{fugl}{P} \quad phil = 0.24517$
$fugv := P \cdot \exp(fv(T, P))$	$fugv = 11.88924$	$fv(T, P) = -0.08932$	$phiv := \frac{fugv}{P} \quad phiv = 0.91456$

Residual entropy for liquid (DELSL) and vapor (DELSV) phases

$$\text{DELSL} := \left[R \cdot \ln(Z(T, P)_0 - \text{CB}(T, P)) + \frac{\text{Da}(T)}{2 \cdot \sqrt{2} \cdot b} \cdot \ln \left[\frac{Z(T, P)_0 + (1 + \sqrt{2}) \cdot \text{CB}(T, P)}{Z(T, P)_0 + (1 - \sqrt{2}) \cdot \text{CB}(T, P)} \right] \right] \cdot 10^5$$

$$\text{DELSV} := \left[R \cdot \ln(Z(T, P)_2 - \text{CB}(T, P)) + \frac{\text{Da}(T)}{2 \cdot \sqrt{2} \cdot b} \cdot \ln \left[\frac{Z(T, P)_2 + (1 + \sqrt{2}) \cdot \text{CB}(T, P)}{Z(T, P)_2 + (1 - \sqrt{2}) \cdot \text{CB}(T, P)} \right] \right] \cdot 10^5$$

Residual enthalpy for liquid (DELHL) and vapor (DELHV) phases

$$\text{DELHL} := \left[R \cdot T \cdot (Z(T, P)_0 - 1) + \frac{T \cdot \text{Da}(T) - a(T)}{2 \cdot \sqrt{2} \cdot b} \cdot \ln \left[\frac{Z(T, P)_0 + (1 + \sqrt{2}) \cdot \text{CB}(T, P)}{Z(T, P)_0 + (1 - \sqrt{2}) \cdot \text{CB}(T, P)} \right] \right] \cdot 10^5$$

$$\text{DELHV} := \left[R \cdot T \cdot (Z(T, P)_2 - 1) + \frac{T \cdot \text{Da}(T) - a(T)}{2 \cdot \sqrt{2} \cdot b} \cdot \ln \left[\frac{Z(T, P)_2 + (1 + \sqrt{2}) \cdot \text{CB}(T, P)}{Z(T, P)_2 + (1 - \sqrt{2}) \cdot \text{CB}(T, P)} \right] \right] \cdot 10^5$$

Ideal gas property changes relative to the reference state

$$\text{DELHIG} := C_{p0} \cdot (T - \text{Trs}) + \frac{C_{p1} \cdot (T^2 - \text{Trs}^2)}{2} + \frac{C_{p2} \cdot (T^3 - \text{Trs}^3)}{3} + \frac{C_{p3} \cdot (T^4 - \text{Trs}^4)}{4}$$

$$\text{DELSIG} := C_{p0} \cdot \ln \left(\frac{T}{\text{Trs}} \right) + C_{p1} \cdot (T - \text{Trs}) + \frac{C_{p2} \cdot (T^2 - \text{Trs}^2)}{2} + \frac{C_{p3} \cdot (T^3 - \text{Trs}^3)}{3} - R \cdot 10^5 \cdot \ln \left(\frac{P}{\text{Prs}} \right)$$

Total entropy and enthalpy relative to ideal gas reference state

$$\text{SL} := \text{DELSIG} + \text{DELSI} \quad \text{SV} := \text{DELSIG} + \text{DELSV} \quad \text{HL} := \text{DELHIG} + \text{DELHI}$$

$$\text{HV} := \text{DELHIG} + \text{DELHV}$$

SUMMARY OF RESULTS

T = 410.15 K Pressure, bar P = 13

	LIQUID	VAPOR
Compressibility	$Z(T,P)_0 = 8.90988 \times 10^{-3}$	$Z(T,P)_2 = 0.90689$
Enthalpy, J/mol	$HL = -3.64797 \times 10^4$	$HV = 2.94801 \times 10^3$
Entropy, J/mol K	$SL = -97.02364$	$SV = -11.83908$
Fugacity coefficient	$phil = 0.24517$	$phiv = 0.91456$
Fugacity, bar	$fugl = 3.18716$	$fugv = 11.88924$

Note: If the chosen temperature and pressure are near the saturation conditions, results for both the vapor and liquid phases will be reported. The phase with the lower fugacity, and therefore lower Gibbs free energy, is the equilibrium phase. If the temperature and pressure are far away from the saturation conditions, the properties only the equilibrium state are reported for both both phases.

Appendix 8 Tera Joules Calculation

1. Calculating the TJ for the waste water (291800 kg/h) stream at 27.5 C.

Using a correlation CP(T) for water

Constants for water liquid

Ref : Smith & van Ness, 4th edition,
Page 114, Table 4.3, Heat capacity of liquids
(Validity: T from 273.15 to 373.15 K)
T in K

$$CP_{Awliq} := 8.712 \quad CP_{Bwliq} := 1.25 \cdot 10^{-3} \quad CP_{Cwliq} := -0.18 \cdot 10^{-6}$$

$$R := 8.314 \quad J/(mol.K)$$

$$CP_w(T) := R \cdot \frac{1000}{18} \cdot (CP_{Awliq} + CP_{Bwliq} \cdot T + CP_{Cwliq} \cdot T^2) \quad J/(kg.K)$$

Waste water stream at 27.5 C (range: 25-30C, 27.5C was taken as the value for calculations)

$$\text{Wastewater} := 291800 \quad \text{kg/h} \quad \text{Value provided by the Principal}$$

The reference temperature was taken as 0 C (273 K)

$$T_{\text{wastewaterin}} := 27.5 + 273 \quad T_{\text{wastewaterin}} = 300.5 \quad K$$

$$T_{\text{reference}} := 273 \quad T_{\text{reference}} = 273 \quad K$$

$$T_{\text{wastewaterout}} := 18 + 273 \quad T_{\text{wastewaterout}} = 291 \quad K$$

Evaluating Cp water within the range: 25 - 0 C

$$cp_{\text{wastewater}} := \frac{\int_{T_{\text{reference}}}^{T_{\text{wastewaterin}}} CP_w(T) dT}{T_{\text{wastewaterin}} - T_{\text{reference}}}$$

$$cp_{\text{wastewater}} = 4.183 \times 10^3 \quad J/(kg.K)$$

$$TJ_{\text{wastewater}} := \text{Wastewater} \cdot cp_{\text{wastewater}} \cdot (T_{\text{wastewaterin}} - T_{\text{wastewaterout}}) \cdot 365 \cdot 24 \cdot 10^{-12}$$

TJ_{wastewater} = 101.571 TJ/year


This is the heat content of the waste water stream at 27.5 C, considering 0 C as the reference temperature

2. Estimation of the temperature of the returning tap water from the Districts:

Assumptions :

1. 10% energy losses in the pipeline from the Upgrading Unit to the district (typical value of energy losses in similar systems).
2. 20°C temperature approach between IN and OUT tap water stream in the district

10% energy losses represents 2°C difference, which added to the desired temperature, 90°C, yields to 92°C for the tap water outlet stream from the Upgrading Unit. Following the same reasoning, the tap water returning temperature will be 68°C.



$$TJ_{CG} := 780 \quad TJ$$

$$\Delta T_{UU} := 92 - 68 \quad \Delta T_{UU} = 24 \quad ^\circ C$$

$$\Delta T_{CG} := 90 - 70 \quad \Delta T_{CG} = 20 \quad ^\circ C$$

Considering the proportionality between the temperature differences and the amount of energy at the Upgrading Unit and at the Central Grid, the TJ/annum to be delivered at the Upgrading Unit can be estimated as follows:

$$\frac{TJ_{CentralGrid}}{TJ_{UpgradingUnit}} = \frac{\Delta T_{CentralGrid}}{\Delta T_{UpgradingUnit}}$$

$$T_{JU} := T_{JCG} \frac{\Delta T_{UU}}{\Delta T_{CG}}$$

$$T_{JU} = 936 \quad T_J$$

3. Calculating the clean water (hot tap water) flow rate in order to achieve 936 TJ/annum considering that the clean water will reach the battery limit (Central Grid) at 90 C in order to compensate any heat losses in the pipeline. The temperature of the cold tap water that reaches the Upgrading Unit is 68 C.

$$T_{Jproduct} := 936 \quad T_{J/year}$$

$$T_{productout} := 92 + 273 \quad T_{productout} = 365 \quad K$$

$$T_{reference} := 273 \quad T_{reference} = 273 \quad K$$

$$T_{productin} := 68 + 273 \quad T_{productin} = 341 \quad K$$

$$c_{product} := \frac{\int_{T_{productin}}^{T_{productout}} CP_w(T) dT}{T_{productout} - T_{productin}}$$

$$c_{product} = 4.217 \times 10^3 \quad J/(kg.K)$$

$$Product := \frac{T_{Jproduct}}{c_{product} \cdot (T_{productout} - T_{productin}) \cdot 365 \cdot 24 \cdot 10^{-12}}$$

$$Product = 1.056 \times 10^6 \quad kg/h$$


This is the flow rate of hot tap water (936TJ/annum, at 92 C), which is going to be sent through pipelines to the District Buildings.

4. Estimation of the temperature of the returning tap water from the Districts:

Assumptions :

1. 10% energy losses in the pipeline from the Upgrading Unit to the district (typical value of energy losses in similar systems).
2. 20°C temperature approach between IN and OUT tap water stream in the district

10% energy losses represents 2°C difference, which added to the desired temperature, 90°C, yields to 92°C for the tap water outlet stream from the Upgrading Unit. Following the same reasoning, the tap water returning temperature will be 68°C.



$$TJCG := 780 \quad TJ$$

$$\Delta TUU := 133 - 67 \quad \Delta TUU = 66 \quad ^\circ C$$

$$\Delta TCG := 130 - 70 \quad \Delta TCG = 60 \quad ^\circ C$$

Considering the proportionality between the temperature differences and the amount of energy at the Upgrading Unit and at the Heat Stations, the TJ/annum to be delivered at the Upgrading Unit can be estimated as follows:

$$\frac{TJ_{CentralGrid}}{TJ_{UpgradingUnit}} = \frac{\Delta T_{CentralGrid}}{\Delta T_{UpgradingUnit}}$$

$$TJ_{UU} := TJ_{CG} \frac{\Delta T_{UU}}{\Delta T_{CG}}$$

$$TJ_{UU} = 858 \quad TJ$$

5. Estimating the clean water (hot tap water) flow rate in order to achieve 858 TJ/annum considering that the clean water will reach the battery limit (Heat Stations) at 130 C in order to compensate any heat losses in the pipeline. The temperature of the cold tap water that reaches the Upgrading Unit is 67 C.

$$TJ_{product} := 858 \quad TJ/year$$

$$T_{productout} := 133 + 273 \quad T_{productout} = 406 \quad K$$

$$T_{productin} := 67 + 273 \quad T_{productin} = 340 \quad K$$

Since the equation $C_p(T)$ is not valid for temperature above 100C, the specific heat of water at 133 was taken from the book Transport Phenomena Data Companion, L.P.B.M. Janssen, M.M.C.G. Warmoeskerken.

$$c_{pproductout} := 4236 \quad J/(kg.K) \quad \text{Cp water at 133C}$$

$$c_{pproductin} := CP_w(67 + 273)$$

$$c_{pproductin} = 4.211 \times 10^3 \quad J/(kg.K) \quad \text{Cp water at 67C calculated with the correlation}$$

$$c_{pproduct} := \frac{c_{pproductout} + c_{pproductin}}{2}$$

$$c_{pproduct} = 4.223 \times 10^3 \quad J/(kg.K)$$


$$Product := \frac{TJ_{product}}{c_{pproduct} \cdot (T_{productout} - T_{productin}) \cdot 365 \cdot 24 \cdot 10^{-12}}$$

$$Product = 3.514 \times 10^5 \quad kg/h$$

This is the flow rate of hot tap water (858TJ/annum, at 133 C), which is going to be sent through pipelines to the District Buildings.

6. Estimation of the temperature of the returning tap water from the Districts taking into consideration the heat losses

After calculating the heat losses in the pipelines, an approximate temperature profile was obtained and the hot tap water outlet temperature in the Upgrading Unit was iteratively adjusted and a final value of 137 C was achieved. The same procedure was applied to the cold tap water inlet temperature at the Upgrading Unit. Therefore, the tap water temperatures to be used to calculate the required TJ in the Upgrading Unit, are: Tout=137 C, Tin=67 C. The TJ at UU=923 TJ



$$TJ_{CG} := 780 \quad TJ$$

$$\Delta T_{UU} := 137 - 67 \quad \Delta T_{UU} = 70 \quad ^\circ C$$

$$\Delta T_{CG} := 130 - 70 \quad \Delta T_{CG} = 60 \quad ^\circ C$$

Considering the proportionality between the temperature differences and the amount of energy at the Upgrading Unit and at the Heat Stations, the TJ/annum to be delivered at the Upgrading Unit can be estimated as follows:

$$\frac{TJ_{CentralGrid}}{TJ_{UpgradingUnit}} = \frac{\Delta T_{CentralGrid}}{\Delta T_{UpgradingUnit}}$$

$$T_{JU} := T_{JCG} \frac{\Delta T_{UU}}{\Delta T_{CG}}$$

$$T_{JU} = 923 \quad T_J \quad \frac{923}{365} \cdot \frac{1}{24} \cdot \frac{1}{3600} \cdot 10^{12} = 2.927 \times 10^7 \quad \text{Watt}$$

This is the energy content of the hot tap water that exits the Upgrading Unit

7. Estimating the hot tap water flow rate in order to achieve 923 TJ/annum considering that the clean water will reach the battery limit (Heat Station) at 130 C in order to compensate any heat losses in the pipeline. The temperature of the cold tap water that reaches the Upgrading Unit is 67 C.

$$T_{J\text{product}} := 923 \quad T_{J/\text{year}}$$

$$T_{\text{productout}} := 137 + 273 \quad T_{\text{productout}} = 410 \quad K$$

$$T_{\text{productin}} := 66 + 273 \quad T_{\text{productin}} = 339 \quad K$$

Since the equation $C_p(T)$ is not valid for temperature above 100C, the specific heat of water at 133 was taken from the book Transport Phenomena Data Companion, L.P.B.M. Janssen, M.M.C.G. Warmoeskerken.

$$c_{p\text{productout}} := 4236 \quad J/(kg.K) \quad C_p \text{ water at } 133C$$

$$c_{p\text{productin}} := C_{pw}(67 + 273)$$

$$c_{p\text{productin}} = 4.211 \times 10^3 \quad J/(kg.K) \quad C_p \text{ water at } 67C \text{ calculated with the correlation}$$

$$c_{p\text{product}} := \frac{c_{p\text{productout}} + c_{p\text{productin}}}{2}$$

$$c_{p\text{product}} = 4.223 \times 10^3 \quad J/(kg.K)$$

$$\text{Product} := \frac{T_{J\text{product}}}{c_{p\text{product}} \cdot (T_{\text{productout}} - T_{\text{productin}}) \cdot 365 \cdot 24 \cdot 10^{-12}}$$

$$\text{Product} = 3.514 \times 10^5 \quad \text{kg/h}$$

This is the flow rate of hot tap water (923TJ/annum, at 137 C), which is going to be sent through pipelines to the District Buildings.

Appendix 9 Overall Heat Transfer Coefficient

Reference : R.K. Sinnott, *Coulson & Richardson's Chemical Engineering*, Volume 6. Butterworth Heinemann, Great Britain, 2003




Figure 12.1. Overall coefficients (join process side duty to service side duty to service side and read U from centre scale)

Appendix 10 Estimation of The Natural Gas and Air Consumption in The Fired Heater

The fired heater is the heat load necessary to increase the temperature of the tap water from 60 C to 97 C.

$$Q_{duty} := 9.355 \times 10^7 \cdot 1.15 \quad \text{BTU/h}$$

$$P_{furnace} := 1.3 \quad \text{bar} \quad \text{Considering Furnace within the range 1.0-1.6 bar (~1.3 bar)}$$

Heatvalue := 1000 BTU/ft³ at 60F (15.5C), 14.7 psia (1.013 bar), this serves as initial input further calculations. The natural gas flowrate will be actually calculated via Aspen Simulation and will change if any heat integration is considered.

$$v_{NG} := \frac{Q_{duty}}{\text{Heatvalue}} \quad v_{NG} = 1.076 \times 10^5 \quad \text{ft}^3/\text{h} \quad \text{Volumetric flow rate of NG at 60F, 14.7 psia}$$

North Sea (Netherlands- Groningen)
non-associated natural gas composition:

Components	Concentration (% vol.)
Methane	81.3
Ethane	2.9
Propane	0.4
N-butane	0.1
C5 ⁺	0.1
Nitrogen	14.3
Carbon Dioxide	0.9

Ref: Chemical Process Technology, Moulijn et al. Wiley & Sons, 2001

which refers to the following literature sources:

1. Our Industry: Petroleum (1977), 5th ed., London, The British Petroleum Company
2. WoodCock KE, Gottlieb M (1994) 'Natural Gas' in Kroschwitz JI and Howegrant M (eds.) Kirk Othmer Encyclopedia of Chemical Technology vol.12, 4th ed., Wiley, New York, pp 318-340.

Via Aspen simulation based on the composition above the average molecular weight, density, the total mole flow rate and the mole flow rates for each component were calculated. The Aspen reference file is: CP.apw

The results are presented below:

Density at 60F(15.5C) and 14.7 psia (1.013bar) = 0.00078820 g/cm³

MW = 18.623 kg/kmol

Total NG mass flow rate = 2343.48 kg/h (125.8379 kmol/h). It was calculated with Aspen (RSTOIC) in order to satisfy the conditions imposed by the fired heater and air demand. Considering the over design of 15% in order to use this fired heater as the backup system, the final values to be used for the design are: NG = 2695.00 kg/h (144.829 kmol/h). The amounts of each combustible components in NG are the following:

nCH ₄ := 117.64	kmol/h	nC ₂ H ₆ := 4.197	kmol/h
nC ₃ H ₈ := 0.5784	kmol/h	nC ₄ H ₁₀ := 0.149	kmol/h
nC ₅ H ₁₂ := 0.149	kmol/h	Considering C ₅ ⁺ as N-pentane	
nN ₂ := 20.69	kmol/h	nCO ₂ := 1.3023	kmol/h

Estimating the air flow rate:

The air flow rate is calculated considering 20% excess air for the combustion being added to the stoichiometric air flow:

Air stoichiometric:

O ₂ methane := 2 · nCH ₄	O ₂ methane = 235.29	kmol/h
O ₂ ethane := 3.5 · nC ₂ H ₆	O ₂ ethane = 14.691	kmol/h
O ₂ propane := 5 · nC ₃ H ₈	O ₂ propane = 2.892	kmol/h
O ₂ butane := 6.5 · nC ₄ H ₁₀	O ₂ butane = 0.972	kmol/h
O ₂ pentane := 8 · nC ₅ H ₁₂	O ₂ pentane = 1.196	kmol/h

TotalO₂stoich := O₂methane + O₂ethane + O₂propane + O₂butane + O₂pentane

TotalO₂stoich = 255.041 kmol/h

The actual flow rate of oxygen to be fed into the furnace is:

O ₂ actual := 1.2 · TotalO ₂ stoich	O ₂ actual = 306.049	kmol/h
---	---------------------------------	--------

Taking into account that O₂ molar concentration in air is 21%, yields:

$$\text{Airmoleflowrate} := \frac{\text{O}_2\text{actual}}{0.21} \qquad \text{Airmoleflowrate} = 1.457 \times 10^3 \text{ kmol/h}$$

With the estimated air flow rate required for the combustion, the final blower capacity was calculated by Aspen.

The blower BHP is calculated:

$$\text{BlowerBHP} := 602.037 \frac{0.0018182}{1.356 \times 10^{-3}} \qquad \text{BlowerBHP} = 807.245 \text{ HP}$$

Also via Aspen CP.apw , Toulet blower = 50 C

This capacity takes into consideration the fact that this blower can be also used to supply the heating demand as back up system.

Appendix 11 Process Flow Scheme

The Process Flow Scheme for this project design are shown in the A3 format as can be seen in the following A3 paper.

Appendix 12 Process Streams Summary

STREAM Nr. :	1		2		3		4		5	
Name :	WW IN		WW OUT		COMP1 IN		COMP1 OUT		COMP2 IN	
COMP MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia 17.03	0	0	0	0	3.89	0.23	3.89	0.23	3.89	0.23
Water 18.02	81.06	4.50	81.06	4.50	0	0	0	0	0	0
Total	81.06	4.50	81.06	4.50	3.89	0.23	3.89	0.23	3.89	0.23
Enthalpy kW	-1293746.38		-1297281.97		-10711.64		-10063.36		-10266.24	
Phase	L		L		V		V		V	
Press. Bara	3.00		2.50		6.50		15.00		14.70	
Temp. °C	27.50		18.00		12.00		93.25		70.85	

STREAM Nr. :	6		7		8		9		10	
Name :	COMP2 OUT		ACOND OUT		EVAP IN		UU IN		WCOOLER IN	
COMP MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia 17.03	3.89	0.23	3.89	0.23	3.89	0.23	0	0	0	0
Water 18.02	0	0	0	0	0	0	97.39	5.41	2.00	0.11
Total	3.89	0.23	3.89	0.23	3.89	0.23	97.39	5.41	2.00	0.11
Enthalpy kW	-9414.74		-14220.52		-14220.52		-1537130.33		-31566.49	
Phase	V		L		L+V		L		L	
Press. Bara	38.00		37.90		6.60		9.00		9.00	
Temp. °C	179.32		75.60		12.00		66.50		66.50	

STREAM Nr. :	11		12		13		14		15	
Name :	WCOND IN		WCOOLER OUT		WCOND OUT		FURNACE IN		FURNACE OUT	
COMP MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia 17.03	0	0	0	0	0	0	0	0	0	0
Water 18.02	95.39	5.30	2.00	0.11	95.39	5.30	97.39	5.41	97.39	5.41
Total	95.39	5.30	2.00	0.11	95.39	5.30	97.39	5.41	97.39	5.41
Enthalpy kW	-1505563.84		-31363.67		-1500759.33		-1532123.02		-1505416.93	
Phase	L		L		L		L		L	
Press. Bara	9.00		8.50		8.50		8.00		6.20	
Temp. °C	66.50		88.78		77.59		77.83		137.15	

STREAM Nr. :	16		17		18		19	
Name :	NGSTD		AIR IN		AIR OUT		EMISSIONS	
COMP MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	0	0	0	0	0	0	0	0
Water	0	0	0	0	0	0	1.15	0.06
Methane	0.50	0.03	0	0	0	0	0	0
Ethane	0.03	1.06e-3	0	0	0	0	0	0
Propane	6.46e-3	1.46e-4	0	0	0	0	0	0
n-Butane	2.12e-3	3.66e-5	0	0	0	0	0	0
n-Pentane	2.64e-3	3.66e-5	0	0	0	0	0	0
Oxygen	0	0	2.41	0.08	2.41	0.08	0.36	0.01
Nitrogen	0.15	5.23e-3	7.94	0.28	7.94	0.28	8.09	0.29
Dioxide carbon	0.01	3.30e-4	0	0	0	0	1.45	0.03
Total	0.71	0.04	10.35	0.36	10.35	0.36	11.05	0.39
Enthalpy kW	-2577.23		-55.31		275.37		-29021.06	
Phase	V		V		V		V	
Press. Bara	1.00		1.00		1.3		1.3	
Temp. °C	15.56		20.00		51.59		79.85	

STREAM Nr. :	20	21	22	23	24
Name :	UU OUT	TO ST. I	FROM ST. I	TO DIS. I	FROM DIS. I
COMP MW	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s
Ammonia 17.03	0 0	0 0	0 0	0 0	0 0
Water 18.02	97.39 5.41	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63
Total	97.39 5.41	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63
Enthalpy kW	-1505356.65	-300288	-305651	-737887	-743126
Phase	L	L	L	L	L
Press. Bara	10.00	10.00	9.50	1.00	1.00
Temp. °C	137.22	133.79	68.48	91.42	65.00

STREAM Nr. :	25	26	27	28	29
Name :	TO ST. IV	FROM ST. IV	TO DIS. IV	FROM DIS. IV	TO CG II
COMP MW	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s
Ammonia 17.03	0 0	0 0	0 0	0 0	0 0
Water 18.02	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63	58.47 3.25
Total	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63	58.47 3.25
Enthalpy kW	-300553	-305774	-738409	-743126	-901012
Phase	L	L	L	L	L
Press. Bara	10.00	9.50	1.00	1.00	9.85
Temp. °C	130.60	66.97	88.80	65.00	133.20

STREAM Nr. :	30	31	32	33	34
Name :	FROM CG II	TO ST. II	FROM ST. II	TO DIS. II	FROM DIS. II
COMP MW	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s
Ammonia 17.03	0 0	0 0	0 0	0 0	0 0
Water 18.02	58.47 3.25	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63
Total	58.47 3.25	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63
Enthalpy kW	-917639	-300812	-305781	-738350	-743126
Phase	L	L	L	L	L
Press. Bara	9.10	9.80	9.30	1.00	1.00
Temp. °C	65.68	128.20	67.64	89.09	65.00

STREAM Nr. :	35	36	37	38	39
Name :	TO ST. V	FROM ST. V	TO DIS. V	FROM DIS. V	TO ST. III
COMP MW	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s
Ammonia 17.03	0 0	0 0	0 0	0 0	0 0
Water 18.02	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63	19.49 1.08
Total	19.49 1.08	19.49 1.08	47.34 2.63	47.34 2.63	19.49 1.08
Enthalpy kW	-300747	-305700	-738376	-743126	-300780
Phase	L	L	L	L	L
Press. Bara	9.80	9.30	1.00	1.00	9.80
Temp. °C	127.90	67.50	88.96	65.00	127.5

STREAM Nr. :	40	41	42
Name :	FROM ST. III	TO DIS. III	FROM DIS. III
COMP MW	kg/s kmol/s	kg/s kmol/s	kg/s kmol/s
Ammonia 17.03	0 0	0 0	0 0
Water 18.02	19.49 1.08	47.34 2.63	47.34 2.63
Total	19.49 1.08	47.34 2.63	47.34 2.63
Enthalpy kW	-305716	-738409	-743126
Phase	L	L	L
Press. Bara	9.30	1.00	1.00
Temp. °C	67.31	88.80	65.00

Overall Component Mass Balance & Stream Heat Balance

STREAM Nr. :		1 IN		2 OUT		OUT-IN	
Name :		WW IN		WW OUT			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	81.06	4.50	81.06	4.50		
Total		81.06	4.50	81.06	4.50		
Press.	Bara	3.00		2.50			
Temp.	°C	27.50		18.00			
Enthalpy	kW	-1293746		-1297282		-3535	

STREAM Nr. :		16 IN		17 IN		19 OUT		OUT-IN	
Name :		NGSTD		AIR IN		EMISSIONS			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia		0	0	0	0	0	0		
Water		0	0	0	0	1.15	0.06		
Methane		0.50	0.03	0	0	0	0		
Ethane		0.03	1.06e-3	0	0	0	0		
Propane		6.46e-3	1.46e-4	0	0	0	0		
n-Butane		2.12e-3	3.66e-5	0	0	0	0		
n-Pentane		2.64e-3	3.66e-5	0	0	0	0		
Oxygen		0	0	2.41	0.08	0.36	0.01		
Nitrogen		0.15	5.23e-3	7.94	0.28	8.09	0.29		
Dioxide carbon		0.01	3.30e-4	0	0	1.45	0.03		
Total		0.71	0.04	10.35	0.36	11.05	0.39		
Press.	Bara	1.00		1.00		1.3			
Temp.	°C	15.56		20.00		79.85			
Enthalpy	kW	-2577		-55		-29021		-26388	

STREAM Nr. :		24 IN		23 OUT		OUT-IN	
Name :		FROM DIS.I		TO DIS. I			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	47.34	2.63	47.34	2.63		
Total		47.34	2.63	47.34	2.63		
Press.	Bara	1.00		1.00			
Temp.	°C	65.00		91.42			
Enthalpy	kW	-743126		-737887		5239	

STREAM Nr. :		34 IN		33 OUT		OUT-IN	
Name :		FROM DIS.II		TO DIS. II			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	47.34	2.63	47.34	2.63		
Total		47.34	2.63	47.34	2.63		
Press.	Bara	1.00		1.00			
Temp.	°C	65.00		89.09			
Enthalpy	kW	-743126		-738350		4776	

STREAM Nr. :		42 IN		41 OUT		OUT-IN	
Name :		FROM DIS. III		TO DIS. III			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	47.34	2.63	47.34	2.63		
Total		47.34	2.63	47.34	2.63		
Press.	Bara	1.00		1.00			
Temp.	°C	65.00		88.80			
Enthalpy	kW	-743126		-738409		4717	

STREAM Nr. :		28 IN		27 OUT		OUT-IN	
Name :		FROM DIS.IV		TO DIS. IV			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	47.34	2.63	47.34	2.63		
Total		47.34	2.63	47.34	2.63		
Press.	Bara	1.00		1.00			
Temp.	°C	65.00		88.80			
Enthalpy	kW	-743126		-738409		4717	

STREAM Nr. :		38 IN		37 OUT		OUT-IN	
Name :		FROM DIS.V		TO DIS. V			
COMP	MW	kg/s	kmol/s	kg/s	kmol/s	kg/s	kmol/s
Ammonia	17.03	0	0	0	0		
Water	18.02	47.34	2.63	47.34	2.63		
Total		47.34	2.63	47.34	2.63		
Press.	Bara	1.00		1.00			
Temp.	°C	65.00		88.96			
Enthalpy	kW	-743126		-738376		4750	

Appendix 13 Equipment Summary & Specification Sheets

In this appendix, the summary of all of the equipment and its specification sheets are made available.

REACTORS, COLUMNS & VESSELS – SUMMARY

EQUIPMENT NR. :	V-01				
NAME :	Ammonia Collector Vessel				
	Vertical				
Pressure [bara] :	37.5				
Temp. [°C] :	75.60				
Volume [m³] :	1.60				
Diameter [m] :	0.93				
L or H [m] :	2.32				
Internals					
- Tray Type :	n.a.				
- Tray Number :	n.a.				
- Fixed Packing					
Type :	n.a.				
Shape :	n.a.				
- Catalyst					
Type :	n.a.				
Shape :	n.a.				
Number					
- Series :	1				
- Parallel :	-				
Materials of Construction (1) :	CS				
Other :					
Remarks: (1) CS : Carbon Steel.					

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : **CPD-3328**
Date : December 13st 2005

HEAT EXCHANGERS & FURNACES – SUMMARY

EQUIPMENT NR. NAME :	E-01 Ammonia Evaporator	E-02 Ammonia Condenser	E-03 Intercooler	E-04 Heat Exchanger District 1	E-05 Heat Exchanger District 2
Type :	Kettle Vaporizer	Kettle Vaporizer	Floating Head	Floating Head	Floating Head
Substance					
- Tubes :	Water	Water	Water	Water	Water
- Shell :	Ammonia	Ammonia	Ammonia	Water	Water
Duty [kW] :	3,535	4,804	203	23,277	23,277
Heat Exchange area [m ²] :	737	232	292	1,557	1,557
Number					
- Series :	1	1	1	1	1
- Parallel :	-	-	-	-	-
Pressure [bara]					
- Tubes :	3.00	9.00	9.00	4.00	4.00
- Shell :	6.60	38.00	15.00	12.80	12.60
Temperature In / Out [°C]					
- Tubes :	27.50 / 17.87	66.50 / 77.59	66.50 / 88.78	65.00 / 91.42	65.00 / 90.09
- Shell :	12.35 / 12.35	179.32 / 75.60	93.25 / 70.85	133.79 / 70.00	133.60 / 70.00
Special Materials of Construction (1) :	Tubes : CS Shell : CS	Tubes : CS Shell : CS	Tubes : CS Shell : CS	Tubes : CS Shell : CS	Tubes : CS Shell : CS
Other :	-	-	-	-	-
Remarks: (1) CS = Carbon Steel.					

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : CPD-3328
Date : December 13st 2005

HEAT EXCHANGERS & FURNACES – SUMMARY

EQUIPMENT NR. NAME :	E-06 Heat Exchanger District 3	E-07 Heat Exchanger District 4	E-08 Heat Exchanger District 5	F-01 Natural Gas Furnace	
Type :	Floating Head	Floating Head	Floating Head	Fired Heater	
Substance					
- Tubes :	Water	Water	Water	Water	
- Shell :	Water	Water	Water	na	
Duty [kW] :	23,285	23,277	23,279	136,899 (1)	
Heat Exchange area [m ²] :	1,557	1,557	1,557	- (2)	
Number					
- Series :	1	1	1	1	
- Parallel :	-	-	-	-	
Pressure [bara]					
- Tubes :	4.00	4.00	4.00	8.00	
- Shell :	9.82	9.77	9.80	1.30	
Temperature In / Out [°C]					
- Tubes :	65.00 / 89.09	65.00 / 88.79	65.00 / 88.98	77.83 / 137.15	
- Shell :	128.20 / 70.00	127.50 / 70.00	127.90 / 70.00	526.85 / 79.85	
Special Materials of Construction (3) :	Tubes : CS Shell : CS	Tubes : CS Shell : CS	Tubes : CS Shell : CS	Tubes : CS Shell : na	
Other :	-	-	-	-	
Remarks: (1) This value is obtained based on the peak demand. (2) To be specified in detailed design. (3) CS = Carbon Steel.					

 Designers : P.W. Falcao A. Mesbah
 M.V. Suherman S. Wennekes

 Project ID-Number : CPD-3328
 Date : December 13st 2005

PUMPS, BLOWERS & COMPRESSORS – SUMMARY

EQUIPMENT NR. :	K-01	K-02	K-03	P-01 A/B	
NAME :	Low Pressure Compressor	High Pressure Compressor	Air Blower	Hot Water Pump	
Type :	Reciprocating	Reciprocating	Centrifugal	Centrifugal	
Number :	1	1	1	2	
Medium Transferred :	Ammonia	Ammonia	Air	Water	
Capacity					
[kg/s] :	3.89	3.89	57.04	438.25	
[m ³ /s] :	0.78 (1)	0.41 (1)	48.16 (1)	0.50	
Density [kg/m ³] :	4.99 (1)	9.43 (1)	1.18 (1)	878	
Pressure [bara]					
Suct. / Disch. :	6.50 / 15.00	14.50 / 38.00	Atm. / 1.30	4.00 / 13.00	
Temperature					
In / Out[°C] :	11.91 / 93.25	70.85 / 179.32	20.00 / 50.33	136.76 / 136.90	
Power [kW]					
- Theor. :	621	852	1822	485	
- Actual :	690	946	2025 (3)	539	
Number					
- Theor. :					
- Actual :	1	1	1	2 (1)	
Special Materials of Construction :	Carbon Steel	Carbon Steel	Cast Iron	Cast Iron	
Other :	-	-	-	Shaft: HT Steel	
Remarks:					
(1) Calculated at inlet condition.					
(2) One installed spare included.					
(3) This value is obtained based on the peak demand.					
(4) HT = High Tensile.					

Designers :	P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes	Project ID-Number :	CPD-3328
		Date :	December 13 st 2005

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-01		In Series : 1	
NAME : Ammonia Evaporator		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser (Air cooled)	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity [kW]	:	3,535 (1)	(Calc.)
Heat Exchange Area [m ²]	:	737 (1),(2)	(Calc.)
Overall Heat Transfer Coefficient [W/m ² ·°C]	:	550	(Approx.)
Log. Mean Temperature Diff. (LMTD) [°C]	:	9.7	
Passes Tube Side	:	- (3)	
Passes Shell Side	:	- (3)	
Correction Factor LMTD (min. 0.75)	:	0.9	
Corrected LMTD [°C]	:	8.7 (1)	(Calc.)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Ammonia	Water
Mass Stream [kg/s]	:	3.89	81.06
Mass Stream to	:		
- Evaporize [kg/s]	:	2.84	-
- Condense [kg/s]	:		
Average Specific Heat [kJ/kg·°C]	:	-	4.18
Heat of Evap. / Condensation [kJ/kg]	:	380	-
Temperature IN [°C]	:	12.35	27.50
Temperature OUT [°C]	:	12.35	17.87
Pressure [bara]	:	6.60	3.00
Material (4)	:	CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=1 1/4".			
(3) To be specified in the detailed design.			
(4) CS=Carbon Steel.			

Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes	Project ID-Number : CPD-3328 Date : December 13 st 2005
---	---

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-02		In Series : 1	
NAME : Ammonia Condenser		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 4,804	(1) (Calc.)
Heat Exchange Area	[m ²]	: 232	(1),(2) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 600	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 38.37	
Passes Tube Side		: -	(3)
Passes Shell Side		: -	(3)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 34.53	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Ammonia	Water
Mass Stream	[kg/s]	3.89	95.39
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]	3.89	-
Average Specific Heat	[kJ/kg.°C]	-	4.18
Heat of Evap. / Condensation	[kJ/kg]	550	-
Temperature IN	[°C]	179.32	66.50
Temperature OUT	[°C]	75.60	77.59
Pressure	[bara]	38.00	9.00
Material (4)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(3) To be specified in the detailed design.			
(4) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wenkes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-03		In Series : 1	
NAME : Intercooler		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 203	(1) (Calc.)
Heat Exchange Area	[m ²]	: 292	(1),(2) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 175	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 4.41	
Passes Tube Side		: -	(3)
Passes Shell Side		: -	(3)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 3.97	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Ammonia	Water
Mass Stream	[kg/s]	3.89	2.00
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	2.40 (4)	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	93.25	66.50
Temperature OUT	[°C]	70.85	88.78
Pressure	[bara]	15.00	9.00
Material (5)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(3) To be specified in the detailed design.			
(4) The value estimated by Aspen Plus.			
(5) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-04		In Series : 1	
NAME : Heat Exchanger District 1		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 23,277	(1),(2) (Calc.)
Heat Exchange Area	[m ²]	: 1,557	(1),(2),(3) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 1000	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 14.95	
Passes Tube Side		: -	(4)
Passes Shell Side		: -	(4)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 13.45	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Water	Water
Mass Stream	[kg/s]	19.48	47.33
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	4.18	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	133.79	65.00
Temperature OUT	[°C]	70.00	91.42
Pressure	[bara]	12.80	4.00 (5)
Material (6)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) This value is obtained for the peak demand.			
(3) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(4) To be specified in the detailed design.			
(5) It is assumed that the tap water is delivered at this pressure.			
(6) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-05		In Series : 1	
NAME : Heat Exchanger District 2		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 23,277	(1),(2) (Calc.)
Heat Exchange Area	[m ²]	: 1,557	(1),(2),(3) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 1000	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 16.97	
Passes Tube Side	:	-	(4)
Passes Shell Side	:	-	(4)
Correction Factor LMTD (min. 0.75)	:	0.9	
Corrected LMTD	[°C]	: 15.27	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Water	Water
Mass Stream	[kg/s]	19.48	47.33
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	4.18	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	133.60	65.00
Temperature OUT	[°C]	70.00	90.09
Pressure	[bara]	12.60	4.00 (5)
Material (6)	:	CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) This value is obtained for the peak demand.			
(3) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(4) To be specified in the detailed design.			
(5) It is assumed that the tap water is delivered at this pressure.			
(6) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-06		In Series : 1	
NAME : Heat Exchanger District 3		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 23,285	(1),(2) (Calc.)
Heat Exchange Area	[m ²]	: 1,557	(1),(2),(3) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 1000	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 16.58	
Passes Tube Side		: -	(4)
Passes Shell Side		: -	(4)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 14.92	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Water	Water
Mass Stream	[kg/s]	19.48	47.33
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	4.18	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	128.20	65.00
Temperature OUT	[°C]	70.00	89.09
Pressure	[bara]	9.82	4.00 (5)
Material (6)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) This value is obtained for the peak demand.			
(3) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(4) To be specified in the detailed design.			
(5) It is assumed that the tap water is delivered at this pressure.			
(6) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-07		In Series : 1	
NAME : Heat Exchanger District 4		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 23,277	(1),(2) (Calc.)
Heat Exchange Area	[m ²]	: 1,557	(1),(2),(3) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 1000	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 14.95	
Passes Tube Side		: -	(4)
Passes Shell Side		: -	(4)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 13.45	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Water	Water
Mass Stream	[kg/s]	19.48	47.33
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	4.18	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	127.50	65.00
Temperature OUT	[°C]	70.00	88.79
Pressure	[bara]	9.77	4.00 (5)
Material (6)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) This value is obtained for the peak demand.			
(3) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(4) To be specified in the detailed design.			
(5) It is assumed that the tap water is delivered at this pressure.			
(6) CS = Carbon Steel.			
Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes		Project ID-Number : CPD-3328 Date : December 13 st 2005	

HEAT EXCHANGER – SPECIFICATION SHEET

EQUIPMENT NUMBER : E-08		In Series : 1	
NAME : Heat Exchanger District 5		In Parallel : none	
General Data			
Service	:	- Heat Exchanger - Cooler - Condenser	- Vaporizer - Reboiler
Type	:	- Fixed Tube Sheets - Floating Head - Hair Pin - Double Tube	- Plate Heat Exchanger - Finned Tubes - Thermosyphon - Kettle Vaporizer
Position	:	- Horizontal - Vertical	
Capacity	[kW]	: 23,279	(1),(2) (Calc.)
Heat Exchange Area	[m ²]	: 1,557	(1),(2),(3) (Calc.)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: 1000	(Approx.)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 16.54	
Passes Tube Side		: -	(4)
Passes Shell Side		: -	(4)
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 14.89	(1)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Water	Water
Mass Stream	[kg/s]	19.48	47.33
Mass Stream to			
- Evaporize	[kg/s]		
- Condense	[kg/s]		
Average Specific Heat	[kJ/kg.°C]	4.18	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	127.90	65.00
Temperature OUT	[°C]	70.00	88.96
Pressure	[bara]	9.80	4.00 (5)
Material (6)		CS	CS
Remarks:			
(1) Calculation is done by Aspen Plus Simulation.			
(2) This value is obtained for the peak demand.			
(3) Tubes: L = 12 ft; OD = 1" on Square Pitch; Tube Pitch=11/4".			
(4) To be specified in the detailed design.			
(5) It is assumed that the tap water is delivered at this pressure.			
(6) CS = Carbon Steel.			

Designers : P.W. Falcao A. Mesbah M.V. Suherman S. Wennekes	Project ID-Number : CPD-3328 Date : December 13 st 2005
---	---

FURNACE – SPECIFICATION SHEET

EQUIPMENT NUMBER : F-01		In Series : 1	
NAME : Natural Gas Furnace		In Parallel : none	
General Data			
Service : Burning Natural Gas		(1)	
Type : Fired Heater			
Capacity	[kW]	: 136899	(2),(3) (Calc.)
Heat Exchange Area	[m ²]	: -	(4)
Overall Heat Transfer Coefficient	[W/m ² .°C]	: -	(4)
Log. Mean Temperature Diff. (LMTD)	[°C]	: 80.77	
Passes Tube Side		: -	(4)
Passes Shell Side		: na	
Correction Factor LMTD (min. 0.75)		: 0.9	
Corrected LMTD	[°C]	: 72.69	(2)
Process Conditions			
		Shell Side	Tube Side
Medium	:	Flue Gas	Water
Mass Stream	[kg/s]	11.06	97.39
Mass Stream to			
- Evaporize	[kg/s]	:	:
- Condense	[kg/s]	:	:
Average Specific Heat	[kJ/kg.°C]	1.23 (2),(5)	4.18
Heat of Evap. / Condensation	[kJ/kg]	-	-
Temperature IN	[°C]	526.85 (6)	77.83
Temperature OUT	[°C]	79.85	137.15
Pressure	[bara]	1.30 (7)	8.00
Material (8),(9)		CS	CS
Remarks:			
(1) Natural gas composition (mole percent): C ₁ =81.3, C ₂ =2.9, C ₃ =0.4, C ₄ =0.1, C ₅ =0.1, CO ₂ =0.9, N ₂ =14.3; temperature: 60 °F, pressure: 14.7 psia.			
(2) Calculation is done by Aspen Plus Simulation.			
(3) This value is obtained based on the peak demand.			
(4) To be specified in the detailed design.			
(5) Calculated at outlet condition.			
(6) Flue gas temperature.			
(7) Flue gas pressure.			
(8) CS = Carbon Steel.			
(9) Insulation should be provided.			

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : **CPD-3328**
Date : December 13st 2005

RECIPROCATING COMPRESSOR –SPECIFICATION SHEET

EQUIPMENT NUMBER : K-01	In Series : 1
NAME : Low Pressure Compressor	In Parallel : none
Service : Compress Ammonia	
Type : Reciprocating	
Operating Conditions & Physical Data	
Compressor Model	: Isentropic
Compressed Gas	: Ammonia
Cp/Cv at inlet condition	: 1.39
Cp/Cv at outlet condition	: 1.38
Density at inlet condition [kg/m ³]	: 4.99
Density at outlet condition [kg/m ³]	: 9.03
Power	
Suction Capacity [m ³ /s]	: 0.78
Discharge Capacity [m ³ /s]	: 0.43
Suction Pressure [bara]	: 6.50
Discharge Pressure [bara]	: 15.00
Suction Temperature [°C]	: 11.91
Discharge Temperature [°C]	: 93.25
Isentropic Temperature [°C]	: 76.61
Isentropic Efficiency [-]	: 0.75
Mechanical Efficiency [-]	: 0.90
Power [kW]	: 690 (1)
Construction Details (2),(3),(4)	
Drive	: Electrical
Material	: CS (5)
Remarks:	
(1) Calculation is done by Aspen Plus simulation.	
(2) Further details are provided by the manufacturer.	
(3) The maximum allowable noise level is 50 db.	
(4) A knockout drum should be provided with the compressor.	
(5) CS: Carbon Steel.	

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : CPD-3328
Date : December 13st 2005

RECIPROCATING COMPRESSOR –SPECIFICATION SHEET

EQUIPMENT NUMBER : K-02	In Series : 1
NAME : High Pressure Compressor	In Parallel : none
Service : Compress Ammonia	
Type : Reciprocating	
Operating Conditions & Physical Data	
Compressor Model	: Isentropic
Compressed Gas	: Ammonia
Cp/Cv at inlet condition	: 1.40
Cp/Cv at outlet condition	: 1.39
Density at inlet condition [kg/m ³]	: 9.43
Density at outlet condition [kg/m ³]	: 18.96
Power	
Suction Capacity [m ³ /s]	: 0.41
Discharge Capacity [m ³ /s]	: 0.21
Suction Pressure [bara]	: 14.50
Discharge Pressure [bara]	: 38.00
Suction Temperature [°C]	: 70.85
Discharge Temperature [°C]	: 179.32
Isentropic Temperature [°C]	: 159.03
Isentropic Efficiency [-]	: 0.75
Mechanical Efficiency [-]	: 0.90
Power [kW]	: 946 (1)
Construction Details (2),(3),(4)	
Drive	: Electrical
Material	: CS (5)
Remarks:	
(1) Calculation is done by Aspen Plus simulation.	
(2) Further details are provided by the manufacturer.	
(3) The maximum allowable noise level is 50 db.	
(4) A knockout drum should be provided with the compressor.	
(5) CS: Carbon Steel.	

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : CPD-3328
Date : December 13st 2005

CENTRIFUGAL BLOWER – SPECIFICATION SHEET

EQUIPMENT NUMBER : K-03	In Series : 1
NAME : Air Blower	In Parallel : none
Service : Blow Air to the Furnace	
Type : Centrifugal	
Operating Conditions & Physical Data	
Compressor Model	: Isentropic
Compressed Gas	: Air
Cp/Cv at inlet condition	: 1.41
Cp/Cv at outlet condition	: 1.41
Density at inlet condition [kg/m ³]	: 1.18
Density at outlet condition [kg/m ³]	: 1.39
Power	
Suction Capacity [m ³ /s]	: 48.16
Discharge Capacity [m ³ /s]	: 40.88
Suction Pressure [bara]	: Atm
Discharge Pressure [bara]	: 1.30
Suction Temperature [°C]	: 20.00
Discharge Temperature [°C]	: 50.33
Isentropic Temperature [°C]	: 42.77
Isentropic Efficiency [-]	: 0.75
Mechanical Efficiency [-]	: 0.90
Power [kW]	: 1944 (1),(2)
Construction Details (3),(4)	
Drive	: Electrical
Material	: Cast Iron
Remarks:	
(1) Calculation is done by Aspen Plus simulation.	
(2) This value is obtained based on the peak demand.	
(3) Further details are provided by the manufacturer.	
(4) The maximum allowable noise level is 50 db.	

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : **CPD-3328**
Date : December 13st 2005

CENTRIFUGAL PUMP – SPECIFICATION SHEET

EQUIPMENT NUMBER : P-01	A/B	Operating : 1
NAME : Hot Water Pump		Installed Spare : 1
Service : Water Pump		
Type : 1 Stage Radial Centrifugal Pump (HSC)		
Number : 2		
Operating Conditions & Physical Data		
Pumped liquid	: Water	
Temperature (T) [°C]	: 137.0	
Density (ρ) [kg/m ³]	: 878	
Viscosity (η) [N·s/m ²]	: 0.0002	
Vapour Pressure (p_v) [bara]	: 3.3	
	at Temperature [°C]	: 137.0
Power		
Capacity (Φ_v) [m ³ /s]	: 0.50	
Suction Pressure (p_s) [bara]	: 4.0 (1)	
Discharge Pressure (p_d) [bara]	: 13.0 (1)	
Brake Power [kW]	: 453 (1),(2)	
Pump Efficiency [-]	: 0.7	
Power at Shaft [kW]	: 503 (1),(2)	
Construction Details (3),(4)		
RPM	: 3600	
Drive	: Electrical	
Type electrical motor	: Totally Enclosed, Fan-Cooled Enclosure	
Tension [V]	: -	
Rotational direction	: Clock / Counter Cl.	
Foundation Plate	: Combined / two parts	
Flexible Coupling	: Yes	
Pressure Gauge Suction	: No	
Pressure Gauge Discharge	: Yes	
N.P.S.H. [m]	: 31.9 (1), (2)	
Construction Materials		
Pump House	: Cast Iron	
Pump Rotor (5)	: HT Steel	
Shaft (5)	: HT Steel	
Special provisions	: none	
Operating Pressure [bara]	: 13.0	
Remarks:		
(1) This value is obtained based on the peak demand.		
(2) Calculation is done by Aspen Plus Simulation		
(3) Further details to be specified by Rotating Equipment specialist.		
(4) The maximum allowable noise level is 50 db.		
(5) HT Steel: High Tensile Steel		

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wenekes

Project ID-Number : **CPD-3328**
Date : December 13st 2005

VESSEL – SPECIFICATION SHEET

EQUIPMENT NUMBER : V-01		In Series : 1	
NAME : Ammonia Collector Vessel		In Parallel : none	
General Data			
Service		: Ammonia Collector	
Type		: - Buffer - Separation - Storage - Reaction	
Position		: - Horizontal - Vertical	
Internals		: - Demister / Plate / Coil	
Heating/Cooling medium		: - none / Open / Closed / External Hxgr	
- Type		: n.a.	
- Quantity		[kg/s] : n.a.	
- Press./Temp.'s		[bara/°C] : n.a.	
Vessel Diameter (ID)		[m] : 0.93	
Vessel Height		[m] : 2.32	
Vessel Tot. Volume		[m ³] : 1.60	
Vessel Material		: CS (1)	
Other		: -	
Process Conditions			
Stream Data		Feed	Bottom
Temperature	[°C] :	75.60	-
Pressure	[bara] :	37.50	-
Density	[kg/m ³] :	513.40	-
Mass Flow	[kg/s] :	3.89	-
Remarks:			
(1) CS: Carbon Steel.			

Designers : P.W. Falcao A. Mesbah
M.V. Suherman S. Wennekes

Project ID-Number : CPD-3328
Date : December 13st 2005

Appendix 14 Demand Fluctuations

A maximum annual demand of 780 TJ at the districts was assumed. This demand is not constant and obviously depends very much on the season and the time of the day. Thus, there are big fluctuations in both monthly and hourly demand and they should be taken into consideration. Our design was made for the average heat consumption, i.e. assuming a constant heat demand (approximately 371 m³/h of hot tap water or 0.09 TJ/h) and adjusting the design afterwards with the over-design factor to correct for monthly and hourly peaks.

Monthly fluctuations

Figure 1 shows the monthly consumption of hot tap water and central heating and was used as basis.




Figure 1. Monthly consumption for hot tap water and central heating, adopted from: http://www.bertie.joan.freeler.nl/totaaloverzichten_MHWC.htm#MHWCsmall




Figure 2. Monthly consumption for hot tap water and central heating

The data for the year 2004 in Figure 2 were used to calculate the ratios (month usage/year usage) and to estimate how the usage of 780 TJ would be distributed over the year based on similar ratios. The results are shown in Table 1.

Table 1. Monthly hot water consumption, hot tap water and central heating, derived from 2

2004-2005	Fraction of 780TJ/annum	Average	TJ/month	Over design
Oct	0.03	0.08	25	0.4
Nov	0.10	0.08	77	1.2
Dec	0.25	0.08	198	3.0
Jan	0.18	0.08	137	2.1
Feb	0.16	0.08	123	1.9
Mar	0.12	0.08	94	1.5
Apr	0.04	0.08	28	0.4
May	0.03	0.08	25	0.4
Jun	0.02	0.08	16	0.2
Jul	0.02	0.08	13	0.2
Aug	0.03	0.08	24	0.4
Sep	0.03	0.08	21	0.3
Total	1	1	780TJ/annum	

The figures in Table 1 show that a design for a constant energy demand will certainly not fulfill the requirements. The furnace should be over-designed for a factor of 3 in comparison with the average usage (0.08 TJ/month) to overcome the monthly fluctuations in heat usage by the district.

Hourly fluctuations

As it was mentioned before there are not only monthly fluctuations, but also hourly fluctuations during the day in the heat demand by the district. People will use less heat during night and more during daylight and evening, with maximum peaks during rush hours.

In order to fulfill this peak demands, there should be another over design, to compensate for the hourly fluctuations and peaks. To deal with these fluctuations one has to know something about the daily characteristics of the heat demand in heating districts.

Figure 3 shows the mean monthly and peak load fluctuation and was used as basis.




Figure 3. Mean monthly and peak load fluctuations, adopted from: http://www.opetchp.net/download/wp7/WP7_presentation_paper_CERTH_%20ISFTA.pdf




Figure 4. A Daily demand distribution

Figure 4 was used to define the ratios for the hourly energy demand in the district. The biggest peak in the graph deviates from the daily average with a factor of 1.48.

Two options were considered to overcome the hourly fluctuations:

Option 1.

The first option to overcome these fluctuations was by means of a big buffer tank. The volume of this buffer tank should be big enough to store the energy amount of the usage above the average demand, which is approximately the accumulation from 07:00 till 22:00 o'clock.

According to figures presented in Table 2, two buffer tanks with capacity of 3.57 hours are needed. It means a volume of 3.57 times the hourly average flow rate of a certain day a year. In the worst case, the monthly demand is the highest. Therefore, it is 3 times as much the average monthly demand, and this all leads to a total volume of approximately 4200 m³. Designing a tank for 4200 m³ and assuming H/D ratio of 2.5 yields a tank with a height of 32 m and a diameter of 13 meter. The use of two buffer tanks will also provide the system with flexibility, especially in case of maintenance. The maximum time available for maintenance (tank volume over the lowest flow rate) is approximately 50 hours. Appendix 3 shows the tank dimension calculations, as well as its cost estimation.

Table 2. Hourly over-design factors, derived from Figure 4

Hour	Factor of over design	Difference from average (relative)	Buffer utilization (hr)
1	0.44	-0.56	
2	0.44	-0.56	
3	0.44	-0.56	
4	0.44	-0.56	
5	0.52	-0.48	
6	0.89	-0.11	
7	1.18	0.18	0.18
8	1.40	0.40	0.40
9	1.48	0.48	0.48
10	1.33	0.33	0.33
11	1.21	0.21	0.21
12	1.15	0.15	0.15
13	1.06	0.06	0.06
14	1.09	0.09	0.09
15	1.12	0.12	0.12
16	1.05	0.05	0.05
17	1.05	0.05	0.05
18	1.18	0.18	0.18
19	1.33	0.33	0.33
20	1.43	0.43	0.43
21	1.39	0.39	0.39
22	1.11	0.11	0.11
23	0.81	-0.19	
24	0.44	-0.56	3.57

Option 2.

Another option and probably a better way to overcome the above average usage is to increase the capacity of the fired heater again, but now with respect to the hourly fluctuations. The hourly peaks are not that big relatively to the average usage; only a maximum factor of 1.48. Therefore, the fired heater capacity should in this case be increased in order to overcome both monthly and daily fluctuations. This is the best option due to the fact that the tanks will be big like shown before. This is a problem because in this area space is not infinitely available, and so making it an expensive solution.

One big fired heater should be used, with an over capacity with a factor of 5, to compensate monthly fluctuations, hourly fluctuations and serve as a back-up system for the ammonia loop. If the demand of the district is lower than the capacity of the MHP, the unloading/loading capacity of the compressors will lower the ammonia flow in the MHP and shut down the fired heater.

The disadvantage of this option is the presence of a fired heater that is not efficiently used; that is, only 20% of its capacity is utilized over the year. The idleness of the furnace is higher during the summer time, when only approximately 5% of the capacity is used. That is why the majority of DHS's in Europe are combined with a power station, the so called combined heat and power.


Results of Fluctuations and Operability

Since the average heating demand is approximately 9 times as much as the average energy input from DSM waste heat stream and the peak demand is approximately 25 times as much of this value, it is impossible to avoid the usage of a gas-fired heater to overcome this situation.

Given the required plant capacity and the results of the evaluation of the demand fluctuations and studies on heat losses in the pipelines, the outputs of our design were mostly established. As a result of heat losses calculations in the pipeline network, the Upgrading Unit has to be designed for 922 TJ/annum in order to compensate the heat losses on the network.

Appendix 16 District Piping System Block Scheme

Insulation Material : PUR
Thickness : 50 mm



Appendix 17 Hazard and Operability Study

Apparatus No. :-			
Intention of apparatus: -			
Line No. 6	Intention of line: transfer ammonia from the discharge of 2 nd compressor to the condenser		
Guide Word	Deviation or disturbance	Possible Causes	Consequences
Not, No	FLOW	1) Failure in the compressor	1) The whole loop is down
More	FLOW	2) Not applicable	None
	PRESSURE	3) Plugging in the condenser 4) Block valve closed in the condenser while the compressor is running	2) Piping failure 3) The whole cycle gets affected
	TEMPERATURE	5) High pressure in the suction and discharge of the compressor 6) High suction temperature	4) Maximum allowable temperature of the 2 nd compressor can be achieved
Less	FLOW	7) Compressor failure	5) Less heat delivered
	PRESSURE	8) Compressor failure	6) Less heat delivered
	TEMPERATURE	9) Low suction temperature 10) Compressor failure	7) Less heat transferred in the condenser
			1) Maintenance
			2) Maintenance
			3) Maintenance
			4) Maintenance
			5) Maintenance
			6) Maintenance

Apparatus No. :-			
Intention of apparatus: -			
Line No. 3	Intention of line: transfer ammonia from the evaporator to compressor1		
Guide Word	Deviation or disturbance	Possible Causes	Consequences
Not, No	FLOW	1) Plugging in the condenser or in the pipe 2) Pipe fracture 3) Control valve failure	1) The cycle does not work 2) None
More	FLOW PRESSURE	4) Not applicable 5) Compressor suction valve fails closed while the compressor is running	3) High pressure in the whole cycle 4) None 5) Maintenance
Less	TEMPERATURE FLOW	6) High heat transfer rate in the evaporator 7) Plugging in the evaporator or in the pipe 8) Control valve failure	4) High temperature at the compressor discharge 5) No big deal
	PRESSURE	9) Expansion valve failure 10) Expansion valve failure 11) Waste water control valve fails closed	6) Process Control of waste water -by pass 7) Compressor control loops adjustment
	TEMPERATURE		8) Proper Maintenance in the control valve 9) Proper Maintenance in the control valves

Intention of apparatus:			
Apparatus No. :-	Intention of line: transfer ammonia from the 1 st compressor to the intercooler	Possible causes	Action required
Line No. 4	Deviation or disturbance	Consequences	
Not, No	FLOW	1) Failure in the compressor valves	1) Maintenance
More	FLOW	2) Not applicable	2) None
	PRESSURE	3) Plugging in downstream 4) Block valve closed while compressor is running	3) Maintenance
	TEMPERATURE	5) High pressure in the suction and discharge of the compressor 6) High suction temperature	4) Maintenance
Less	FLOW	7) Not applicable	5) None
	PRESSURE	8) Compressor failure	6) Maintenance
	TEMPERATURE	9) Low suction temperature 10) Compressor failure	7) Maintenance

Apparatus No. :-				Intention of apparatus :-			
Line No. 5				Intention of line: Feed ammonia into compressor 2			
Guide Word	Deviation or disturbance	Possible Causes	Consequences	Action Required			
Not, No	FLOW	1) Pipe fracture 2) 1st compressor failure	1) The cycle does not work 2) Compressor 2 runs empty	1) Shutdown the compressor			
More	FLOW	3) Not applicable	3) None	2) None			
	PRESSURE	4) Compressor suction valve fails closed while the compressor is running	4) High pressure in the whole cycle	3) Maintenance			
	TEMPERATURE	5) Intercooler does not work properly	5) High temperature at the compressor discharge	4) Process Control of tap cold water			
Less	FLOW	6) Low flow down upstream	6) No big deal	5) Compressor control loops adjustment			
	PRESSURE	7) Compressor 1 failure	7) Low heat transfer in the condenser	6) Proper Maintenance in the compressor			
	TEMPERATURE	7) Failure in the control system failure	8) Low heat transfer in the condenser	7) Maintenance in the control loop of the intercooler			

Apparatus No. :-			
Intention of apparatus: -			
Line No. 7	Intention of line: transfer ammonia liquid to the expansion valve		
Guide Word	Deviation or disturbance	Possible causes	Consequences
Not, No	FLOW	1) Compressor failure 2) Block valve fails closed upstream the control valve	1) No ammonia enters the evaporator 2) The whole cycle gets affected
More	FLOW	3) Not applicable	3) None
	PRESSURE	4) Plugging in downstream 5) Block valve downstream the expansion closed while compressor is running	4) High temperature in the evaporator and in the suction of the 1 st compressor
	TEMPERATURE	6) High temperature at compressor	5) Two-phase flow
Less	FLOW	7) Flange leak	Covered by (1), (2)
	PRESSURE	8) Compressor failure	6) Two-phase flow
	TEMPERATURE	9) Insulation failure	7) No major consequences
			1) Maintenance
			2) None
			3) Check lines
			4) Maintenance
			5) Process Control loop at the condenser
			Covered by (1)
			Covered by (1)
			Covered by (1)

Apparatus No. :-		Intention of apparatus: -			
Line No. 8	Intention of line: transfer ammonia from the expansion valve to the evaporator	Deviation or disturbance	Possible Causes	Consequences	Action Required
Not, No	FLOW	1) Plugging in the condenser or in the pipe 2) Pipe fracture 3) Control valve failure	1) The cycle does not work	1) Stop the compressor from running 2) Close the waste water valve 3) Provide a small tank to collect ammonia 4) None	
More	FLOW	4) Not applicable. The compressor delivers a certain amount that is adjusted 5) Control valve failure	2) None		
	PRESSURE	6) Control valve failure	3) Two-phase flow to the compressor	5) Waste water by-pass control loop linked to the control valve	
	TEMPERATURE	7) Plugging in the condenser or in the pipe 8) Control valve failure	4) Two-phase flow to the compressor	Covered by (4)	
Less	FLOW	9) Compressor failure 10) Pipe leak	5) High temperature at compressor suction	6) Maintenance 7) Slow down the compressor	
	PRESSURE	11) Compressor failure 12) Pipe leak	6) Lower suction pressure at the 1 st compressor	8) Maintenance	
	TEMPERATURE		7) Lower suction pressure at the 1 st compressor	9) Maintenance	

Apparatus No. :-				
Intention of apparatus: -				
Line No. 17	Intention of line: transfer air from the blower to the fired heater			
Guide Word	Deviation or disturbance	Possible Causes	Consequences	
			Action Required	
Not, No	FLOW	1) Blower failure	1) No combustion 2) Natural gas sent to the atmosphere 3) Explosion	1) Maintenance 2) Proper ratio air: NG control
More	FLOW	2) Failure in the flow control valves	4) Inefficient combustion 5) Uncontrolled emissions	3) Maintenance
	PRESSURE	3) Not likely to occur	6) None	4) None
	TEMPERATURE	4) Not applicable considering the temperature range of the fired heater	7) None	5) None
Less	FLOW	5) Piping fracture 6) Flange leak	8) Poor combustion	6) Maintenance
	PRESSURE	7) Blower failure	9) Mal function of the burner	7) Maintenance
	TEMPERATURE	8) Insulation failure	10) No hazardous for the process	8) Maintenance

Apparatus No. :-				Intention of apparatus: -			
Line No. 16				Intention of line: transfer natural gas to the fired heater			
Guide Word	Deviation or disturbance	Possible Causes	Consequences	Action Required			
Not, No	FLOW	1) Control valve failure (fails closed)	1) No proper heat released to tap water	1) Maintenance			
More	FLOW	2) Failure with flow control valve	2) No proper heat released to tap water	2) Maintenance			
	PRESSURE	3) Only likely if there is higher pressure in the NG supply	3) Piping failure	3) None			
	TEMPERATURE	4) Not applicable	4) None	4) None			
Less	FLOW	5) Failure with flow control valve	5) No proper heat released to tap water	5) Maintenance			
	PRESSURE	6) Leak in the supply header or in the pipeline	6) Mal function of the burner	6) Maintenance			
	TEMPERATURE	7) Insulation failure	7) Minor hazardous for the process	7) Maintenance			

Apparatus No. :-					
Line No. 21	Intention of line: transfer hot tap water from the Central Grid 1 to the heat station (HEX1)	Deviation or disturbance	Possible causes	Consequences	Action Required
Not, No	FLOW	1) Plugging 2) Piping fracture 3) Pump failure 4) Block valve closed	1) No heat distribution, freezing of the equipment	1) Close the block valve to the district	
More	FLOW	5) Failure in the flow control valves	2) Increasing in the outgoing temperature	2) Proper maintenance	
	PRESSURE	6) Plugging in downstream 7) Block valve closed while pump is running	3) Piping failure 4) Line subjected to full pump delivery or surge pressure	3) Pipe should be designed to maximum value 4) Check lines	
	TEMPERATURE	8) Furnace control system failure (both temperature and flow)	5) Line fracture or flange leak 6) Two-phase flow	5) Install thermo-expansion relief valve Covered by (1), (2), (3) in the UU-IN file	
Less	FLOW	9) Piping fracture 10) Flange leak 11) Pump failure	7) Low heat distribution	6) Maintenance	
	PRESSURE	12) Pump failure	8) Two-phase flow 9) Pump cavitation 10) Less heat transfer (gas-liquid)	7) Proper Maintenance	
	TEMPERATURE	13) Furnace failure 14) Insulation failure	11) Low heat distribution	8) Maintenance	

Apparatus No. : -	Intention of apparatus: -			Action Required
Line No. 22	Intention of line: transfer hot tap water from Heat Station 1 (HEX1) to the Central Grid 1 (CG1)			
Guide Word	Deviation or disturbance	Possible Causes	Consequences	
Not, No	FLOW	1) Plugging 2) Piping fracture 3) Pump failure 4) Block valve closed	1) No heat distribution, freezing of the equipment	1) Close the block valve to the district
More	FLOW	5) Failure in the flow control valves	2) Increasing in the outcoming temperature	2) Proper maintenance
	PRESSURE	6) Plugging in downstream 7) Block valve closed while pump is running	3) Piping failure 4) Line subjected to full pump delivery or surge pressure	3) Pipe should be designed to maximum value 4) Check lines
	TEMPERATURE	8) Furnace control system failure (both temperature and flow) 9) Failure in the heat exchanger control system	5) Line fracture or flange leak 6) Two-phase flow	5) Install thermo-expansion relief valve Covered by (1), (2), (3) in the UU-IN file
Less	FLOW	10) Piping fracture 11) Flange leak 12) Pump failure 13) Scaling in heat exchanger	7) Low heat distribution	6) Maintenance
	PRESSURE	14) Pump failure	8) Two-phase flow 9) Pump cavitation 10) Less heat transfer (gas+liquid) 11) Low heat distribution	7) Maintenance
	TEMPERATURE	15) Furnace failure 16) Insulation failure		8) Maintenance

Apparatus No. :-			
Line No. 10	Intention of apparatus: - Intention of line: transfer cold tap water to the intercooler		
Guide Word	Deviation or disturbance	Possible Causes	Consequences
Not, No	FLOW	1) Control valve failure 2) Failure in the upstream pipeline 3) Block valve closed	1) High temperature in the suction of the 2 nd compressor 2) Maintenance
More	FLOW	4) Failure in the flow control valves	2) No hazardous consequences to the process
	PRESSURE	5) Plugging in downstream 6) Block valve closed while pump is running	3) Piping failure 4) Line subjected to full pump delivery or surge pressure
	TEMPERATURE	7) Furnace control system failure (both temperature and flow) 8) Failure in the heat exchanger control system	5) Line fracture or flange leak 6) Two-phase flow
Less	FLOW	9) Piping fracture 10) Flange leak 11) Scaling in heat exchanger	7) Low heat distribution
	PRESSURE	12) Pump failure	8) Two-phase flow 9) Pump cavitation 10) Less heat transfer (gas-liquid)
	TEMPERATURE	13) Furnace failure 14) Insulation failure	11) Low heat distribution Covered by (6)
			6) Install thermo-expansion relief valve Covered by (1), (2), (3) in the UU-IN file 7) Maintenance Covered by (6)

Apparatus No. : -		Intention of apparatus: -				
Line No.	Guide Word	Intention of line: transfer tap water from the mixer to the furnace	Deviation or disturbance	Possible Causes	Consequences	Action Required
Not, No	FLOW		1) Control valve failure 2) Failure in the upstream pipeline (block valve closed)	1) No heat supplied to the districts	1) Shut down the compressor 2) Maintenance	
More	FLOW PRESSURE		3) Not applicable 4) Plugging in downstream 5) Block valve closed while pump is running	2) Not applicable 3) Piping failure 4) Line subjected to full pump delivery or surge pressure	3) None 4) Maintenance 5) Check lines	
	TEMPERATURE		6) Furnace control system failure (both temperature and flow) 7) Failure in the heat exchanger control system	5) Two-phase flow	6) Install thermo-expansion relief valve Covered by (1), (2), (3) in the UU-IN file	
Less	FLOW		8) Piping fracture 9) Flange leak 10) Scaling in heat exchanger (condenser and intercooler)	5) Low heat distribution to the districts	7) Maintenance	
	PRESSURE		11) Pump failure 12) Flange leak	6) Two-phase flow	Covered by (6)	
	TEMPERATURE		13) Inefficient heat transfer in the condenser 14) Insulation failure	7) Low heat distribution	Covered by (6)	


Apparatus No. : -	Intention of apparatus: -			Action Required
Line No. 29	Intention of line: transfer hot tap water from the Upgrading Unit to the Central Grid 2			
Guide Word	Deviation or disturbance	Possible Causes	Consequences	
Not, No	FLOW	1) Plugging 2) Piping fracture 3) Pump failure	1) No heat distribution, freezing of the equipment 2) Local hot spot in ammonia loop 3) Race in the temperature of the compressor 4) Not Applicable	1) Shut-down the furnace 2) Shut-down the compressor 3) Waste water inlet should bypass the evaporator 4) Not Applicable
More	FLOW	4) Not Applicable (Closed-loop)		
	PRESSURE	5) Plugging in the downstream 6) Block valve closed while pump is running	5) Piping failure 6) Line subjected to full pump delivery or surge pressure	5) Pipe should be designed to maximum value 6) Check lines
	TEMPERATURE	7) Furnace control system failure (both temperature and flow) 8) Failure in the district distribution system	7) Line fracture or flange leak 8) High pressure in transfer line	7) Install thermo-expansion relief valve
Less	FLOW	9) Piping fracture 10) Flange leak 11) Pump failure	9) Low heat distribution	8) Maintenance
	PRESSURE	12) Pump failure	10) Two-phase flow 11) Pump cavitation 12) Less heat transfer (gas-liquid)	9) Proper Maintenance
	TEMPERATURE	13) Furnace failure 14) Insulation failure	13) Low heat distribution	10) Maintenance

Appendix 18 Fire and Explosion Index Calculation

Area/Country: The Netherlands		Division: -	Location -	Date 12/1/2005
Site -	Manufacturing Unit Upgrading Unit of District Heating System (DHS)		Process Unit Heat Upgrading Unit	
Materials in Process Unit Ammonia, Natural Gas, Air and Water				
State of Operation Ammonia Thermal Cycle, Water Fired Heater and Water Pipeline Network			Basic Materials for Material Factor Ammonia	
Material Factor				4.00
1. General Process Hazards			Penalty Factor Range	Penalty Used
Base Factor			1.00	1.00
A. Exothermic Chemical Reactions			0.30 - 1.25	-
B. Endothermic Processes			0.20 - 0.40	-
C. Material Handling and Transfer			0.25 - 1.05	-
D. Enclosed or Indoor Process Units			0.25 - 0.90	0.30
E. Acces			0.20 - 0.35	0.35
F. Drainage and Spill Control			0.25 - 0.50	0.25
General Process Hazards Factor (F1)				1.90
2. Special Process Hazards			Penalty Factor Range	Penalty Used
Base Factor			1.00	1.00
A. Toxic Material(s)			0.20 - 0.80	0.60
B. Sub-Atmospheric Pressure (< 500 mm Hg)			0.50	-
C. Operation In or Near Flammable Range				
1. Tank Farms Storage Flammable Liquids			0.50	-
2. Process Upset or Purge Failure			0.30	0.30
3. Always in Flammable Range			0.80	0.80
D. Dust Explosion			0.25 - 2.00	-
E. Pressure				
Operating Pressure: 3800 kPa				-
Relief Setting: kPa				-
F. Low Temperature			0.20 - 0.30	-
G. Quantity of Flammable Material:				
Hc = 2195 kg				
Hc = 11315.6 kcal/kg				
1. Liquids or Gases in Process				0.16
2. Liquids or Gases in Storage				-
3. Combustible Solids in Storage, Dust in Process				-
H. Corrosion and Erosion			0.10 - 0.75	-
I. Leakage - Joints and Packing			0.10 - 1.50	0.30
J. Use of Fired Equipment				-
K. Hot Oil Heat Exchange System			0.15 - 1.15	-

L. Rotating Equipment	0.50	0.50
Special Process Hazards Factor (F2)		3.66
Process Units Hazards Factor (F1 x F2) = F3		6.95
Fire and Explosion Index (F3 x MF = F&EI)		28

Appendix 19 Heat Losses Calculation (Way In and Return)



WAY IN (hot tap water) at 133C

Nominal diameters: 16" and 14"
Schedule 40 carbon steel pipes

Pipe internal and external diameters for each branch, inches

$$D := \begin{pmatrix} 16 \\ 14 \\ 14 \\ 14 \\ 14 \\ 14 \end{pmatrix}$$

$$\text{din} := \begin{pmatrix} 15 \\ 13.124 \\ 13.124 \\ 13.124 \\ 13.124 \\ 13.124 \end{pmatrix} \quad \text{dext} := \begin{pmatrix} 16 \\ 14 \\ 14 \\ 14 \\ 14 \\ 14 \end{pmatrix}$$

Mass flowrate in each branch, kg/s

$$\text{massflowrate} := \begin{pmatrix} 97.39 \\ 32.47 \\ 32.47 \\ 32.47 \\ 32.47 \\ 32.47 \end{pmatrix} \quad \text{kg/s}$$

The diameters and flow rates in each branch were calculated with Aspen Pipeline model.

Pipe length in each branch, m

$$\text{Length} := \begin{pmatrix} 3000 \\ 900 \\ 1800 \\ 1400 \\ 1600 \\ 1500 \end{pmatrix} \quad \text{m}$$

Calculating the diameters in meter

$$\text{din} := \text{din} \cdot 2.54 \cdot 10^{-2} \quad \text{din} = \begin{pmatrix} 0.381 \\ 0.333 \\ 0.333 \\ 0.333 \\ 0.333 \\ 0.333 \end{pmatrix} \quad \text{m} \quad \text{dext} := \text{dext} \cdot 2.54 \cdot 10^{-2} \quad \text{dext} = \begin{pmatrix} 0.406 \\ 0.356 \\ 0.356 \\ 0.356 \\ 0.356 \\ 0.356 \end{pmatrix} \quad \text{m}$$

Physical Properties of water at bulk temperature, T=133°C:

$$T := 133 \quad \text{C} \quad \text{Bulk temperature}$$

Density

$$\rho := 882.0 \quad \text{kg/m}^3 \quad \text{Source: Aspen}$$

Dynamic viscosity

$$\mu := 0.25 \cdot 10^{-2} \quad \text{g/(cm.s)} \quad \text{Source: Aspen}$$

Thermal conductivity

$$k_w := 0.685 \quad \text{Watt/(m.K)} \quad \text{Source: Aspen}$$

Specific heat

$$c_p := 425 \quad \text{J/(kg.K)} \quad \text{Source: Transport Phenomena Data Companion L.P.B.M. Janssen, M.M.C.G. Warmoeskerken}$$

Dimensionless Numbers (Re, Pr, Nu) were calculated at the bulk temperature, T=133 C

$$\text{Pr} := 1.325 \quad \text{Pr} = 1.325 \quad \text{Prandtl Number at bulk temperature Source: Transport Phenomena Data Companion}$$

Velocity in the pipe, m/s

$$vel := \frac{\overrightarrow{\text{massflowrate}}}{\rho \cdot \pi \cdot \frac{din^2}{4}}$$

$$vel = \begin{pmatrix} 0.968 \\ 0.422 \\ 0.422 \\ 0.422 \\ 0.422 \\ 0.422 \end{pmatrix} \quad \text{m/s}$$

$$Re := \frac{\overrightarrow{din \cdot vel \cdot \rho}}{\mu} \cdot \frac{1000}{100}$$

$$Re = \begin{pmatrix} 1.302 \times 10^6 \\ 4.961 \times 10^5 \\ 4.961 \times 10^5 \\ 4.961 \times 10^5 \\ 4.961 \times 10^5 \\ 4.961 \times 10^5 \end{pmatrix}$$

Since $Re > 10^4$, there is turbulent flow

$$Nu := 0.023 Re^{0.8} \cdot Pr^{0.33}$$

$$Nu = \begin{pmatrix} 1.967 \times 10^3 \\ 908.868 \\ 908.868 \\ 908.868 \\ 908.868 \\ 908.868 \end{pmatrix}$$

Nusselt Number for forced convection

Reference :

Coulson and Rihardson s, Chemical Engineering, Flow, Heat Transfer and Mass Transfer, 6th edition

$x := 0.05 \quad \text{m}$ Insulation thickness was taken as 5 cm

Convective heat transfer coefficient

$$h := \left(\frac{\text{kW}}{\text{dext}} \cdot Nu \right)$$

$$h = \begin{pmatrix} 3.318 \times 10^3 \\ 1.752 \times 10^3 \\ 1.752 \times 10^3 \\ 1.752 \times 10^3 \\ 1.752 \times 10^3 \\ 1.752 \times 10^3 \end{pmatrix} \quad \text{Watt/(m}^2\cdot\text{K)}$$

Insulation thermal conductivity For Micro-PUR packed with cyclopentane gas,
 $K=0.031 \text{ Watt/(m.K)}$
 $k_i := 0.031 \quad \text{Watt/(m.K)}$ Source: Article "Evolutie in buizen voor
 stadsverwarming, 2003"

For PUR, Polyurethane, $K=0.36 \text{ Watt/(m.K)}$
 Source: Transport Phenomena Data Companion

For Glass wool, $K=0.041 \text{ Watt/(m.K)}$
 Source: Coulson and Richardson §

Estimation of the insulation outlet temperature:

$T_g := 15 \quad \text{C}$ Ground surface temperature, average over the year

$$aa := \left[\left(\frac{d_{in}}{2} + x \right) \cdot \frac{h}{k_i} \cdot \ln \left(\frac{\frac{d_{in}}{2} + x}{\frac{d_{in}}{2}} \right) \right]$$

$$aa = \begin{pmatrix} 5.999 \times 10^3 \\ 3.213 \times 10^3 \\ 3.213 \times 10^3 \\ 3.213 \times 10^3 \\ 3.213 \times 10^3 \\ 3.213 \times 10^3 \end{pmatrix}$$

$$TL := \frac{T + aa \cdot T_g}{aa + 1}$$

$$TL = \begin{pmatrix} 15.02 \\ 15.037 \\ 15.037 \\ 15.037 \\ 15.037 \\ 15.037 \end{pmatrix}$$

C Ref: Coulson and Richardson §, Chemical Engineering, Flow, Heat Transfer and Mass Transfer, 6th edition

Estimation of the heat losses through the insulation only (considering pipe located in a pipe way on the ground):


$$Q_{\text{lossinsulation}} := \frac{2 \cdot \pi \cdot k_i \cdot (T - T_L)}{\ln \left(\frac{\frac{\text{dext}}{2} + x}{\frac{\text{dext}}{2}} \right)}$$

$$Q_{\text{lossinsulation}} = \begin{pmatrix} 104.46 \\ 92.72 \\ 92.72 \\ 92.72 \\ 92.72 \\ 92.72 \end{pmatrix} \quad \text{W/m}$$

Estimation of the heat losses through the insulation and the ground (pipe insulated and underground):

There are two layers: insulation (5cm) + ground (80cm deep)

hb := 0.8 m Height buried



hb : height buried
dex : pipe external diameter
x : insulation thickness

$$k_{\text{soil}} := 1.5 \left(\frac{252}{3600} \cdot \frac{4.18}{0.3048} \cdot 1.8 \right) \quad k_{\text{soil}} = 2.592 \quad \text{Watt/(m.K)}$$

Source: Kreith, F. Principles of Heat Transfer, 2nd edition, International Textbook Company, Scranton, Pa, 1965

Soil thermal conductivity is strongly dependent on the kind of soil (e.g. dry or wet) For wet soil, $k=1.5 \text{ BTU/(h.ft.F)}$, which was the type of soil considered.

$$QT := \frac{T - T_g}{\frac{1}{2 \cdot \pi} \left[\frac{1}{k_i} \cdot \ln \left(\frac{\frac{d_{ext}}{2} + x}{\frac{d_{ext}}{2}} \right) + \frac{1}{k_{soil}} \cdot \ln \left[\frac{hb + \left(\frac{d_{ext}}{2} + x \right)}{\left(\frac{d_{ext}}{2} + x \right)} + \left[\frac{hb + \left(\frac{d_{ext}}{2} + x \right)}{\left(\frac{d_{ext}}{2} + x \right)} - 1 \right]^{\frac{1}{2}} \right]} \right]}$$

The resistance to heat transfer in the film as well as in the pipe wall were considered to be negligible.

$$QT = \begin{pmatrix} 95.253 \\ 85.131 \\ 85.131 \\ 85.131 \\ 85.131 \\ 85.131 \end{pmatrix} \text{ Watt/m} \quad \text{Heat losses per length unit for each branch, Watt/m}$$

$$Q_{Loss} := (QT \cdot \text{Length}) \rightarrow Q_{Loss} = \begin{pmatrix} 2.858 \times 10^5 \\ 7.662 \times 10^4 \\ 1.532 \times 10^5 \\ 1.192 \times 10^5 \\ 1.362 \times 10^5 \\ 1.277 \times 10^5 \end{pmatrix} \text{ Watt} \quad \text{Heat losses in Watt}$$

Estimation of final temperature in each branch considering T initial as 133 C

$$t_f := \left(T - \frac{Q_{Loss}}{\text{massflowrate} \cdot cp} \right) \rightarrow t_f = \begin{pmatrix} 132.31 \\ 132.445 \\ 131.89 \\ 132.137 \\ 132.014 \\ 132.075 \end{pmatrix} \text{ C}$$

$$\Delta T := (T - t_f) \rightarrow \Delta T = \begin{pmatrix} 0.69 \\ 0.555 \\ 1.11 \\ 0.863 \\ 0.986 \\ 0.925 \end{pmatrix} \text{ C} \quad \Delta T \text{ per branch, C}$$

Branch from CG1 to CG2:

$$T_{\text{finalCG1CG2}} = t_f_0$$

$$T_{\text{finalCG1CG2}} = 132.31 \quad \text{C}$$

$$\Delta T_{\text{CG1CG2}} = \Delta T_0$$

$$\Delta T_{\text{CG1CG2}} = 0.69 \quad \text{C}$$

$$Q_{\text{LossCG1CG2}} = Q_{\text{Loss}_0}$$

$$Q_{\text{LossCG1CG2}} = 2.858 \times 10^5 \quad \text{Watt}$$

Branch from CG1 to HEX1:

$$T_{\text{finalCG1HEX1}} = t_f_1$$

$$T_{\text{finalCG1HEX1}} = 132.445 \quad \text{C}$$

$$\Delta T_{\text{hotCG1HEX1}} = \Delta T_1$$

$$\Delta T_{\text{hotCG1HEX1}} = 0.555 \quad \text{C}$$

$$Q_{\text{LhotCG1HEX1}} = Q_{\text{Loss}_1}$$

$$Q_{\text{LhotCG1HEX1}} = 7.662 \times 10^4 \quad \text{Watt}$$

Branch from CG1 to HEX2:

$$T_{\text{finalCG1HEX2}} = t_f_2$$

$$T_{\text{finalCG1HEX2}} = 131.89 \quad \text{C}$$

$$\Delta T_{\text{hotCG1HEX2}} = \Delta T_2$$

$$\Delta T_{\text{hotCG1HEX2}} = 1.11 \quad \text{C}$$

$$Q_{\text{LhotCG1HEX2}} = Q_{\text{Loss}_2}$$

$$Q_{\text{LhotCG1HEX2}} = 1.532 \times 10^5 \quad \text{Watt}$$

Branch from CG2 to HEX3:

$$T_{\text{finalCG2HEX3}} = t_f_3$$

$$T_{\text{finalCG2HEX3}} = 132.137 \quad \text{C}$$

$$\Delta T_{\text{hotCG2HEX3}} = \Delta T_3$$

$$\Delta T_{\text{hotCG2HEX3}} = 0.863 \quad \text{C}$$

$$Q_{\text{LhotCG2HEX3}} = Q_{\text{Loss}_3}$$

$$Q_{\text{LhotCG2HEX3}} = 1.192 \times 10^5 \quad \text{Watt}$$

Branch from CG2 to HEX4:

$$T_{\text{finalCG2HEX4}} = t_f_4$$

$$T_{\text{finalCG2HEX4}} = 132.014 \quad \text{C}$$

$$\Delta T_{\text{hotCG2HEX4}} = \Delta T_4$$

$$\Delta T_{\text{hotCG2HEX4}} = 0.986 \quad \text{C}$$

$$Q_{\text{LhotCG2HEX4}} = Q_{\text{Loss}_4}$$

$$Q_{\text{LhotCG2HEX4}} = 1.362 \times 10^5 \quad \text{Watt}$$

Branch from CG2 to HEX5:

$T_{\text{finalCG2HEX5}} = t_{f5}$	$T_{\text{finalCG2HEX5}} = 132.075$	C
$\Delta T_{\text{hotCG2HEX5}} = \Delta T_5$	$\Delta T_{\text{hotCG2HEX5}} = 0.925$	C
$Q_{\text{LhotCG2HEX5}} = Q_{\text{Loss}_5}$	$Q_{\text{LhotCG2HEX5}} = 1.277 \times 10^5$	Watt

Total heat losses in the pipeline (hot tap water stream) = 1671.3×10^3 Watt

Total content of hot tap water leaving the Upgrading Unit = 2.927×10^7 Watt

Percentage of the energy content lost in the pipeline is the following:

$$\frac{1671.3 \cdot 10^3}{2.927 \cdot 10^7} \cdot 100 = 5.71$$

5.7% of the input energy available in the hot tap water exiting the Upgrading Unit is lost in the pipeline

Returning (cold tap water) at 70 C

All pipe data (i.e., diameter, length, insulation thickness), mass flowrates, etc, are the same as in the Way In branch (hot tap water)

Physical Properties of water at bulk temperature, $T=70^\circ\text{C}$:

$T := 70$ C Bulk temperature

Density

$\rho := 977.9$ kg/m³ Source: Transport Phenomena Data Companion
L.P.B.M. Janssen, M.M.C.G. Warmoeskerken

Dynamic viscosity

$\mu := 0.404 \cdot 10^{-2}$ g/(cm.s) Source: Transport Phenomena Data Companion
L.P.B.M. Janssen, M.M.C.G. Warmoeskerken

Thermal conductivity

$k_w := 0.665$ Watt/(m.K) Source: Transport Phenomena Data Companion
L.P.B.M. Janssen, M.M.C.G. Warmoeskerken

Specific heat

$$c_p := 4194 \quad \text{J/(kg.K)} \quad \text{Source: Transport Phenomena Data Companion}$$

L.P.B.M. Janssen, M.M.C.G. Warmoeskerken

Dimensionless Numbers (Re, Pr, Nu) were calculated at the bulk temperature, T=70 C

$$Pr := 2.57 \quad Pr = 2.57 \quad \text{Prandtl Number at bulk temperature}$$

Source: Transport Phenomena Data Companion

Velocity in the pipe, m/s

$$vel := \frac{\overrightarrow{\text{massflowrate}}}{\rho \cdot \pi \cdot \frac{din^2}{4}} \quad vel = \begin{pmatrix} 0.874 \\ 0.38 \\ 0.38 \\ 0.38 \\ 0.38 \\ 0.38 \end{pmatrix} \quad \text{m/s}$$

$$Re := \frac{\overrightarrow{din \cdot vel \cdot \rho}}{\mu} \cdot \frac{1000}{100} \quad Re = \begin{pmatrix} 8.056 \times 10^5 \\ 3.07 \times 10^5 \\ 3.07 \times 10^5 \\ 3.07 \times 10^5 \\ 3.07 \times 10^5 \\ 3.07 \times 10^5 \end{pmatrix} \quad \text{Since } Re > 10^4, \text{ there is turbulent flow}$$

$$Nu := 0.023 Re^{0.8} \cdot Pr^{0.33} \quad Nu = \begin{pmatrix} 1.667 \times 10^3 \\ 770.362 \\ 770.362 \\ 770.362 \\ 770.362 \\ 770.362 \end{pmatrix} \quad \text{Nusselt Number for forced convection}$$

$$x := 0.05 \quad \text{m} \quad \text{Insulation thickness was taken as 5 cm}$$

Convective heat transfer coefficient

$$h := \left(\frac{kw}{dext} \cdot Nu \right) \quad h = \begin{pmatrix} 2.728 \times 10^3 \\ 1.441 \times 10^3 \\ 1.441 \times 10^3 \\ 1.441 \times 10^3 \\ 1.441 \times 10^3 \\ 1.441 \times 10^3 \end{pmatrix} \quad \text{Watt}/(\text{m}^2 \cdot \text{K})$$

$$aa := \left[\left(\frac{din}{2} + x \right) \cdot \frac{h}{ki} \cdot \ln \left(\frac{\frac{din}{2} + x}{\frac{din}{2}} \right) \right] \quad aa = \begin{pmatrix} 4.932 \times 10^3 \\ 2.642 \times 10^3 \\ 2.642 \times 10^3 \\ 2.642 \times 10^3 \\ 2.642 \times 10^3 \\ 2.642 \times 10^3 \end{pmatrix}$$

$$TL := \frac{T + aa \cdot Tg}{aa + 1} \quad TL = \begin{pmatrix} 15.011 \\ 15.021 \\ 15.021 \\ 15.021 \\ 15.021 \\ 15.021 \end{pmatrix} \quad \text{C}$$

Estimation of the heat losses through the insulation only (considering pipe located in a pipe way on the ground):

$$Q_{lossinsulation} := \frac{2 \cdot \pi \cdot ki \cdot (T - TL)}{\ln \left(\frac{\frac{dext}{2} + x}{\frac{dext}{2}} \right)} \quad Q_{lossinsulation} = \begin{pmatrix} 48.687 \\ 43.214 \\ 43.214 \\ 43.214 \\ 43.214 \\ 43.214 \end{pmatrix} \quad \text{W/m}$$

Estimation of the heat losses through the insulation and the ground (pipe insulated and undergrounded):

There are two layers: insulation (15cm) + ground (80cm deep)

hb := 0.8 m Height buried

$$Q_T := \frac{T - T_g}{\frac{1}{2 \cdot \pi} \left[\frac{1}{k_i} \cdot \ln \left(\frac{\frac{d_{ext}}{2} + x}{\frac{d_{ext}}{2}} \right) + \frac{1}{k_{soil}} \cdot \ln \left[\frac{hb}{\left(\frac{d_{ext}}{2} + x \right)} + \left[\frac{hb}{\left(\frac{d_{ext}}{2} + x \right)} - 1 \right]^2 \right]} \right]}$$

$$Q_T = \begin{pmatrix} 44.952 \\ 40.08 \\ 40.08 \\ 40.08 \\ 40.08 \\ 40.08 \end{pmatrix}$$

Heat losses per length unit for each branch, Watt/m

Watt/m

$$Q_{Loss} := (Q_T \cdot \text{Length})$$

$$Q_{Loss} = \begin{pmatrix} 1.349 \times 10^5 \\ 3.607 \times 10^4 \\ 7.214 \times 10^4 \\ 5.611 \times 10^4 \\ 6.413 \times 10^4 \\ 6.012 \times 10^4 \end{pmatrix}$$

Heat losses in Watt

Watt

Estimation of final temperature in each branch considering T initial as 133 C :

$$t_f := \left(T - \frac{Q_{Loss}}{\text{massflowrate} \cdot c_p} \right)$$

$$t_f = \begin{pmatrix} 69.67 \\ 69.735 \\ 69.47 \\ 69.588 \\ 69.529 \\ 69.559 \end{pmatrix}$$

C

$$\Delta T := (T - t_f)$$

$$\Delta T = \begin{pmatrix} 0.33 \\ 0.265 \\ 0.53 \\ 0.412 \\ 0.471 \\ 0.441 \end{pmatrix} \quad \begin{array}{l} \Delta T \text{ per branch, C} \\ \\ \\ \text{C} \\ \\ \end{array}$$

Branch from CG1 to CG2:

$$T_{\text{finalCG1CG2}} = t_{f_0}$$

$$T_{\text{finalCG1CG2}} = 69.67 \quad \text{C}$$

$$\Delta T_{\text{coldCG1CG2}} = \Delta T_0$$

$$\Delta T_{\text{coldCG1CG2}} = 0.33 \quad \text{C}$$

$$Q_{\text{LcoldCG1CG2}} = Q_{\text{Loss}_0}$$

$$Q_{\text{LcoldCG1CG2}} = 1.349 \times 10^5 \quad \text{Watt}$$

Branch from CG1 to HEX1:

$$T_{\text{finalCG1HEX1}} = t_{f_1}$$

$$T_{\text{finalCG1HEX1}} = 69.735 \quad \text{C}$$

$$\Delta T_{\text{coldCG1HEX1}} = \Delta T_1$$

$$\Delta T_{\text{coldCG1HEX1}} = 0.265 \quad \text{C}$$

$$Q_{\text{LcoldCG1HEX1}} = Q_{\text{Loss}_1}$$

$$Q_{\text{LcoldCG1HEX1}} = 3.607 \times 10^4 \quad \text{Watt}$$

Branch from CG1 to HEX2:

$$T_{\text{finalCG1HEX2}} = t_{f_2}$$

$$T_{\text{finalCG1HEX2}} = 69.47 \quad \text{C}$$

$$\Delta T_{\text{coldCG1HEX2}} = \Delta T_2$$

$$\Delta T_{\text{coldCG1HEX2}} = 0.53 \quad \text{C}$$

$$Q_{\text{LcoldCG1HEX2}} = Q_{\text{Loss}_2}$$

$$Q_{\text{LcoldCG1HEX2}} = 7.214 \times 10^4 \quad \text{Watt}$$

Branch from CG2 to HEX3:

$$T_{\text{finalCG2HEX3}} = t_{f_3}$$

$$T_{\text{finalCG2HEX3}} = 69.588 \quad \text{C}$$

$$\Delta T_{\text{coldCG2HEX3}} = \Delta T_3$$

$$\Delta T_{\text{coldCG2HEX3}} = 0.412 \quad \text{C}$$

$$Q_{\text{LcoldCG2HEX3}} = Q_{\text{Loss}_3}$$

$$Q_{\text{LcoldCG2HEX3}} = 5.611 \times 10^4 \quad \text{Watt}$$

Branch from CG2 to HEX4:

$$T_{\text{finalCG2HEX4}} = t_{f4}$$

$$T_{\text{finalCG2HEX4}} = 69.529 \quad \text{C}$$

$$\Delta T_{\text{coldCG2HEX4}} = \Delta T_4$$

$$\Delta T_{\text{coldCG2HEX4}} = 0.471 \quad \text{C}$$

$$Q_{\text{LcoldCG2HEX4}} = Q_{\text{Loss}4}$$

$$Q_{\text{LcoldCG2HEX4}} = 6.413 \times 10^4 \quad \text{Watt}$$

Branch from CG2 to HEX5:

$$T_{\text{finalCG2HEX5}} = t_{f5}$$

$$T_{\text{finalCG2HEX5}} = 69.559 \quad \text{C}$$

$$\Delta T_{\text{coldCG2HEX5}} = \Delta T_5$$

$$\Delta T_{\text{coldCG2HEX5}} = 0.441 \quad \text{C}$$

$$Q_{\text{LcoldCG2HEX5}} = Q_{\text{Loss}5}$$

$$Q_{\text{LcoldCG2HEX5}} = 6.012 \times 10^4 \quad \text{Watt}$$

Reference used :

1. Neher, J.H., 1949, The temperature rise of buried cables and pipes. Trans.A.I.E.E. 68, (1):9-21
2. Sissom, L.E., Pitts, D. R., Elements of Transport Phenomena, 1972, McGraw-Hill, Inc.
3. Kreith, F. Principles of Heat Transfer, 2nd edition, International Textbook Company, Scranton, Pa, 1965
4. Coulson and Richardson, Chemical Engineering, Flow, Heat Transfer and Mass Transfer, 6th edition
5. Transport Phenomena Data Companion, L.P.B.M. Janssen, M.M.C.G. Warmoeskerken
6. Article: Evolutie in buizen voor stadsverwarming, 2003

Appendix 20 Exergy Analysis of The Process

References:

Smith, J.M., Van Ness, H.C., Introduction to Chemical Engineering Thermodynamics 4th edition, 1987, McGraw-Hill, USA.

Since ammonia undergoes a cyclic process, the only changes that need to be considered for calculation of the ideal work are those of the gases passing through the furnace.

Ideal work is calculated by the following expression:

Source: Aspen

$$\begin{aligned} \text{ExEMISSION} &:= -2.653 \cdot 10^6 && \text{J/kg} && \text{massflowgases} &:= 11.0 && \text{kg/s} \\ \text{ExNGSTD} &:= -2.534 \cdot 10^6 && \text{J/kg} && \text{massflowair} &:= 10.34 && \text{kg/s} \\ \text{ExAIRIN} &:= -4.5295 \cdot 10^4 && \text{J/kg} && \text{massflowNG} &:= 0.713 && \text{kg/s} \end{aligned}$$

$$\text{Wideal} := -[\text{massflowgases} \cdot \text{ExEMISSION} - (\text{massflowNG} \cdot \text{ExNGSTD} + \text{massflowair} \cdot \text{ExAIRIN})]$$

$$\text{Wideal} = 2.704 \times 10^7 \quad \text{Watt} \quad \text{Eq.16.5 Van Ness}$$

Calculating the rate of entropy generation for each of the units of the cycle:

$$T_0 := 298.15 \quad \text{K}$$

W lost at the furnace

$$\text{SEMISSION} := 98.145 \quad \text{J/(kg.K)}$$

$$\text{SNGSTD} := -3674.0 \quad \text{J/(kg.K)}$$

$$\text{SAIRIN} := 133.997 \quad \text{J/(kg.K)}$$

$$\text{SgenerationFurnace} := \text{massflowgases} \cdot \text{SEMISSION} - (\text{massflowNG} \cdot \text{SNGSTD} + \text{massflowair} \cdot \text{SAIRIN})$$

$$\text{SgenerationFurnace} = 2.318 \times 10^3 \quad \text{Watt/K}$$

$$\text{WlostFurnace} := T_0 \cdot [\text{massflowgases} \cdot \text{SEMISSION} - (\text{massflowNG} \cdot \text{SNGSTD} + \text{massflowair} \cdot \text{SAIRIN})]$$

Eq 16.15 Van Ness

$$\text{WlostFurnace} = 6.91 \times 10^5 \quad \text{Watt}$$

W lost at the compressors

$$\text{massflowrateammonia} := 3.85 \quad \text{kg/s}$$

$$\text{SCOMP1OUT} := -6.753 \cdot 10^3 \quad \text{J/(kg.K)} \quad \text{SCOMP1IN} := -6.865 \cdot 10^3 \quad \text{J/(kg.K)}$$

$$\text{SgenerationCompr1} := \text{massflowrateammonia} \cdot (\text{SCOMP1OUT} - \text{SCOMP1IN})$$

$$\text{SgenerationCompr1} = 435.68 \quad \text{Watt/K}$$

$$\text{WlostCompr1} := \text{massflowrateammonia} \cdot T_0 \cdot (\text{SCOMP1OUT} - \text{SCOMP1IN})$$

$$\text{WlostCompr1} = 1.299 \times 10^5 \quad \text{Watt}$$

$$\text{SCOMP2OUT} := -6.761 \cdot 10^3 \quad \text{J/(kg.K)} \quad \text{SCOMP2IN} := -6.885 \cdot 10^3 \quad \text{J/(kg.K)}$$

$$\text{SgenerationCompr2} := \text{massflowrateammonia} \cdot (\text{SCOMP2OUT} - \text{SCOMP2IN})$$

$$\text{SgenerationCompr2} = 482.36 \quad \text{Watt/K}$$

$$\text{WlostCompr2} := \text{massflowrateammonia} \cdot T_0 \cdot (\text{SCOMP2OUT} - \text{SCOMP2IN})$$

$$\text{WlostCompr2} = 1.438 \times 10^5 \quad \text{Watt}$$

$$\text{SgenerationCompression} := \text{SgenerationCompr1} + \text{SgenerationCompr2}$$

$$\text{SgenerationCompression} = 918.04 \quad \text{Watt/K}$$

$$\text{WlostCompression} := \text{WlostCompr1} + \text{WlostCompr2}$$

$$\text{WlostCompression} = 2.737 \times 10^5 \quad \text{Watt}$$

W lost at the control valve

$$\text{Svout} := -1.006 \cdot 10^4 \quad \text{J/(kg.K)} \quad \text{Svin} := -1.0197 \cdot 10^4 \quad \text{J/(kg.K)}$$

$$\text{SgenerationCvalve} := \text{massflowrateammonia} \cdot (\text{Svout} - \text{Svin})$$

$$\text{SgenerationCvalve} = 532.93 \quad \text{Watt/K}$$

$$\text{WlostValve} := \text{massflowrateammonia} \cdot T_0 \cdot (\text{Svout} - \text{Svin})$$

$$W_{\text{lostValve}} = 1.589 \times 10^5 \quad \text{Watt}$$

W lost at the pump

$$SCWOUT := -7.8587 \cdot 10^3 \quad \text{J/(kg.K)} \quad SFURNOUT := -7.8592 \cdot 10^3 \quad \text{J/(kg.K)}$$

$$S_{\text{generationPump}} := \text{massflowrateammonia} \cdot (SCWOUT - SFURNOUT)$$

$$S_{\text{generationPump}} = 1.945 \quad \text{Watt/K}$$

$$W_{\text{lostPump}} := \text{massflowrateammonia} \cdot T_0 \cdot (SCWOUT - SFURNOUT)$$

$$W_{\text{lostPump}} = 579.902 \quad \text{Watt}$$

$$S_{\text{Total}} := S_{\text{generationPump}} + S_{\text{generationCvalve}} + S_{\text{generationCompression}} + S_{\text{generationFurnace}}$$

$$SP\% := \frac{S_{\text{generationPump}}}{S_{\text{Total}}} \cdot 100 \quad SP\% = 0.052$$

$$SCV\% := \frac{S_{\text{generationCvalve}}}{S_{\text{Total}}} \cdot 100 \quad SCV\% = 14.134$$

$$S_{\text{Compr}}\% := \frac{S_{\text{generationCompression}}}{S_{\text{Total}}} \cdot 100 \quad S_{\text{Compr}}\% = 24.347$$

$$SF_{\text{urn}}\% := \frac{S_{\text{generationFurnace}}}{S_{\text{Total}}} \cdot 100 \quad SF_{\text{urn}}\% = 61.468$$

$$W_{\text{lostPump}}\% := \frac{W_{\text{lostPump}}}{W_{\text{ideal}}} \cdot 100 \quad W_{\text{lostPump}}\% = 2.145 \times 10^{-3}$$

$$\text{WlostFurn\%} := \frac{\text{WlostFurnace}}{\text{Wideal}} \cdot 100 \quad \text{WlostFurn\%} = 2.556$$

$$\text{WlostComp\%} := \frac{\text{WlostFurnace}}{\text{Wideal}} \cdot 100 \quad \text{WlostFurn\%} = 2.556$$

$$\text{WlostCvalve\%} := \frac{\text{WlostValve}}{\text{Wideal}} \cdot 100 \quad \text{WlostCvalve\%} = 0.588$$

Appendix 21 Exergy Losses Calculation

References :

1. Article: Comakli, K. Yuksel, B., Camakli, O., Dept. of Mechanical Engineering, Ataturk University, Turkey, *Evaluation of energy and exergy losses in district heating network*, 2003, Applied Thermal Engineering 24(2004) 1009-1017.
2. K. Iyer, C. Van Wijmen, E. Babbe. *Feasibility Study of District Heating of Delft Using Residual Waste Heat of DSM*. 3 June 2004. TU Delft, The Netherlands
3. Kotas, T.J., *The Exergy Method of Thermal Plant Analysis*, 2nd edition, Krieger Publishing, Company, USA, 1995

The average pressure in the main network is approximately 13 bar.

The exergy balance is written as follows:

Exergy of hot water = Exergy lost in the pipeline due to heat losses +
 Exergy lost due to hot water transportation +
 Exergy lost during the heat transfer in the heat exchangers

Heat losses were calculated in Appendix 19, considering the Micro-PUR as insulation and insulation thickness of 50mm

Exergy Losses in the main pipeline

**PPG2 branch - From central grid 1 (CCG1) to central grid 2 (CCG2)
 (16" Sch 40, 3000m), both ways**

Exergy losses due to heat losses in the pipe:

$$\text{Loss}_{\text{shotCG1CG2}} := 2.858 \times 10^5 \quad \text{Watt}$$

$$\text{Loss}_{\text{coldCG1CG2}} := 1.349 \times 10^5 \quad \text{Watt}$$

$$\text{Q}_{\text{lossesmain}} := \text{Loss}_{\text{shotCG1CG2}} + \text{Loss}_{\text{coldCG1CG2}}$$

$$\text{Q}_{\text{lossesmain}} = 4.207 \times 10^5 \quad \text{Watt}$$

$$T_0 := 25 + 273 \quad T_0 = 298 \quad \text{K} \quad \text{Average temperature of the surroundings taken as } 25^\circ\text{C}$$

$$T_{\text{hotwater}} := 133 + 273 \quad T_{\text{hotwater}} = 406 \quad \text{K}$$

$$T_{\text{Hotwaterin}} := 133 + 273 \quad T_{\text{Hotwaterin}} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$T_{\text{Hotwaterout}} := 70 + 273 \quad T_{\text{Hotwaterout}} = 343 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$T_w := \frac{T_{\text{Hotwaterin}} + T_{\text{Hotwaterout}}}{2} \quad T_w = 374.5 \quad \text{K} \quad 372.5 - 273 = 99.5$$

$$\text{ExLoss}_{\text{main}} := Q_{\text{losses}_{\text{main}}} \cdot \left(1 - \frac{T_0}{T_w} \right)$$

$$\text{ExLoss}_{\text{main}} = 8.594 \times 10^4 \quad \text{Watt}$$

Exergy Losses in the pipeline #1
PHEX1 branch - From CCG1 to heat exchanger 1 (HEX1)
(14" Sch 40, 900m), both ways

Exergy losses due to heat losses in the pipe:

$$\text{Losshot}_{\text{CG1HEX1}} := 7.662 \times 10^4 \quad \text{Watt}$$

$$\text{Losscold}_{\text{CG1HEX1}} := 3.607 \times 10^4 \quad \text{Watt}$$

$$Q_{\text{losses1}} := \text{Losshot}_{\text{CG1HEX1}} + \text{Losscold}_{\text{CG1HEX1}}$$

$$Q_{\text{losses1}} = 1.127 \times 10^5 \quad \text{Watt}$$

$$T_{\text{Hotwaterin}} := 133 + 273 \quad T_{\text{Hotwaterin}} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$T_{\text{Hotwaterout}} := 66 + 273 \quad T_{\text{Hotwaterout}} = 339 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$T_w := \frac{T_{\text{Hotwaterin}} + T_{\text{Hotwaterout}}}{2} \quad T_w = 372.5 \quad \text{K}$$

$$\text{ExLoss1} := Q_{\text{losses1}} \cdot \left(1 - \frac{T_0}{T_w} \right)$$

$$\text{ExLoss1} = 2.254 \times 10^4 \quad \text{Watt}$$

Exergy Losses in the pipeline #2
PHEX2 branch - From CCG1 to heat exchanger 2 (HEX2)
(14" Sch 40, 1800m), both ways

Exergy losses due to heat losses in the pipe:

$$\text{Losshot}_{\text{CG1HEX2}} := 1.532 \times 10^5 \quad \text{Watt}$$

$$\text{Losscold}_{\text{CG1HEX2}} := 7.214 \times 10^4 \quad \text{Watt}$$

$$Q_{\text{losses2}} := \text{LosshotCG1HEX2} + \text{LosscoldCG1HEX2}$$

$$Q_{\text{losses2}} = 2.253 \times 10^5 \quad \text{Watt}$$

$$T_{\text{Hotwaterin}} := 133 + 273 \quad T_{\text{Hotwaterin}} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$T_{\text{Hotwaterout}} := 66 + 273 \quad T_{\text{Hotwaterout}} = 339 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$T_w := \frac{T_{\text{Hotwaterin}} + T_{\text{Hotwaterout}}}{2} \quad T_w = 372.5 \quad \text{K}$$

$$\text{ExLoss2} = Q_{\text{losses2}} \cdot \left(1 - \frac{T_0}{T_w} \right)$$

$$\text{ExLoss2} = 4.507 \times 10^4 \quad \text{Watt}$$

Exergy Losses in the pipeline #3
PHEX3 branch - From CCG2 to heat exchanger 3 (HEX3)
(14" Sch 40, 1400m), both ways

Exergy losses due to heat losses in the pipe:

$$\text{LosshotCG1HEX3} := 1.192 \times 10^5 \quad \text{Watt}$$

$$\text{LosscoldCG1HEX3} := 5.611 \times 10^4 \quad \text{Watt}$$

$$Q_{\text{losses3}} := \text{LosshotCG1HEX3} + \text{LosscoldCG1HEX3}$$

$$Q_{\text{losses3}} = 1.753 \times 10^5 \quad \text{Watt}$$

$$T_{\text{Hotwaterin}} := 133 + 273 \quad T_{\text{Hotwaterin}} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$T_{\text{Hotwaterout}} := 66 + 273 \quad T_{\text{Hotwaterout}} = 339 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$T_w := \frac{T_{\text{Hotwaterin}} + T_{\text{Hotwaterout}}}{2} \quad T_w = 372.5 \quad \text{K}$$

$$\text{ExLoss3} := Q_{\text{losses3}} \cdot \left(1 - \frac{T_0}{T_w} \right)$$

$$\text{ExLoss3} = 3.506 \times 10^4 \quad \text{Watt}$$

Exergy Losses in the pipeline #4
PHEX4 branch - From CCG2 to heat exchanger 4 (HEX4)
(14" Sch 40, 1600m), both ways

Exergy losses due to heat losses in the pipe:

$$\text{LosshotCG1HEX4} := 1.362 \times 10^5 \quad \text{Watt}$$

$$\text{LosscoldCG1HEX4} := 6.413 \times 10^4 \quad \text{Watt}$$

$$\text{Qlosses4} := \text{LosshotCG1HEX4} + \text{LosscoldCG1HEX4}$$

$$\text{Qlosses4} = 2.003 \times 10^5 \quad \text{Watt}$$

$$\text{THotwaterin} := 133 + 273 \quad \text{THotwaterin} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$\text{THotwaterout} := 66 + 273 \quad \text{THotwaterout} = 339 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$\text{Tw} := \frac{\text{THotwaterin} + \text{THotwaterout}}{2} \quad \text{Tw} = 372.5 \quad \text{K}$$

$$\text{ExLoss4} := \text{Qlosses4} \cdot \left(1 - \frac{\text{T0}}{\text{Tw}} \right)$$

$$\text{ExLoss4} = 4.007 \times 10^4 \quad \text{Watt}$$

Exergy Losses in the pipeline #5
PHEX5 branch - From CCG2 to heat exchanger 5 (HEX5)
(14" Sch 40, 1500m), both ways

Exergy losses due to heat losses in the pipe:

$$\text{LosshotCG1HEX5} := 1.277 \times 10^5 \quad \text{Watt}$$

$$\text{LosscoldCG1HEX5} := 6.012 \times 10^4 \quad \text{Watt}$$

$$\text{Qlosses5} := \text{LosshotCG1HEX5} + \text{LosscoldCG1HEX5}$$

$$\text{THotwaterin} := 133 + 273 \quad \text{THotwaterin} = 406 \quad \text{K} \quad \text{Hot stream (IN)}$$

$$\text{THotwaterout} := 66 + 273 \quad \text{THotwaterout} = 339 \quad \text{K} \quad \text{Cold stream (Return)}$$

$$T_w := \frac{T_{\text{Hotwaterin}} + T_{\text{Hotwaterout}}}{2} \quad T_w = 372.5 \quad \text{K}$$

$$\text{ExLoss5} := Q_{\text{losses5}} \cdot \left(1 - \frac{T_0}{T_w} \right)$$

$$\text{ExLoss5} = 3.756 \times 10^4 \quad \text{Watt}$$

Exergy losses due to hot water transportation

Electric-driven pumps are used transport hot water from the Upgrading Unit to the Districts.

Electrical energy is pure exergy and such exergy is used to overcome the flow resistance in the pipeline network, which is actually transformed into heat.

$$W_p := 107824.6 \quad \text{Watt}$$

$$\text{ELossTransport} := W_p \cdot \left(\frac{T_0}{T_w} \right) \quad \text{ELossTransport} = 8.626 \times 10^4 \quad \text{Watt}$$

Exergy losses during heat transfer in the heat exchangers (5 heat exchangers in total)

Heat transfer in a heat exchanger is an irreversible process and as a consequence exergy losses occur. The total exergy losses in the process is due to irreversibility in heat transfer

in addition to friction of both flows. According to Kotas [68], exergy losses due to friction in liquid flow are small due to small specific volume of the compressible fluids.

$$Q_c := 2.33 \cdot 10^7 \quad \text{Watt} \quad \text{Heat duty of each heat exchanger (5 in total)}$$

$T_{\text{hotin}} := 133 + 273 \quad \text{K}$ This temperature changes depending on the heat losses. Let's assume T_{hotin} as 133 C.

$T_{\text{hotout}} := 70 + 273 \quad \text{K}$ Taken based on approach rules of thumb for heat exchangers.

$T_{\text{coldin}} := 60 + 273 \quad \text{K}$ Taken based on approach rules of thumb for heat exchangers.

$T_{\text{coldout}} := 90 + 60 \quad \text{K}$ Required temperature at the districts

$$T_{hot} := \frac{T_{hotin} + T_{hotout}}{2} \quad T_{hot} = 374.5 \quad \text{K}$$

$$T_{cold} := \frac{T_{coldin} + T_{coldout}}{2} \quad T_{cold} = 241.5 \quad \text{K}$$

$$4219.3(133 - 70) \cdot 32.47 = 8.631 \times 10^6 \quad Q_c := 8.631 \times 10^6$$

$$E_{LossHeatExchangers} := 5T_0 \cdot (-Q_c) \cdot \left(\frac{1}{T_{hot}} - \frac{1}{T_{cold}} \right)$$

$$E_{LossHeatExchangers} = 1.891 \times 10^7 \quad \text{Watt}$$

Total Exergy Losses

$$E_{LossPipe} := E_{Lossmain} + E_{Loss1} + E_{Loss2} + E_{Loss3} + E_{Loss4} + E_{Loss5}$$

$$E_{LossPipe} = 2.662 \times 10^5 \quad \text{Watt}$$

$$T_{ExergyLoss} := E_{LossPipe} + E_{LossTransport} + E_{LossHeatExchangers}$$

$$T_{ExergyLoss} = 1.926 \times 10^7 \quad \text{Watt}$$

Total exergy input to hot water

Estimating the exergy of the hot water stream (discharge of the pump) exiting the Upgrading Unit

Using Peng Robinson EoS

From Program Prop Mathcad at 137C and 13 bar,

$T_{ref} = 298\text{K}$,

PR EoS:

$H = -36479.7 \text{ J/mol}$

$S = -97.02364 \text{ J/(mol.K)}$

$$H := -36479.7 \frac{1}{18} \cdot 1000 \quad H = -2.027 \times 10^6 \quad \text{J/Kg}$$

$$S := -97.02364 \frac{1}{18} \cdot 1000 \quad S = -5.39 \times 10^3 \quad \text{J/(kg.K)}$$

$$\text{massflowrate} := 97.39 \quad \text{massflowrate} = 97.39 \quad \text{kg/s}$$

$$\text{Ex} := \text{massflowrate} \cdot (H - T0 \cdot S)$$

$$\text{Ex} = -4.094 \times 10^7 \quad \text{J/s} \quad \text{Ex} = -4.094 \times 10^7 \quad \text{Watt}$$

$$\text{TotalExergyinput} := 4.094 \times 10^7 \quad \text{Watt} \quad \text{Taken as positive value}$$

Percentage of exergy losses:

$$\text{RatioELossPipeExergyinput} := \frac{\text{ELossPipe}}{\text{TotalExergyinput}}$$

$$\text{RatioELossPipeExergyinput} = 6.503 \times 10^{-3} \quad \text{fraction of input exergy lost in the pipeline due to heat losses}$$

$$\text{RatioELossTransportExergyinput} := \frac{\text{ELossTransport}}{\text{TotalExergyinput}}$$

$$\text{RatioELossTransportExergyinput} = 2.107 \times 10^{-3} \quad \text{fraction of input exergy lost in the pipeline due to flow, friction, etc}$$

$$\text{RatioELossHeatExchangersExergyinput} := \frac{\text{ELossHeatExchangers}}{\text{TotalExergyinput}}$$

$$\text{RatioELossHeatExchangersExergyinput} = 0.462 \quad \text{fraction of input exergy lost in the heat exchangers}$$

Result from Aspen AVAILMX for stream CWOUT: Exergy=-1.277*10⁹ Watt

Method 2. Lee-Kesler EoS

From the tables Ref: RPP, 4th edition:

H=-2445.43 J/mol

S=-27.203 J/(mol.K)

$$H := -2445.43 \frac{1}{18} \cdot 1000$$

$$H = -1.359 \times 10^5 \quad \text{J/Kg}$$

$$S := -27.203 \frac{1}{18} \cdot 1000$$

$$S = -1.511 \times 10^3 \quad \text{J/(kg.K)}$$

$$\text{massflowrate} := 97.39$$

$$\text{massflowrate} = 97.39 \quad \text{kg/s}$$

$$\text{Ex} := \text{massflowrate} \cdot (H - T0 \cdot S)$$

$$\text{Ex} = 3.063 \times 10^7 \quad \text{J/s}$$

$$\text{Ex} = 3.063 \times 10^7 \quad \text{Watt}$$

Appendix 22 COP Calculation

Calculating the coefficient of performance of the MHP (mechanical heat pump) and for the CHP (chemical heat pump).

Mechanical heat pump (MHP):

From the simulation with Aspen the following data were gathered:

$$Q_{\text{high}} := 4.804 \times 10^6 \quad \text{Watt}$$

$$Q_{\text{intercooler}} := 2.028 \times 10^5 \quad \text{Watt}$$

$$Q_{\text{low}} := 3.535 \times 10^6 \quad \text{Watt}$$

$$W_{\text{compression}} := 9.4583 \times 10^5 + 6.896 \times 10^5 \quad \text{Watt} \quad \text{Energy input as work by the compressors}$$

1. Coefficient of Performance (COP)

$$\text{COP} := \frac{Q_{\text{high}} + Q_{\text{intercooler}}}{W_{\text{compression}}}$$

$$\text{COP} = 3.061$$

COP = 3.1, ratio useful heat output to energy input (work). Qintercooler was included since it was recovered at high temperature (discharge of the first compressor)

2. Exergy Efficiency (η_E)

$$T_{\text{low}} := 12.0 + 273$$

$$T_{\text{low}} = 285 \quad \text{K} \quad \text{Evaporator temperature}$$

$$T_{\text{high}} := 76.0 + 273$$

$$T_{\text{high}} = 349 \quad \text{K} \quad \text{Condenser temperature}$$

$$T_c := 0 + 273$$

$$T_c = 273 \quad \text{K} \quad \text{Reference temperature, taken as } 0 \text{ C (must be lower than } T_{\text{low}})$$

$$\text{COP}_{\text{ideal}} := \frac{1 - \frac{T_c}{T_{\text{high}}}}{1 - \frac{T_c}{T_{\text{low}}}}$$

$$\text{COP}_{\text{ideal}} = 5.172$$

This is Carnot COP

$$\eta_E := \frac{\text{COP}}{\text{COP}_{\text{ideal}}}$$

$$\eta_E = 0.592$$

This parameter indicates the quality and quantity of the upgraded heat.

Chemical heat pump (CHP):

From the simulation with Aspen the following data were gathered:

$$Q_{\text{reboiler}} := 7973.71 \quad \text{kW} \qquad Q_{\text{exo}} := 1788.51 \quad \text{kW}$$

$$Q_{\text{condenser}} := 8687.81 \quad \text{kW} \qquad Q_{\text{endo}} := 2318.81 \quad \text{kW}$$

$$Q_{\text{low}} := Q_{\text{reboiler}} + Q_{\text{endo}}$$

$$Q_{\text{low}} = 1.029 \times 10^4 \quad \text{kW} \quad Q_{\text{low}} \text{ is the amount of heat absorbed that is used for both the endothermic reaction and the products separation in the distillation column.}$$

$$Q_{\text{high}} := Q_{\text{exc}} \quad Q_{\text{high}} \text{ is the amount of upgraded heat at the highest temperature, that is to say the exothermic reaction heat duty}$$

The COP can be calculated by the following equation:

$$\text{COP} := \frac{Q_{\text{high}}}{Q_{\text{low}}}$$

$$\text{COP} = 0.174$$

COP = 17.4%. It is the enthalpy efficiency of the system

The ideal COP is limited by the conservation law of heat and entropy:

$$T_{\text{high}} := 200 + 273 \quad \text{temperature of the exothermic reactor}$$

$$T_{\text{c}} := 43.73 + 273 \quad \text{temperature of the condenser}$$

$$T_{\text{low}} := 82.5 + 273 \quad \text{temperature of the exothermic reactor}$$

$$\text{COP}_{\text{ideal}} := \frac{1 - \left(\frac{T_{\text{c}}}{T_{\text{low}}} \right)}{1 - \left(\frac{T_{\text{c}}}{T_{\text{high}}} \right)}$$

$$\text{COP}_{\text{ideal}} = 0.33$$

COP_{ideal} = 33.3%. It is the maximum fraction of the recovered waste heat that can be upgraded.

Appendix 25 Total Investment of Ammonia Heat Pump

Description	Fraction	Amount
Total investment		\$ 29,264,054
<u>Fixed capital</u>	1.00	\$ 24,512,821
<u>Direct costs</u>	0.79	\$ 19,291,590
<u>Onsite costs</u>		\$ 16,043,641
Purchased equipment	0.37	\$ 9,082,000
Purchased-equipment installation	0.17	\$ 4,081,385
Instrumentation and control	0.05	\$ 1,164,359
Piping UU	0.04	\$ 980,513
Electrical equipment and materials	0.03	\$ 735,385
<u>Offsite costs</u>		\$ 3,247,949
Buildings	0.03	\$ 735,385
Yard improvement	0.03	\$ 796,667
Service facilities	0.04	\$ 980,513
Land	0.03	\$ 735,385
<u>Indirect costs</u>	0.21	\$ 5,221,231
Engineering and supervision	0.08	\$ 1,961,026
Construction expenses	0.05	\$ 1,176,615
Contractor's fee	0.03	\$ 612,821
Contingency	0.06	\$ 1,470,769
<u>Working capital</u>		\$ 1,463,203
Raw material, finished products, accounts receivable, cash on hand, account payable and taxes payable 15% of total capital investment.	0.05	\$ 1,463,203
<u>Costs for transport pipelines</u> *		\$ 16,953,225
<u>One time revenues (minus)</u>		-\$ 13,665,194
<u>Start-up costs</u>		\$ 1,470,769
Process modifications, start-up labor, loss in production	0.06	\$ 1,470,769

Prices from (NAP prijzenboekje 20e editie februari 1999)		
The price for total steel underground transport pipelines are (1999)(16inch):	440	€ /m
The material price for under ground steel transport pipes (DN350), included average discount of 45%	88	€ /m
Price for laying the pipes:	352	€ /m
Index correction of 4 % per year:	445	€ /m
Prices for the pipes (by Marcel Verboven, Weijers-Waalwijk BV)		
DN350 – 355,6x5,6 / 500 (staal – PUR – PE) Standaard PUR schuim	117.68	€ /m
DN350 – 355,6x5,6 / 500 (staal – PUR – PE) MicroPUR schuim	156.98	€ /m
In the first case we used Standaard PUR, resulting at a length of 21 km in:	11,824,518	€
Including tax	\$	16,953,225

Appendix 27 Production Cost of Furnace

	Water	Natural Gas	Electricity
price	1.28 euro/m ³	0.18 euro/m ³	0.1 euro/kWh
BTW	1.06	1.19	1.19
tax	0.146 euro/m ³	0.01 euro/m ³	0.0086 euro/kWh
km			
V pipe 16 inch	1868 m ³	Furnace 125000 m ³ /hr	Clean w pump 1 53 kW
V pipe 14 inch	596 m ³	3540 m ³ /hr	Blower 378 kW
total amount	2,464 m ³	38,758,620 m ³	3,776,524 kWh
costs	€ 3,703	€ 8,689,683	€ 481,884
total costs	€ 9,175,270		
	\$ 10,952,930		
1m ³ gas	31.7MJ		
exchange course:	0.8377\$/euro		

Appendix 28 Total Product Cost

	Fraction	of	Amount
Total product costs			\$ 20,314,787
<u>Manufacturing costs</u>			\$ 19,958,957
<u>Direct production cost</u>	0.73	Total product costs	\$ 14,786,715
Raw materials		Gas, waste water	\$ 9,743,402
Utilities		Electricity NH3 H2O	\$ 2,766,279
Maintenance	0.04	Fixed capital	\$ 980,513
Operating supplies	0.15	Maintenance	\$ 147,077
Labor	*	Operators	\$ 450,000
Supervision	0.2	Labor	\$ 90,000
Laboratory charges			\$ -
Royalties	0.03	Total product costs	\$ 609,444
<u>Fixed charges</u>	0.21	Total product costs	\$ 4,259,934
Depreciation	0.1	Fixed capital	\$ 2,451,282
Local taxes	0.025	Fixed capital	\$ 612,821
Insurance	0.007	Fixed capital	\$ 171,590
Rent	0		
Interest	0.035	Total cap invest.	\$ 1,024,242
<u>Plant OVHD</u>	0.04	Total product costs	\$ 912,308
	0.72	Labor	\$ 324,000
	0.024	Fixed capital	\$ 588,308
<u>SARE</u>	0.025	Revenue	\$ 355,830

* The plant will be controlled by a 5 shifts, each shift consists of 2 persons. The salary of an operator is assumed to be € 45,000 per year. Supervision is supposed to be 1/5 of the labor costs, equals 1 supervisor.

Appendix 29 Revenues

City heating rates for small users and small business-like users from 1 oct 2005

BTW	19%
Energy tax	6.32 €/ GJ
exchange course:	0.8377 \$/euro

Annual consumption	780000 GJ
Houses connected	11000

Heat price for heating and hot tap water		Fraction	Inc tax	Ex tax
Consumption less than 119 GJ per GJ	119 GJ per GJ	0.8	€ 22.04	€ 12.20
Consumption from 119 GJ per GJ	119 GJ per GJ	0.2	€ 19.59	€ 10.14
Right for usage (yearly)			€ 295.07	€ 247.96
One time connection contribution			€ 3,715.18	€ 3,122.00

Total yearly revenues	€ 11,923,148	\$ 14,233,196
-----------------------	--------------	---------------

Consumption	€ 9,195,610
Connections	€ 2,727,538

1/3 of the one time connection revenues	€ 11,447,333	\$ 13,665,194
---	--------------	---------------

Source: <http://gemeente.purmerend.nl/smartsite.html?id=3923>

Appendix 30 Chemical Heat Pump Simulation

In order to validate the previously done feasibility study, the Chemical Heat Pump (CHP) process was simulated in Aspen Plus. The simulation flowsheet and the distillation profiles are presented here.


It should be noted that both endothermic and exothermic reactors were modeled by using the equilibrium reactor models (conversions were specified based on data gathered from the literature/simulation studies). The conditions of the reactors were also specified so that only the corresponding reactions were taking place. Unlike the endothermic reaction, which was simulated in the liquid phase (at boiling point), the exothermic reaction was simulated in the gas phase following the information gathered from the articles that report similar studies [10],[12],[13]. The conversions were predicted according to the chemical equilibrium conditions mentioned in the articles [10],[12],[13],[14]. The molar ratio hydrogen to acetone was set as 1.0 in accordance with the article [12].

Moreover, the distillation column was modeled with rigorous multi component distillation with partial condenser. The purity of acetone in the bottom and isopropanol in the top were specified and determined the reflux ratio and the reboiler duty.



The remaining equipments (compressor and heat exchanger) were straight forwardly modeled.



Only one tear stream (the feed to the exothermic reactor, FEEDEXO) was used to perform the simulation within the cycle. It serves as input for the total flow rate, which remains constant as the simulation runs. However, its composition, temperature, and pressure are automatically updated as a result of each run.

Based on heat integration studies, other simulations were run in order to better evaluate the technical feasibility of this system. However, due to low temperature level of DSM waste water, there is no way to use this stream as the heating source of isopropanol-acetone chemical heat pump.



Considering the design specifications of 2.3% mole fraction of isopropanol at distillate and 1.0% mole fraction of acetone at bottoms, the distillation profiles were found to be as follows:





Appendix 31 Economic Evaluation of Chemical Heat Pump

All the costs have been evaluated based on "Product and Process Design Principles" [1]. According to Chemical engineering Magazine (2), the Annual CE Plant Cost Index for 2000 (Base Case):

$$CE1 := 394.1$$

The Annual CE Plant Cost Index for 2004:

$$CE2 := 444.2$$

The cost of equipments are calculated separately, as follows:

Blower: $P_c := 501.9 \text{ hp}$

Blower horsepower:

The cost of centrifugal (turbo) blower including the cost of electric motor is:

$$CB := \exp(6.6547 + 0.7900 \ln(P_c))$$

For cast iron as material of construction:

$$FM := 1.0$$

$$C_{p\text{Blower}} := FM \cdot CB \cdot \left(\frac{CE2}{CE1} \right)$$

$$C_{p\text{Blower}} = 1.19 \times 10^5 \text{ \$}$$

Air Blower:

This blower is oversized to cope with the fluctuations in the winter time.

Blower horsepower: $P_c := 2.575 \times 10^3 \text{ hp}$

The cost of centrifugal (turbo) blower including the cost of electric motor is:

$$CB := \exp(6.6547 + 0.7900 \ln(P_c))$$

For cast iron as material of construction:

$$FM := 1.0$$

$$C_{p\text{AIRBlower}} := FM \cdot CB \cdot \left(\frac{CE2}{CE1} \right)$$

$$C_{p\text{AIRBlower}} = 4.331 \times 10^5 \text{ \$}$$

Heat Exchanger:

Shell side : Tcompout := 334.49 K Tfeedexo := 460.07 K

Tube side : Texoout := 473.15 K Tfeeddis2 := 348.15 K

$$\Delta T_{HEX} := \frac{[(T_{feedexo} - T_{compout}) - (T_{exoout} - T_{feeddis2})]}{\ln \left[\frac{(T_{feedexo} - T_{compout})}{(T_{exoout} - T_{feeddis2})} \right]}$$

$$\Delta T_{HEX} = 125.292 \quad K$$

$$Q_{HEX} := 2.694 \times 10^6 \quad \text{Watt}$$

According to Coulson & Richardson [3], the heat coefficient is:

$$U := 200 \frac{\text{Watt}}{\text{m}^2 \cdot K}$$

thus, the heat exchanger area is:

$$A_{HEX} := \frac{Q_{HEX} 10.764}{U \cdot \Delta T_{HEX}}$$

$$A_{HEX} = 1.157 \times 10^3 \quad \text{ft}^2$$

The material of construction of the shell side and the tube side is carbon steel, thus

$$FM := 0.0 + \left(\frac{A_{HEX}}{100} \right)^{0.0}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure based on the shell side pressure in psig is calculated as follows:

$$P_{HEX} := 1.5 \quad \text{bar}$$

$$P_{HEXShell} := P_{HEX} 14.5 - 14.7$$

$$P_{HEXShell} = 7.05 \quad \text{psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HEXShell}}{100} \right) + 0.0017 \left(\frac{P_{HEXShell}}{100} \right)^2$$

$$FP = 0.982$$

The heat exchanger is of floating head type:

$$CB_{HEX} := \exp\left[11.667 - 0.8709 \ln(A_{HEX}) + 0.09005 (\ln(A_{HEX}))^2\right]$$

The purchase cost of the heat exchanger is:

$$C_{pHEX} := FP \cdot FM \cdot FL \cdot CB_{HEX} \left(\frac{CE_2}{CE_1}\right)$$

$$C_{pHEX} = 2.741 \times 10^4 \quad \$$$

Distillation Condenser:

Shell side (process fluid): $T_{cond} := 316.88 \text{ K}$ $T_{cwout} := 302.1 \text{ K}$

Tube side (cooling water): $T_{cwin} := 293.1 \text{ K}$

$$\Delta T_{COND} := T_{cond} - \left(\frac{T_{cwin} + T_{cwout}}{2}\right)$$

$$\Delta T_{COND} = 19.232 \text{ K}$$

$$Q_{COND} := 8.694 \times 10^6 \text{ Watt}$$

According to Coulson & Richardson [3], the heat coefficient is:

$$U := 600 \frac{\text{Watt}}{\text{m}^2 \cdot \text{K}}$$

thus, the heat exchanger area is:

$$A_{COND} := \frac{Q_{COND} 10.764}{U \cdot \Delta T_{COND}}$$

$$A_{COND} = 8.11 \times 10^3 \text{ ft}^2$$

The material of construction of the shell side and the tube side is carbon steel, thus

$$FM := 0.0 + \left(\frac{A_{COND}}{100}\right)^{0.0}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure based on the shell side pressure in psig is calculated as follows:

$$P_{HEX} := 1.15 \text{ bar}$$

$$P_{HEXShell} := P_{HEX} \cdot 14.5 - 14.7$$

$$P_{HEXShell} = 1.975 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HEXShell}}{100} \right) + 0.0017 \left(\frac{P_{HEXShell}}{100} \right)^2$$

$$FP = 0.981$$

The heat exchanger is of floating head type:

$$C_{BCOND} := \exp \left[11.667 - 0.8709 \ln(A_{COND}) + 0.09005 (\ln(A_{COND}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pCOND} := FP \cdot FM \cdot FL \cdot C_{BCOND} \left(\frac{CE2}{CE1} \right)$$

$$C_{pCOND} = 8.387 \times 10^4 \text{ \$}$$

Distillation Reboiler:

$$\text{Shell side (process fluid): } T_{reb} := 358.19 \text{ K}$$

$$\text{Tube side (LPsteam): } T_{steam} := 399.8 \text{ K}$$

$$\Delta T_{REB} := T_{steam} - T_{reb}$$

$$\Delta T_{REB} = 41.625 \text{ K}$$

$$Q_{REB} := 7.972 \times 10^6 \text{ Watt}$$

According to Coulson & Richardson [3], the heat coefficient is:

$$U := 100 \frac{\text{Watt}}{\text{m}^2 \cdot \text{K}}$$

thus, the heat exchanger area is:

$$A_{REB} := \frac{Q_{REB} \cdot 10.764}{U \cdot \Delta T_{REB}}$$

$$A_{REB} = 2.062 \times 10^3 \text{ ft}^2$$

The material of construction of the shell side and the tube side is carbon steel, thus

$$FM := 0.0 + \left(\frac{AREB}{100} \right)^{0.0}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure based on the shell side pressure in psig is calculated as follows:

$$PHEX := 1.1 \quad \text{bar}$$

$$PHEX_{\text{Shell}} := PHEX \cdot 14.5 - 14.7$$

$$PHEX_{\text{Shell}} = 1.25 \quad \text{psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHEX_{\text{Shell}}}{100} \right) + 0.0017 \left(\frac{PHEX_{\text{Shell}}}{100} \right)^2$$

$$FP = 0.981$$

The heat exchanger is of floating head type:

$$CBREB := \exp \left[11.667 - 0.8709 \ln(AREB) + 0.09005 (\ln(AREB))^2 \right]$$

The purchase cost of the heat exchanger is:

$$Cp_{REB} := FP \cdot FM \cdot FL \cdot CBREB \left(\frac{CE2}{CE1} \right)$$

$$Cp_{REB} = 3.554 \times 10^4 \quad \$$$

Distillation Column:

Column diameter: $D_i := 13.1 \text{ ft}$

Number of trays: $N_t := 23$

Tray spacing: $T_s := 2 \text{ ft}$

Length of column expect the heads:

$$L := N_t \cdot T_s$$

$$L = 46 \text{ ft}$$

Density of carbon steel:

$$\text{density} := 490 \frac{\text{lb}}{\text{ft}^3}$$

Since the operating pressure of column is between 0 and 5 psig, the design pressure is:

$$P_d := 10 \text{ psig}$$

The operating temperature of the column is 180 F, thus the design temperature is:

$$T_d := 230 \text{ F}$$

For SA-387B which is a commonly used low-alloy (1%Cr and 0.5% Mo) steel for

non-corrosive environment including the presense of hydrogen, operating at this

design temperature the maximum allowable stress is:

$$S := 15000 \text{ psi}$$

For carbon steel the value of welding efficiency is:

$$E := 0.85$$

Based on the above values, the cylindrical shell wall thickness is computed from ASME pressure-vessel code as follows:

$$t_p := \frac{P_d \cdot D_i \cdot 12}{2 \cdot S \cdot E - 1.2 \cdot P_d}$$

$$t_p = 0.062 \text{ inch}$$

Since the operational pressure is low, this thickness is small to give sufficient rigidity to column, according to column diameter the following wall thickness is used:

$$t_p := \frac{5}{16} \text{ inch}$$

The weight of the shell and the two heads is approximately:

$$W := \pi \cdot \left(D_i + \frac{t_p}{12} \right) \cdot (L + 0.8 \cdot D_i) \cdot \frac{t_p \cdot \text{density}}{12}$$

$$W = 2.972 \times 10^4 \text{ lb}$$

since the material of construction is carbon steel:

$$FM := 1.0$$

$$Cv := \exp\left[7.0374 + 0.18255 \ln(W) + 0.02297 (\ln(W))^2\right]$$

$$Cpl := 237.1 \cdot (Di)^{0.63316} \cdot (L)^{0.80161}$$

Thus, the cost of the column including nozzles, manholes, a skirt, internals, platforms, and ladders is:

$$CP := FM \cdot Cv + Cpl$$

$$CP = 1.113 \times 10^5 \quad \$$$

The cost of trays should be included:

The number of trays is greater than 20: $Fnt := 1.0$

Valve tray is used: $Ftt := 1.18$

The material of construction of trays is carbon steel: $Ftm := 1.0$

$$Cbt := 369 \cdot \exp(0.1739 Di)$$

Thus the cost of trays is:

$$Ct := Nt \cdot Fnt \cdot Ftt \cdot Ftm \cdot Cbt$$

$$Ct = 9.772 \times 10^4 \quad \$$$

The total cost of distillation column, including trays and internals is:

$$CpDIS := (CP + Ct) \cdot \left(\frac{CE2}{CE1}\right)$$

$$CpDIS = 2.356 \times 10^5 \quad \$$$

Endo Reactor:

Since the waste water temperature is lower than the process stream temperature in the endo reactor, low pressure steam with equivalent energy content as waste water has been considered as the energy resource for the endothermic reaction. Moreover, the reactor is considered to be a shell-tube heat exchanger:

$$\text{Shell side (steam) : } T_{\text{steam}} := 399.8 \text{ K} \quad T_{\text{feeddis1}} := 336.58 \text{ K}$$

$$\text{Tube side : } T_{\text{feedendo}} := 358.19 \text{ K}$$

$$\Delta T_{\text{ENDREAC}} := T_{\text{steam}} - \left(\frac{T_{\text{feedendo}} + T_{\text{feeddis1}}}{2} \right)$$

$$\Delta T_{\text{ENDREAC}} = 52.43 \text{ K}$$

$$Q_{\text{ENDREAC}} := 2.326 \times 10^6 \text{ Watt}$$

According to Coulson & Richardson [3], the heat coefficient is:

$$U := 1000 \frac{\text{Watt}}{\text{m}^2 \cdot \text{K}}$$

thus, the heat exchanger area is:

$$A_{\text{ENDREAC}} := \frac{Q_{\text{ENDREAC}}}{U \cdot \Delta T_{\text{ENDREAC}}}$$

$$A_{\text{ENDREAC}} = 477.529 \text{ ft}^2$$

The material of construction of the shell side and the tube side is carbon steel, thus

$$FM := 0.0 + \left(\frac{A_{\text{ENDREAC}}}{100} \right)^{0.0}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure based on the shell side pressure in psig is calculated as follows:

$$P_{\text{HEX}} := 1.16 \text{ bar}$$

$$P_{\text{HEXShell}} := P_{\text{HEX}} \cdot 14.5 - 14.7$$

$$P_{\text{HEXShell}} = 2.12 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHEXShell}{100} \right) + 0.0017 \left(\frac{PHEXShell}{100} \right)^2$$

$$FP = 0.981$$

The heat exchanger is of floating head type:

$$CBENDREAC := \exp \left[11.667 - 0.8709 \ln(AENDREAC) + 0.09005 (\ln(AENDREAC))^2 \right]$$

The purchase cost of the endo reactor is:

$$CpENDREAC := FP \cdot FM \cdot FL \cdot CBENDREAC \left(\frac{CE2}{CE1} \right)$$

$$CpENDREAC = 2.064 \times 10^4 \quad \$$$

Exo Reactor:

The reactor is considered to be a shell-tube heat exchanger:

$$\text{Shell side :} \quad T_{feedexo} := 460.07 \text{ K} \quad T_{exoout} := 473.1 \text{ K}$$

$$\text{Tube side (clean water) :} \quad T_{cleanwin} := 333.1 \text{ K} \quad T_{cleanwout} := 335.36 \text{ K}$$

$$\Delta T_{EXOREAC} := \frac{[(T_{exoout} - T_{feedexo}) - (T_{cleanwout} - T_{cleanwin})]}{\ln \left[\frac{(T_{exoout} - T_{feedexo})}{(T_{cleanwout} - T_{cleanwin})} \right]}$$

$$\Delta T_{EXOREAC} = 6.12 \text{ K}$$

$$Q_{EXOREAC} := 1.789 \times 10^6 \text{ Watt}$$

According to Coulson & Richardson [3], the heat coefficient is:

$$U := 600 \frac{\text{Watt}}{\text{m}^2 \cdot \text{K}}$$

thus, the heat exchanger area is:

$$A_{EXOREAC} := \frac{Q_{EXOREAC} \cdot 10.764}{U \cdot \Delta T_{EXOREAC}}$$

$$A_{EXOREAC} = 5.244 \times 10^3 \text{ ft}^2$$

The material of construction of the shell side and the tube side is carbon steel, thus

$$FM := 0.0 + \left(\frac{AEXOREAC}{100} \right)^{0.0}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure based on the shell side pressure in psig is calculated as follows:

$$PHEX := 1.15 \text{ bar}$$

$$PHEX_{Shell} := PHEX \cdot 14.5 - 14.7$$

$$PHEX_{Shell} = 1.975 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PHEX_{Shell}}{100} \right) + 0.0017 \left(\frac{PHEX_{Shell}}{100} \right)^2$$

$$FP = 0.981$$

The heat exchanger is of floating head type:

$$CBEXOREAC := \exp \left[11.667 - 0.8709 \ln(AEXOREAC) + 0.09005 (\ln(AEXOREAC))^2 \right]$$

The purchase cost of the endo reactor is:

$$C_{pEXOREAC} := FP \cdot FM \cdot FL \cdot CBEXOREAC \left(\frac{CE2}{CE1} \right)$$

$$C_{pEXOREAC} = 6.152 \times 10^4 \text{ \$}$$

Pump:

Centrifugal pump is selected because all the requirements in terms of volumetric flow rate, developed head and NPSH are met.

$$Q := 7.91 \times 10^3 \quad \text{gpm}$$

$$\text{NPSH} := 116.28 \quad \text{ft}$$

$$H := 259.04 \quad \text{ft}$$

$$S := Q \cdot (H)^{0.5}$$

$$S = 1.273 \times 10^5 \quad \text{gpm} \cdot \text{ft}^{0.5}$$

The material of construction is cast iron, thus:

$$\text{FM} := 1.0$$

The type of pump is 1 stage radial centrifugal pump (HSC) with 3600 shaft rpm, thus:

$$\text{FT} := 1.70$$

$$\text{CBPUMP} := \exp(9.2951 - 0.6019 \ln(S) + 0.0519 \ln(S)^2)$$

$$\text{CpPump} := \text{FT} \cdot \text{FM} \cdot \text{CBPUMP} \left(\frac{\text{CE2}}{\text{CE1}} \right)$$

The cost of electric motor for pump is calculated as follows:

Pump brake horsepower: $\text{PB} := 650.08 \quad \text{hp}$

$$\eta_m := 0.80 + 0.0319 \ln(\text{PB}) - 0.00182 (\ln(\text{PB}))^2$$

$$\text{PC} := \frac{\text{PB}}{\eta_m}$$

The motor type of "Totally enclosed, fan-cooled enclosure" with 3600 rpm is selected, thus the type factor for the electric motor is:

$$\text{FTmotor} := 1.4$$

$$\text{CBMOTOR} := \exp[5.4866 + 0.13141 \ln(\text{PC}) + 0.053255 (\ln(\text{PC}))^2 + 0.028628 (\ln(\text{PC}))^3 - 0.0035549 (\ln(\text{PC}))^4]$$

$$\text{CpMotor} := \text{FTmotor} \cdot \text{CBMOTOR} \left(\frac{\text{CE2}}{\text{CE1}} \right)$$

$$\text{CpPumpTotal} := \text{CpPump} + \text{CpMotor}$$

$$\text{CpPumpTotal} = 6.267 \times 10^4 \quad \$$$

A spare pump needs to be added.

Fired Heater:

The cost of the fired heater depends on absorbed heat. Since the operational pressure is not too high and the material of construction is carbon steel, there is no need to apply any correction factor.

This fired heater is designed in such a way to cope with the fluctuations in the winter time. Furthermore, the flue gas heat exchanger and the furnace are combined:

$$Q_{\text{Furnace}} := 3.554 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$Q_{\text{FGHX}} := 1.449 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

$$Q_{\text{duty}} := Q_{\text{FGHX}} + Q_{\text{Furnace}}$$

$$Q_{\text{duty}} = 5.003 \times 10^8 \frac{\text{Btu}}{\text{hr}}$$

Pressure factor: FP := 1

Material Factor: FM := 1

$$CB_{\text{FIRHEAT}} := 0.512 (Q_{\text{duty}})^{0.81}$$

$$C_{\text{pFIRHEAT}} := FP \cdot FM \cdot CB_{\text{FIRHEAT}} \left(\frac{CE2}{CE1} \right)$$

$$C_{\text{pFIRHEAT}} = 6.421 \times 10^6 \quad \$$$

Heat Exchanger District 1:

Area of the HXDIS1: $A_{HXDIS1} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel, thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS1}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$P_{HXDIS1Shell} := 170.98 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HXDIS1Shell}}{100} \right) + 0.0017 \left(\frac{P_{HXDIS1Shell}}{100} \right)^2$$

$$FP = 1.016$$

The heat exchanger is of floating head type:

$$CB_{HXDIS1} := \exp \left[11.667 - 0.8709 \ln(A_{HXDIS1}) + 0.09005 (\ln(A_{HXDIS1}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS1} := FP \cdot FM \cdot FL \cdot CB_{HXDIS1} \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS1} = 1.571 \times 10^5 \$$$

Heat Exchanger District 2:

Area of the HXDIS2: $AH_{XDIS2} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel, thus:

$$FM := 0.00 + \left(\frac{AH_{XDIS2}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PH_{XDIS2Shell} := 168.113 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PH_{XDIS2Shell}}{100} \right) + 0.0017 \left(\frac{PH_{XDIS2Shell}}{100} \right)^2$$

$$FP = 1.015$$

The heat exchanger is of floating head type:

$$CB_{HXDIS2} := \exp \left[11.667 - 0.8709 \ln(AH_{XDIS2}) + 0.09005 (\ln(AH_{XDIS2}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS2} := FP \cdot FM \cdot FL \cdot CB_{HXDIS2} \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS2} = 1.57 \times 10^5 \text{ \$}$$

Heat Exchanger District 3:

Area of the HXDIS3: $A_{HXDIS3} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS3}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$P_{HXDIS3Shell} := 127.73 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HXDIS3Shell}}{100} \right) + 0.0017 \left(\frac{P_{HXDIS3Shell}}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CB_{HXDIS3} := \exp \left[11.667 - 0.8709 \ln(A_{HXDIS3}) + 0.09005 (\ln(A_{HXDIS3}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS3} := FP \cdot FM \cdot FL \cdot CB_{HXDIS3} \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS3} = 1.555 \times 10^5 \text{ \$}$$

Heat Exchanger District 4:

Area of the HXDIS4: $A_{HXDIS4} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{A_{HXDIS4}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$P_{HXDIS4Shell} := 127.10 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{P_{HXDIS4Shell}}{100} \right) + 0.0017 \left(\frac{P_{HXDIS4Shell}}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CB_{HXDIS4} := \exp \left[11.667 - 0.8709 \ln(A_{HXDIS4}) + 0.09005 (\ln(A_{HXDIS4}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS4} := FP \cdot FM \cdot FL \cdot CB_{HXDIS4} \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS4} = 1.555 \times 10^5 \text{ \$}$$

Heat Exchanger District 5:

Area of the HXDIS5: $AH_{XDIS5} := 1.676 \times 10^4 \text{ ft}^2$

The material of construction of the shell side and the tube side is carbon steel thus:

$$FM := 0.00 + \left(\frac{AH_{XDIS5}}{100} \right)^{0.00}$$

$$FM = 1$$

The tube length was assumed to be 12 ft, thus:

$$FL := 1.12$$

The pressure factor based on the shell side pressure in psig is calculated as follows:

$$PH_{XDIS5Shell} := 127.4 \text{ psig}$$

$$FP := 0.9803 + 0.018 \left(\frac{PH_{XDIS5Shell}}{100} \right) + 0.0017 \left(\frac{PH_{XDIS5Shell}}{100} \right)^2$$

$$FP = 1.006$$

The heat exchanger is of floating head type:

$$CB_{HXDIS5} := \exp \left[11.667 - 0.8709 \ln(AH_{XDIS5}) + 0.09005 (\ln(AH_{XDIS5}))^2 \right]$$

The purchase cost of the heat exchanger is:

$$C_{pHXDIS5} := FP \cdot FM \cdot FL \cdot CB_{HXDIS5} \left(\frac{CE2}{CE1} \right)$$

$$C_{pHXDIS5} = 1.555 \times 10^5 \$$$

Total Purchase Cost:

$$\text{SUM1} := \text{CpBlower} + \text{CpAIRBlower} + \text{CpHEX} + \text{CpREB} + \text{CpCONE}$$

$$\text{SUM2} := \text{CpDIS} + \text{CpFIRHEAT} + 2\text{CpPumpTotal} + \text{CpENDREAC} + \text{CpEXOREAC}$$

$$\text{SUM3} := \text{CpHXDIS1} + \text{CpHXDIS2} + \text{CpHXDIS3} + \text{CpHXDIS4} + \text{CpHXDIS5}$$

$$\text{CpTOTAL} := \text{SUM1} + \text{SUM2} + \text{SUM3}$$

$$\text{CpTOTAL} = 8.344 \times 10^6 \quad \$$$

References

- 1- W. D. Seider, J.D. Seader, D.R. Lewin, "Product & Process Design Principles", John Wiley and Sons, Inc., 2004.
- 2- Economic Indicators (July 2005): www.CHE.COM
- 3- R.K. Sinnott, "Coulson & Richardson's Chemical Engineering", Vol 6, Butterworth-Heinemann Publisher, Oxford.

Appendix 32 Total Investment of Chemical Heat Pump


Description	Fraction	Amount
Total investment		\$ 27,155,950
<u>Fixed capital</u>	1.00	\$ 22,510,121
<u>Direct costs</u>	0.79	\$ 17,715,466
<u>Onsite costs</u>		\$ 14,732,874
Purchased equipment	0.37	\$ 8,340,000
Purchased-equipment installation	0.17	\$ 3,747,935
Instrumentation and control	0.05	\$ 1,069,231
Piping UU	0.04	\$ 900,405
Electrical equipment and materials	0.03	\$ 675,304
<u>Offsite costs</u>		\$ 2,982,591
Buildings	0.03	\$ 675,304
Yard improvement	0.03	\$ 731,579
Service facilities	0.04	\$ 900,405
Land	0.03	\$ 675,304
<u>Indirect costs</u>	0.21	\$ 4,794,656
Engineering and supervision	0.08	\$ 1,800,810
Construction expenses	0.05	\$ 1,080,486
Contractor's fee	0.03	\$ 562,753
Contingency	0.06	\$ 1,350,607
<u>Working capital</u>		\$ 1,357,797
Raw material, finished products, accounts receivable, cash on hand, account payable and taxes payable 15% of total capital investment.	0.05	\$ 1,357,797
<u>Costs for transport piping</u> *		\$ 16,953,225
<u>One time revenues (minus)</u>		-\$ 13,665,194
<u>Start-up costs</u>		\$ 1,350,607
Process modifications, start-up labor, loss in production	0.06	\$ 1,350,607

Prices from (NAP prijzenboekje 20e editie februari 1999)		
The price for total steel underground transport pipelines are (1999)(16inch):	440	€ /m
The material price for under ground steel transport pipes (DN350), included average discount of 45%	88	€ /m
Price for laying the pipes:	352	€ /m
Index correction of 4 % per year:	445	€ /m
Prices for the pipes (by Marcel Verboven, Weijers-Waalwijk BV)		
DN350 – 355,6x5,6 / 500 (staal – PUR – PE) Standaard PUR schuim	117.68	€ /m
DN350 – 355,6x5,6 / 500 (staal – PUR – PE) MicroPUR schuim	156.98	€ /m
In the first case we used Standaard PUR, resulting at a length of 21 km in:	11,824,518	€
Including tax	\$	16,953,225

Appendix 33 Production Cost of Chemical Heat Pump

	Water	Natural Gas	Electricity	Cooling water
price	1.28 euro/m ³	0.18 euro/m ³	0.1 euro/kWh	0.0041885 euro/kWh
BTW	1.06	1.19	1.19	1.19
tax	0.146 euro/m ³	0.01 euro/m ³	0.0086 euro/kWh	
km				
V pipe 16 inch	1868	28,705 MJ/h	374 kW	condenser
V pipe 14 inch	598	7,932,456 m ³ /y	378 kW	
		120,000 ft ³ /h	53 kW	
		29,766,620 m ³ /y		
total amount/year	2,464 m ³	47,123,846 m ³	7,055,488 kWh	76105128 kWh
costsly	€ 3,703	€ 10,665,186	€ 900,280	€ 379,332
total costsly	€ 11,469,149			
	\$ 13,691,237			
1m ³ gas	31.7MJ			
exchange course:	0.8377euro for 1 dollar			

Appendix 34 T-xy Diagram for Acetone-Isopropanol




Appendix 35 Utility Cost

EQUIPMENT		SUMMARY OF UTILITIES												REMARKS		
		HEATING						COOLING							POWER	
Nr.	Name	Load		Consumption (t/h)		Hot	Cooling Load	Consumption (t/h)		Air	Water	Actual Load	Consumption (t/h, kWh/h)		Remarks	
		KW	MP	LP	MP			HP	HP				MP	Electric		
K 01	Compressor 1										691			691		
K 02	Compressor 2										946			946		
P 01	Clean water pump										67			67		
K 03	Blower										367			367		
TOTAL		0	0	0	0	0	0	0	0	0	0	2071	0	0	2071	
Project ID Number : CPD3328 Completion Date : 3-Dec-05																

Appendix 36 Team Photograph






Process Equipment Summary	
E01 : Ammonia Evaporator	K02 : Second Ammonia Compressor
E02 : Intercooler	V01 : Ammonia Collector Vessel
E03 : Ammonia Condenser	
K01 : First Ammonia Compressor	

Designers
P.W.C. Falcao
A. Mesbah
M.V. Suherman
S. Wennekes

Process Flow Scheme	
Project	: Design of A District Heating System Including The Upgrading of Residual Industrial Waste-Heat
Proj. ID Number	: CPD3328
Completion Date	: December 13 th , 2005
○ Stream number	□ Temp. (K) ○ Pressure (Bara)



Process Equipment Summary

- F01** : Furnace
- K01** : Air Blower
- P01** : Clean Water Pump


Designers

- P.W.C. Falcao**
- A. Mesbah**
- M.V. Suherman**
- S. Wennekes**

Process Flow Scheme

- Project : Design of A District Heating System Including The Upgrading of Residual Industrial Waste-Heat
- Proj. ID Number : **CPD3328**
- Completion Date : December 13th, 2005

Stream number
 Temp. (K)
 Pressure (Bara)



Process Equipment Summary			
E04 : Heat Exchanger I	E07 : Heat Exchanger IV		
E05 : Heat Exchanger II	E08 : Heat Exchanger V		
E06 : Heat Exchanger III	CG : Central Grid		

Designers
P.W.C. Falcao
A. Mesbah
M.V. Suherman
S. Wennekes

Process Flow Scheme	
Project	: Design of A District Heating System Including The Upgrading of Residual Industrial Waste-Heat
Proj. ID Number	: CPD3328
Completion Date	: December 13 th , 2005
○	Stream number
□	Temp. (K)
○	Pressure (Bara)