



Integrated Facade System in High Rise Office Buildings *in Tropical Climate Condition*


Melissa Krisanti Tanuharja
4326989

Mentors
Ir. Eric van den Ham
Ir. Arie Bergsma
MSc. Alejandro Prieto Hoces

Building Technology Track
Graduation studio



Responsible for 40% of the global primary energy consumption




Energy Consumption in Office Buildings

“To what extent building strategies can be integrated as facade system which able to reduce cooling energy demand in high rise office buildings in hot and humid tropical climate condition?”

PARAMETERS **REDUCTION**
on cooling load demand **COMFORT**
level **CONSTRUCTION**
feasibility

TOOLS **LITERATURE**
studies **BUILDING**
simulation **ENERGY**
calculation




END PROCESS **FINAL**
product

CLIMATE
condition

World Map of Köppen–Geiger Climate Classification

updated with CRU TS 2.1 temperature and VASCLimov v1.1 precipitation data 1951 to 2000



Main climates


- A: equatorial
- B: arid
- C: warm temperate
- D: snow
- E: polar

Precipitation

- W: desert
- S: steppe
- f: fully humid
- s: summer dry
- w: winter dry
- m: monsoonal

Temperature

- h: hot arid
- k: cold arid
- a: hot summer
- b: warm summer
- c: cool summer
- d: extremely continental
- F: polar frost
- T: polar tundra



<http://gpcc.dwd.de>
<http://koepfen-geiger.vu-wien.ac.at>


Kottke, M.,
 J. Grieser, C. Beck,
 B. Rudolf, and F. Rubel,
 2006: World Map of Köppen–
 Geiger Climate Classification
 updated. *Meteorol. Z.*, 15, 259-263.

Monsoon window

- Air temperature drop when its raining (to 24°C-27°C)
- Allows the outdoor air flows when its raining outside

Roof and eave

- Rainwater runs off faster
- Shade the building from direct sun radiation



Sun shading device

cover the whole facade area

Layout configuration

create shading on each floor

Sun shading device

follow the sun path



Full glazed facade

Low-e double glass unit

Full glazed facade

Low-e coated glass



Jakarta

climate data

	Temperature (°C)				Average Precipitation (mm)	Average Sunlight (hours)	Wet Days (+0.1 mm)	Relative Humidity (%)			Monthly Ave. Clear Sky (days)
	Average		Record					AM	PM	Average	
	Min	Max	Min	Max							
Jan	23	29	21	34	300	5	18	95	75	80.4	1
Feb	23	29	21	33	300	5	17	95	75	81	2
Mar	23	30	21	33	211	6	15	94	73	80.3	4
Apr	24	31	21	34	147	7	11	94	71	79.8	4
May	24	31	21	34	114	7	9	94	69	80	2
Jun	23	31	19	34	97	7	7	93	67	79.6	1
Jul	23	31	19	33	64	7	5	92	64	79.1	2
Aug	23	31	19	34	43	8	4	90	61	79.1	1
Sep	23	31	19	36	66	8	5	90	62	79.3	1
Oct	23	31	21	37	112	7	8	90	64	81.9	1
Nov	23	30	20	36	142	6	12	92	68	82.5	1
Dec	23	29	19	34	203	5	14	92	71	80.5	0
Ave.	23.2	30.3	20.1	34.3	149.9	6.5	10.4	92.6	68.3	80.3	1.7

Adaptive thermal comfort

in office building in Jakarta

Neutral Temperature

$$T_{operative} = 26.70^{\circ}\text{C}$$

Comfort Range

$$T_{operative} = 23.50^{\circ}\text{C} - 29.90^{\circ}\text{C}$$

PSYCHROMETRIC CHART California Energy Code

LOCATION: DTM Universitas Indonesia, Jawa Barat, IDN
 Latitude/Longitude: 6.363° South, 106.824° East, Time Zone from Greenwich 7
 Data Source: MN6 999 WMO Station Number, Elevation 60 m


LEGEND

COMFORT INDOORS
 100% ■ COMFORTABLE
 0% ■ NOT COMFORTABLE

DESIGN STRATEGIES: JANUARY through DECEMBER

- 0.0% 1 Comfort(0 hrs)
- 60.9% 2 Sun Shading of Windows(2447 hrs)
- 3 High Thermal Mass(0 hrs)
- 0.2% 4 High Thermal Mass Night Flushed(9 hrs)
- 5 Direct Evaporative Cooling(0 hrs)
- 6 Two-Stage Evaporative Cooling(0 hrs)
- 7 Natural Ventilation Cooling(0 hrs)
- 3.4% 8 Fan-Forced Ventilation Cooling(135 hrs)
- 9 Internal Heat Gain(0 hrs)
- 10 Passive Solar Direct Gain Low Mass(0 hrs)
- 11 Passive Solar Direct Gain High Mass(0 hrs)
- 12 Wind Protection of Outdoor Spaces(0 hrs)
- 13 Humidification Only(0 hrs)
- 14 Dehumidification Only(0 hrs)
- 96.4% 15 Cooling, add Dehumidification if needed(3871 hrs)
- 16 Heating, add Humidification if needed(0 hrs)

100.0% Comfortable Hours using Selected Strategies
 (4014 out of 4015 hrs)



PLOT: COMFORT INDOORS

Hourly Daily Min/Max

All Hours Selected Hours

8 a.m. through 6 p.m.

All Months Selected Months

JAN through DEC

One Month JAN Next Month

One Day 1 Next Day

One Hour 8 a.m. Next Hour


TEMPERATURE RANGE:

-10 to 40 °C Fit to Data

Display Design Strategies

Show Best set of Design Strategies

BUILDING
strategies



Floor to ceiling height	= 3.2	m
Orientation	= West	
Room volume	= 55.30	m ³
Room floor area	= 17.28	m ²
Indoor set point temperature	= 26.7	°C
Indoor set point RH%	= 60	%

PASSIVE WAY **SUN SHADING**
device system

ACTIVE WAY **DEHUMIDIFICATION** **INDIRECT EVAPORATIVE**
system cooling system

TOOLS **LITERATURE** **BUILDING** **ENERGY**
studies simulation calculation

RESULT **INTEGRATED**
facade system

PASSIVE WAY

PARAMETERS

PERFORMANCE

- Reduction on cooling load in the space inside
- Shading performance

INTEGRATION

- Able to be integrated with other systems
- Possible dimension and shape

COMFORT

- Daylight factor
- Illuminance

Improvement in the numbers of comfort hours
(egg crate type)



26%

Reduction on heat impact


1/3

Olgay, V. (1962). Design with climate-bioclimate approach to architectural regionalism


S. Fadzil & N. Al-Tamimi (2011). The Potential of Shading Devices for Temperature reduction in high rise residential buildings in the tropic



1





2




3

Optimized shading device surrounding shade with verticals



ACTIVE WAY



Indirect evaporative cooling unit

Dehumidification unit

DESICCANT DEHUMIDIFICATION

attract moisture from the air by creating an area of low surface vapor pressure at the surface of the desiccant

PARAMETERS

PERFORMANCE


- Reduction on relative humidity inside the space
- Energy sources

INTEGRATION


- Possible integration with cooling system
- Possible integration in the facade system

APPLICABILITY

- Desiccant material
- Working principle
- Possible dimension and size



J. Woods & E. Kozubal (2011). Desiccant Enhanced Evaporative Air Conditioning. NREL.



MATERIAL

SOLID

silica gel

LIQUID

- Triethylene Glycol (TEG)
- Calcium Chloride (CaCl_2)
- Lithium Chloride (LiCl)

SYSTEM

HYBRID

- Vapor Compression System
- Vapor Absorption System

STAND ALONE

- Spray Tower
- Packed Bed Tower
- Wetted Wall Column

SOURCE

NATURAL GAS

ELECTRICITY

SOLAR ENERGY

- PV Panel
- Solar Thermal Collector

LIQUID
desiccant

Calcium Chloride (CaCl₂)

- more data in literature about its material properties are available
- cheaper than TEG and LiCl for its moisture absorption and low corrosive

STAND ALONE
system

Spray

- low cost
- compact size
- low effectiveness

Packed Bed

- compact size
- high effectiveness
- health and corrosion issues
- unable to be integrated with cooling system

Wetted Wall

- high effectiveness
- no health and corrosion issues
- easier maintenance
- able to be integrated with cooling system

Solar
source

Solar Thermal Collector


- the most efficient
- proven by several built references

Wetted wall (falling films) column principle

3 regenerator unit


2 liquid desiccant media

1 intake air hot and humid air







DEHUMIDIFICATION SYSTEM

— liquid desiccant (solution)
→ warm and humid air





Intake air

hot and humid air




○ Indoor Air
● Outdoor Air



Liquid desiccant

media



Calculation

TEMPERATURE

30.3°C

outdoor max ave. temperature

26.7°C

indoor comfort temperature

RELATIVE HUMIDITY

80%

outdoor ave. relative humidity

60%

indoor relative humidity

9.47 g/m³

moisture to be removed

ROOM DATA

55.30 m²

room volume

0.05 m³/s

air change rates

38.02 litres/day


total moisture removal

(for 100% indoor dehumidification 1/4 less)

56.17 litres/day

total volume of liquid desiccant needed

(for 100% indoor dehumidification 1/4 less)



height = 1.50 m²

volume = 0.000471 m³

176 tubes

total tubes to be provided

Regenerator unit


PARAMETERS

PERFORMANCE

Able to provide thermal energy to regenerate the liquid desiccant



APPLICABILITY

Ideal location





with sun shading device

as louvre



cross section



Calculation

DEHUMIDIFICATION SYSTEM

SURFACE AREA **1.97 m²**
per facade module

LIQUID DESICCANT


38.02 litres/day
to be regenerated

24.49 kWh/day

(for 100% indoor dehumidification 1/4 less)

to evaporate 38.02 liters of liquid desiccant

12.43 kWh/m².day
need to be provided



2.48 kWh/m².day
able to be provided

(for 100% indoor dehumidification it can covers 1/3 of the required energy)

1/5
of the total required energy

INDIRECT EVAPORATIVE COOLING

reduce the dry bulb air temperature without adding more moisture in the supply air

PARAMETERS

PERFORMANCE


Comparable to normal vapor compression system



INTEGRATION

- Possible integration with dehumidification system
- Possible integration in the facade system

APPLICABILITY

- Working principle
- Possible dimension and size





(with assumption efficiency of 60%)

30.3°C drop to 26.52°C

Dehumidification
Indirect Evaporative Cooling



System principle


INDIRECT EVAPORATIVE COOLING

3 outtake air
cool and dry air

2 indirect evaporative cooling
media

1 intake air
hot and dry air





FACADE

integration

PASSIVE WAY **SUN SHADING**
device system

ACTIVE WAY **DEHUMIDIFICATION** **INDIRECT EVAPORATIVE**
system cooling system

TOOLS **LITERATURE** **BUILDING** **ENERGY**
studies simulation calculation


RESULT **INTEGRATED**
facade system


sun shading system

dehumidification and indirect evaporative cooling unit


monsoon window

regenerator unit







Intake air optional system



MODULE SYTSEMS




MODULE A




Reduce the risk of a mix intake air between outdoor air and humid air from evaporation

- Indoor Air
- Outdoor Air



MODULE B





COMPC


Sun shading

Visible


Opaque









- 1 Aluminum profile for egg-crate sun shading device
- 2 Aluminum mullion profile with connection to the sun shading profile
- 3 Regenerator unit with evacuated tube solar collector
- 4 Double glass unit (8mm + 12mm air gap + 6mm)
- 5 Opaque aluminum panel
- 6 Aluminum mullion profile
- 7 Dehumidifier unit with permeable tubes
- 8 Aluminum mullion profile
- 9 Aluminum transom profile
- 10 Pipe to and from heat exchanger for cool water
- 11 Opaque aluminum panel




DETAILS







- 1 Double glass unit (8mm + 12mm air gap + 6mm)
- 2 Aluminium mullion profile
- 3 Aluminium mullion profile cap
- 4 Opaque panel 8mm
- 5 Aluminium transom profile
- 6 Adjustable aluminium grill for dehumidification intake air (monsoon window)



- 1 Opaque panel 8mm
- 2 Microporous polypropylene tube
- 3 Aluminium grill for outtake air to indoor space
- 4 Aluminium mullion profile
- 5 Double glass unit (8mm + 12mm air gap + 6mm)
- 6 Regenerator unit
- 7 Sun shading louver
- 8 Aluminium profile for sun shading panel



- 1 Aluminium transom profile
- 2 Aluminium grill for outtake air to indoor space
- 3 Opaque panel 8mm (inner pane)
- 4 Microporous polypropylene tube
- 5 Opaque panel 8mm (outer pane)




- 1 Double glass unit (8mm + 12mm air gap + 6mm)
- 2 Aluminium transom profile
- 3 Double glass unit (8mm + 12mm air gap + 6mm)
- 4 Aluminium transom profile
- 5 Aluminium composite panel
- 6 Aluminium transom cap profile

ASSEMBLY PROCESS


Component 1

assembly process


1



2




3



Component 2


assembly process

1




- vertical connection lock
- aluminum transom profile
- aluminum mullion profile
- intake air grill (monsoon window)

2




- aluminum composite panel
- indirect evaporative cooling unit
- opaque panel
- dehumidification unit

3



Component 3

assembly process








Pre-assembled

manufacture and transportation

1

2

3




On-site

bracket fixing

1

2


3




On-site

assembly process


1




2




3







Building Maintenance Unit
Compact Crane Type
adaptable to non-flat building
max.reach of 6.5m




2 OUTDOOR

Maintenance

process

1 INDOOR



SIMULATION AND CALCULATION

analysis

PASSIVE WAY **SUN SHADING**
device system

ACTIVE WAY **DEHUMIDIFICATION** **INDIRECT EVAPORATIVE**
system cooling system

TOOLS **LITERATURE** **BUILDING** **ENERGY**
studies simulation calculation

RESULT **INTEGRATED**
facade system

ENERGY CALCULATION

2 | Fan (2 units)
(18.4 W)

4 | Dehumidifier unit
(289.20 W)

Energy required
integrated facade

1 | Facade heat transfer
(199.07 W)

3 | Pump (2 units)
(90 W)

5 | Cooled water
(1.48 W)

(2041.49 Btu/h)

$$H_{\text{facade}} + H_{\text{fan}} + H_{\text{pump}} + H_{\text{dehumidifier}} + H_{\text{cooled water}}$$

598.15 W

required energy for integrated facade

(6000 Btu/h)

1758.42 W

required energy for air conditioning

1/3

compared to required energy for air conditioning

BUILDING SIMULATION

CONDITION

Orientation

West

Simulation date

21 June

Working hours

08:00-18:00

Set point temperature

26.5°C

Set point %RH

60 %

Models





settings

1

2

3

4





	Model 1	Model 2	Model 3	Model 4
Sun Shading Device	Not Applied	Applied	Applied	Applied
Window to Wall Ratio	32%	32%	16%	32%
External Windows	Double clear glass (6mm/13mm air)	Double clear glass (6mm/13mm air)	Double clear glass (6mm/13mm air)	Double tinted glass (6mm/13mm air)
HVAC Template	Fan-coil unit	Fan-coil unit	None	None
Mechanical Ventilation	On	On	Off	Off


Summary




results

	Model 1	Model 2	Model 3	Model 4
Total Cooling Load (kW)	3.11	2.57	1.71	1.97
Annual Cooling Energy Demand (kWh/m ² .year)	218.97	180.95	120.40	138.71
Relative Humidity (%)	40.90	42.40	43.20	42.20
Max. Operative Temp. in Day (°C)	31.10	30.60	30.40	30.50
Average Daylight Factor (%)	3.74	2.01	0.89	2.01
Maximum Illuminance (lux)	2094.97	1401.09	1154.28	1313.22















CONCLUSION

	Option 0	Option 1	Option 2	Option 3	Option 4	Option 5
						
Sun Shading Device	applied	applied	applied	applied	applied	applied
Dehumidification	integrated in HVAC	applied	applied	applied	applied	applied
Indirect Evaporative Cooling	by vapor compression AC	applied	applied	applied	by vapor compression AC	by vapor compression AC
Regenerator Unit	not available	integrated (1/5)	integrated (1/5)	centralized	integrated (1/5)	centralized
Visual Comfort	+	-	+	+	+	+
Energy Performance	75% cooling energy demand	45% cooling load reduction	37% cooling load reduction	regeneration units require more space	better cooling performance	better cooling performance
		(better efficiency for DIEC)	(less efficiency for DIEC)	(less efficiency for DIEC)	(less efficiency for Dehumidification)	(less efficiency for Dehumidification)
Maintenance and Assembly	+++	-	-	+	-	++
Floor to Floor Height	> 4.5 m	≤ 4.5 m	≤ 4.5 m	4.5 m	> 4.5 m	> 4.5 m

There are several possible building strategies both active and passive way that are able to tackle the high cooling energy demand in high rise office building in hot and humid climate

The integration between strategies can be accomplished under several conditions and requirements which resulted in difference level of performance

CLIMATE

Cooling and dehumidification

96.4%

Sun shading devices

60.9%

BUILDING STRATEGIES

Egg crate sun shading device

efficient shape and dimension

Indirect evaporative cooling

add no moisture

Desiccant dehumidification

renewable energy sources


FACADE INTEGRATION

Visual comfort

daylight and glare

Construction

difficulties



More complex maintenance

More complex construction process

Higher initial cost

37-45% less work for main cooling unit

37-45% less size for main cooling unit

Lower operation cost

RECOMMENDATION

for further development


INTEGRATED FACADE SYSTEM


Physical Test

Cost Overview

Solar Source Efficiency

SOLAR SOURCE OPTIMIZATION






North Orientation


Average radiation
903.12 kWh/m²

Point a (meter)

x = 0.89

z = 0.87






South Orientation


Average radiation
896.52 kWh/m²

Point a (meter)

x = 0.98

z = 0.90






West Orientation

Average radiation
987.00 kWh/m²

Point a (meter)

x = 0.04

z = 1.00



THANK YOU