





***“So, ladies and gentlemen. Let’s act. Let’s act together. And let’s act now! “
-Mark Rutte, Prime Minister of The Netherlands***


Final energy use by sector in 28 EU countries



Building Sector




Services Sector



Office Sector

*(Eurostat, 2017)
(National Energy Foundation, 2016)*



45 %


45% of the offices in The Netherlands are older than **30 years**.



-50 %


Energy renovation can **reduce** the overall energy demand by **50%**.

*(Vijverberg, 2002)
(Saheb et al., 2015)*



Design principle NZEB: Trias Energetica

Only **7.8%** of the total final energy consumption in The Netherlands **use the energy generated from renewable sources.**



The **Earth, Wind and Fire concept (EWF)** can play a key intervention as it utilizes the environmental energy of **earth mass, wind and sun** to **generate and supply energy**.

Refurbishment of an office building in The Netherlands using the Earth, Wind and Fire system.

P5 | Shriya Balakrishnan



1st Mentor: Dr. R.M.J. Bokel (Building Physics and Services)

2nd Mentor: Dr. ing. T. Konstantinou (Building Product Innovation)

Research Advisors: Kitty Huijbers (ABT), Dr. Ben Bronsema & Provinciehuis Utrecht

*Research
Question*

Literature study

Analysis

Results

Conclusion

*Research
Question*

Literature study

Analysis

Results

Conclusion

*Research
Question*

Literature study

Analysis

Results

Conclusion

*Research
Question*

Literature study

Analysis

Results

Conclusion

*Research
Question*

Literature study

Analysis

Results

Conclusion

How are the **design strategies**, derived from the **Earth, Wind and Fire system**, implemented in the **refurbishment of an office building** in The Netherlands in order to **improve the energy performance**?

Problem Statement

Literature study

Analysis

Results

Conclusion

Delft Seminars in Building Technology
ARIA075 2014/15 - Q1

Tutors - Mauro Parravicini & Ben Bronsma

Natalia A. Valdes Cano / 4417933

EWF Adaptive Fire Facade

Small text describing the project context or location.

Add-on to existing structure



1. Existing structure Neufelst: The non-rectangular form of the Neufelst has an unconventional structural situation of columns and load-bearing walls on the facade.
2. Add Earth Wind Fire: Solar chimneys on Southern walls for sprayed suction throughout the day and climate cascades on the Northern walls.
3. Add solar energy: Use rest of the facade for generation of solar energy through rotating photovoltaic (PV) panels.

Rotating Photovoltaic Louvers




1. Generating electricity: Photovoltaic panels generate most electricity when they are placed on a perpendicular angle to the sun. Therefore they should be able to rotate with it. Panels on the Southern part of the building are able to generate a 200W/m² (TNO, 2014).
2. Shading: The louvers create external shading which keeps the heat out of the building, which will reduce the need for cooling. To a lesser degree, they are also able to reduce the amount of glare and noise.
3. Horizontal views: Users will be able to see wide horizontal views. Furthermore looking up and down will be a less degree possible.

Scenarios



- A. Default working mode: The louvers will not be rotated in the default mode. Instead users can experience the wide views while the amount of daylight stays at the maximum.
- B. Needs multiple users: The louvers respond to both the individual needs of the users as the mass one. Instead users can experience the wide views while the amount of daylight stays at the maximum.
- C. Non-working mode: During lunch, in the weekends and all the other times people are not using the space, the louvers will rotate according to the most perpendicular position towards the sun.

Angle Optimization



Strategy: The louvers will rotate in order to maximize the surface which hits the sun. The angle should be as perpendicular as possible. With Grasshopper 3D a simulation was built to analyze the rotation of the louvers. The weather data is derived from Autodesk ECOTECT Analysis software and is based on the yearly averages of Utrecht.


Adaptive Fire Facade

Small text describing the facade's adaptability.

Small text describing the facade's adaptability.

Small text describing the facade's adaptability.

Structure




Air supply and drainage




Fragment facade



The EWF ecosystem



Main elements





Site / Building Data





2030 Challenge



Design Theme





Earth - Wind - Fire Concept



Delft Seminars on Building Technology

Jasper Vos 1533649 (ARIA075) 2014/2015 Q1
Tutors: Mauro Parravicini, Ben Bronsma

OPENING UP THE OFFICE



(Brightspace, 2020)
























SOLAR CHIMNEY

Separate from the building

Connected to the building

In the facade

On the roof

 <p>Separate chimney's could function as sun shading device and to get more daylight into the building.</p>	 <p>A chimney could be designed like it bumped into the existing building. By combining it with an atrium the distribution of exhaust air could also be arranged.</p>	 <p>The niches in the building shape could be filled up with chimney. This doesn't make them very expressive but is effective from a climatic point of view by reducing the facade area.</p>	 <p>By adding a greenhouse on the roof of a building, air could be sucked out of the building due to the overpressure in the greenhouse.</p>
 <p>Reuse old material to construct the chimney. Put a small vented roof on top of the chimney to improve its performance.</p>	 <p>An expressive 'proboscis'-like chimney could be added to the building.</p>	 <p>The chimney could be expressed a bit in the facade by delicate changes in the shape of an extra facade layer.</p>	
 <p>A lot of small chimney's around the building would add character but compromise on its performance.</p>	 <p>The chimney's and supply/exhaust shunts could be made expressive/explicit in the shape of an extra facade layer that is wrapped around the building.</p>	 <p>The chimney('s) could be hidden behind an extra facade layer that is wrapped around the building.</p>	
 <p>One large separate chimney would have a better performance than a lot of small chimney's. Separation of the building would allow more daylight in the building.</p>	 <p>The collection of the exhaust air at the bottom of the building could be made expressive with big shunt channels that circle around the building.</p>	 <p>The chimney('s) could be hidden behind an extra facade layer that is wrapped around the building.</p>	
 <p>The diagrid structure could be emphasized with a swaying chimney and exhaust shunts in different directions around it.</p>	 <p>The diagrid structure could be emphasized with a swaying chimney and exhaust shunts in different directions around it.</p>	 <p>By creating a solar facade the building shape is kept the same but the building performance is improved.</p>	
 <p>Swaying chimney's around the building wouldn't compromise its performance but add more architectural identity. Add heat recovery on top incl. turbine to produce energy.</p>	 <p>Separate facade elements with difference characteristics (depths, material) could be designed for the different EWF elements.</p>	 <p>The chimney could be hidden in an extra facade layer but delicately emphasized by an orientation of glass facade sheets.</p>	
	 <p>A trapezium shaped chimney with integrated exhaust shunt could be should. The shape doesn't necessarily improve it's performance.</p>	 <p>Space for the chimney's could be created by making cut outs in the structure if the structure allows this.</p>	
	 <p>Whole floor elements could be removed to create an atrium with chimney's that stick out of the building.</p>	 <p>Space for the chimney could be created by cutting off a part of a corner of the structure if the structure allows this.</p>	


CLIMATE CASCADE			
In the building		In the facade	
	By making a cut out in the core of the building a space is created for the climate cascade. The inner ring is for the cascade, the outer ring for the supply of the air.		A cascade could be added built up from elements. The droplets inside the cascade could be visualised in the facade to emphasize its working principle.
	Also a cut out design but the supply air is distributed through the space via a raised floor. By making the cascade transparent a climatic architectural element is created.		Niches in the building could be filled up with climate cascade(s). In this way the amount of facade area is reduced which enhances the energy performance of a building.
	By surrounding the cascade with staircases the interaction of the cascade with building occupants is increased.		A smart skin could be used. In this way transparency is achieved without influencing the performance of the cascade.
	A round cut out might be more efficient for the load bearing structure. The supply shunt are accommodated in existing vertical shafts.		An entrance can be enhanced by placing the cascades around it. The addition of a print on a glass panel could work as sun shading and function as a communication tool.
	The cut out could create space for both the climate cascade as well as the vertical distribution shafts for supply air.		Space could be created by making a cut out in the facade. By using transparent surfaces in the facade the cascade is made explicit, but this design is subtle.
	By creating more climate cascade ... ADD TEXT ...		The cascade and the supply shaft could be visualised together by adding to 'towers' the the building that are connected at the bottom.
	The climate cascade could be emphasized by making it more expressive inside the building.		The cascade could be made visible from both the inside and outside. Louvers could be used to reduce the heat load on the transparent surfaces.
	The vertical installation shafts in the existing building could be used for the climate cascade and supply shunts.		ETFE panels with a sunshading layer. In this way transparency is achieved without influencing the performance of the cascade.
			Automatically controllable horizontal sunblinds could be used to reduce the heat load on the cascade. By using LED lights the working principle of the cascade could be emphasized.
			By keeping cascades as small as possible, the needed pump capacity to pump up the water is reduced together with the duct sizes.
			The cascade and supply shunts could be placed next to each other in a double facade. In this design integrated LED PV glass is used at the outer layer of the facade.
			Cascade and supply shunts could be placed in front of each other in a double facade.
			The cascade could be placed behind an extra facade layer.

(Swier, 2019)


BUILDING ASSESSMENT

Building context

Urban context



Availability of space




Placement of the elements in visible junctions



Building shape


Minimum building height



Unused spaces and projections




Minimum Free floor height




Facade

Include Open able windows




Small facade grids




Load bearing


Demountable building elements




Additional floors



Addition of facade




Large building grid




Climate study

Sun and Wind study





Heat and cold storage





EWF design strategies : General strategies

- **Shaft/duct sizes are bigger** than usual
- **Decentralized supply and centralized exhaust** or **centralized supply and decentralized exhaust**.



Centralized supply and decentralized exhaust



Decentralized supply and centralized exhaust

(Chaouat, 2015)

Climate cascade

- The **ventilation capacity** of the climate cascade should be **6.5 dm/s/person** .
- Climate cascade should be placed at **every 6th floor or multiple of it** .


Solar Chimney

- Orientation: **South, South west or south east**.
- A **single big solar chimney** gives better results than multiple small chimneys.
- The **depth** should be **min 0.65 m**
- The glass panes should have a **high G-value** and **low U-value** .
- **Solar facades** are a good solution.
- **Building integrated PV** and **solar panels** on the roof can contribute to high energy savings.
- The **heat from the exhaust air** should be **reused and stored**.



Provinciehuis Utrecht , Utrecht (flying holland.nl, n.d.)

Construction period	: 1992-2012
Number of floors	: 18 floors (19 th and 20 th floors are technical spaces)
Size	: 53953 m ² GFA/ 29096 m ² GO
Parking area	: 18270 m ² GFA
Function	: predominantly office with meeting function
Working hours	: 8:00 am – 8:00 pm (Mon-Fri)
Meeting rooms timings	: 8:00 am to 10:00pm (Mon-Fri)
No. of Occupants	: 1000
Floor height	: 3.5 m



Architectural data


- Façade : $R_c = 2.0$
- Climate window : $U = 1.2 \text{ W/ m}^2 \text{ K}$ (13cm cavity)
- Sun protection inside : electrically operated intermediate blinds

Technical data


- Heat generation : district heat network Utrecht-Nieuwegein ($\eta = 150\%$)
- Heat distribution : VAV boxes (transport medium water)
- Space heating control : room thermostats
- Cold generation : air/water compression refrigerators
- Cold distribution : ventilation air (transport medium air with 7°C)
- Ventilation : mechanical exhaust and supply
- Domestic Hot Water : TSA on district heating network and electric boilers
- Humidification : adiabatic humidification
- Heat recovery high rise : heat wheels

4 Design options


**Case 1: 1 Climate Cascade,
1 Solar Chimney**




**Case 2: 2 Climate Cascade,
2 Solar Chimney**



**Case 3: 1 Climate Cascade,
2 Solar Chimney**




**Case 4: 2 Climate Cascade,
1 Solar Chimney**



■ Climate Cascade ■ Supply shaft ■ Solar Chimney ■ Exhaust Exhaust shaft ■ Exhaust ducts ■ Supply ducts


**Case 1: 1 Climate Cascade, 1 Solar Chimney
(Decentralized supply, Centralized exhaust)**

■ 2.0 x 2.0 m Climate Cascade ■ 2.0 x 2.0 m Supply shaft ■ 14.5 x 0.80 m Solar Chimney ■ 2.40 x 1.50 m Exhaust shaft — Exhaust ducts — Supply ducts




**Case 2a: 2 Climate Cascade, 2 Solar Chimney
(Decentralized supply, Decentralized exhaust)**

■ 1.35 x 1.35 m Climate Cascade ■ 1.35 x 1.35 m Supply shaft ■ 9.90 x 0.70 m Solar Chimney ■ 2.40 x 1.50 m Exhaust shaft — Exhaust ducts — Supply ducts




**Case 2b: 2 Climate Cascade, 2 Solar Chimney
(Decentralized supply, Centralized exhaust)**

■ 1.35 x 1.35 m Climate Cascade ■ 1.35 x 1.35 m Supply shaft ■ 9.90 x 0.70 m Solar Chimney ■ 2.40 x 1.50 m Exhaust shaft — Exhaust ducts — Supply ducts




**Case 3: 1 Climate Cascade, 2 Solar Chimney
(Decentralized supply, Centralized exhaust)**

■ 2.0 x 2.0 m Climate Cascade ■ 2.0 x 2.0 m Supply shaft ■ 9.90 x 0.70 m Solar Chimney ■ 2.40 x 1.50 m Exhaust shaft — Exhaust ducts — Supply ducts






**Case 4: 2 Climate Cascade, 1 Solar Chimney
(Decentralized supply, Centralized exhaust)**

■ 1.35 x 1.35 m Climate Cascade ■ 1.35 x 1.35 m Supply shaft ■ 14.5 x 0.80 m Solar Chimney ■ 2.40 x 1.50 m Exhaust shaft — Exhaust ducts — Supply ducts




Basic Excel Modeling








- Air Velocity= 2 m/s
- No. of Nozzles= 9




- Air Velocity= 3 m/s
- No. of Nozzles= 9




- Air Velocity= 3.8 m/s
- No. of Nozzles= 9




- Depth= 0.65 m
- Air velocity= 0.5 m/s
1.0 m/s
1.5 m/s



- Depth= 0.80 m
- Air velocity= 0.5 m/s
1.0 m/s
1.5 m/s




- Depth= 1.0 m
- Air velocity= 0.5 m/s
1.0 m/s
1.5 m/s




CLIMATE CASCADE


Case 1: 1 Climate Cascade, 1 Solar Chimney




Case 2: 2 Climate Cascade, 2 Solar Chimney



Case 3: 1 Climate Cascade, 2 Solar Chimney



Case 4: 2 Climate Cascade, 1 Solar Chimney



Pump energy (MWh)

Fan energy (MWh)

Additional Heating energy (kWh/m²)

Air Velocity (1 m/s = 10 m/s)



Generated Pressure

Tout of Climate Cascade (1°C = 10°C)


No. of Nozzles (1 = 10)

CLIMATE CASCADE


Case 1: 1 Climate Cascade, 1 Solar Chimney



Case 3: 1 Climate Cascade, 2 Solar Chimney



Case 4: 2 Climate Cascade, 2 Solar Chimney




- Lower pump energy
- Minimum fan energy
- Reduced Pressure losses via supply ducts
- No. of Nozzles= 4
- Air velocity= 3.8 m/s
- Size= 1.35 x 1.35 m

SOLAR CHIMNEY


Case 1: 1 Climate Cascade, 1 Solar Chimney

Size= 14.5 x 0.8 m




Case 2: 2 Climate Cascade, 2 Solar Chimney

Size= 9.9 x 0.7 m




Case 3: 1 Climate Cascade, 2 Solar Chimney

Size= 9.9 x 0.7 m



Case 4: 2 Climate Cascade, 1 Solar Chimney

Size= 14.5 x 0.8 m



Thermal Draught (1 Pa= 100Pa)

Tout at the top of Chimney (1°C = 10°C)


Air Velocity (1 m/s = 100 m/s)

Fan energy (kWh)


Recovered Heat energy (MWh)

SOLAR CHIMNEY


Case 1: 1 Climate Cascade, 1 Solar Chimney




Case 3: 1 Climate Cascade, 2 Solar Chimney



Case 2: 2 Climate Cascade, 2 Solar Chimney



Case 4: 2 Climate Cascade, 1 Solar Chimney



Design conditions


Determining variables

Energy calculations


Chosen option

CHOSEN OPTION


**Case 2b: 2 Climate Cascade, 2 Solar Chimney
(Decentralized supply, Centralized exhaust)**





Dynamic Modeling using Design Builder



Existing System without EWF




Existing System without EWF




Thermal Comfort

ATG Method for accessing Thermal Comfort




Thermal Comfort assessment of the existing system without EWF

— Class B Upper Limit Class C Upper Limit - - - Class D Upper Limit — Class B Upper Limit Class C Upper Limit - - - Class D Upper Limit • Hours



Building	Provinciehuis Utrecht
Space	1 Office floor
Building type	Beta
Temperature type	Operative
Analysis Period	Jan-Sept
Occupied Hours	8049
Thermal Performance	Bad
Class	Class D

Comfort Bandwidth	No. of Hours	% of Time
Class B	2858	35.51
Class C	2231	27.72
Class D	1567	19.47
Above Class D	1393	17.31




New System with EWF



EnergyPlus Output

1 Jan - 31 Dec, Monthly

Evaluation



Comparison between the 2 systems



62% less Ventilation energy

36% less Cooling energy

72% less Heating energy

53% Reduction Overall

EWF System Energy

EWF system energy consumption

	EWF Ventilation Energy without Heat recovery		EWF Ventilation Energy with Heat recovery	
	Primary Energy (kWh/year)	Primary Energy (kWh/m2)	Primary Energy (kWh/year)	Primary Energy (kWh/m2)
Climate Cascade				
Pump energy	54,800	-	25800	
Fan energy	6,700	-	0	
Additional Heating energy	368,000	12.7	196,693	10.2
Solar Chimney				
Fan energy	1800	-	1800	
Total	431,300		224,293	

EWF Ventilation Energy		
	Primary Energy (kWh/year)	Primary Energy (kWh/m2)
Climate Cascade		
Pump energy	25800	-
Fan energy	0	-
Additional Heating energy	196,693	12.7
Solar Chimney		
Fan energy (22°C constant Incoming air)	1800	-
Fan energy (Varying temperatures according to dynamic simulations)	2500	-
Total	224,993	


Heat Recovery system



Winter situation

Pre-heats the outdoor air from 2°C to 13°C

Climate Cascade





Summer situation

Air-water heat exchanger


Booster heat pump

Recharging the ATES system

DHW




Thermal Comfort assessment of the New system with EWF



Building	Provinciehuis Utrecht
Space	1 Office floor
Building type	Beta
Temperature type	Operative
Analysis Period	Jan-Sept
Occupied Hours	1367
Thermal Performance	Acceptable
Class	Class C

Comfort Bandwidth	No. of Hours	% of Time
Class B	1000	73.1
Class C	308	22.5
Class D	59	4.3




Improved System with EWF


EnergyPlus Output

1 Jan - 31 Dec, Monthly

Evaluation



Comparison with EWF and Improved System with EWF




22% more Heating energy

18% less Cooling energy

2% Increase overall


Thermal Comfort assessment of the Improved System with EWF

— Class B Upper Limit Class C Upper Limit - - - Class D Upper Limit — Class B Upper Limit Class C Upper Limit - - - Class D Upper Limit • Hours



Building	Provinciehuis Utrecht
Space	1 Office floor
Building type	Beta
Temperature type	Operative
Analysis Period	Jan-Sept
Occupied Hours	255
Thermal Performance	Good
Class	Class B

Comfort Bandwidth	No. of Hours	% of Time
Class B	232	90.98
Class C	23	9.02
Class D	0	0




EWF system is an efficient way to reduce the energy consumption.

EWF system has better thermal comfort than the existing system.


With further improvements, the building achieves maximum thermal comfort.

3 Façade Options


FAÇADE OPTION 1:
Building Integrated
Photovoltaic



FAÇADE OPTION 2:
Sun-shading with PV




FAÇADE OPTION 3:
Living Wall system with
BIPV




FAÇADE OPTION 1: Building Integrated Photovoltaic

Elevation



Section



Prefab sandwich panel insulated aluminium with building integrated PV-cell in the South, SW and SE facade


Double glazed openable window with 13 cm air cavity and roller blinds within the cavity

Existing façade element: Granite façade panel


Double glazed Fixed window with 13 cm air cavity and roller blinds within the cavity

FAÇADE OPTION 1: Building Integrated Photovoltaic

Detailed Elevation




Detailed section




FAÇADE OPTION 2: Sun-shading with PV

Elevation



Section



Double glazed openable window with 13 cm air cavity and roller blinds within the cavity


Fixed Sun-shading with PV at 35° in the South Facade

Existing façade element: Granite façade panel


Double glazed Fixed window with 13 cm air cavity and roller blinds within the cavity

FAÇADE OPTION 2: Sun-shading with PV


Detailed Elevation



Detailed Section




FAÇADE OPTION 3: Living Wall system with BIPV




FAÇADE OPTION 3: Living Wall system with BIPV




Detailed Elevation




Detailed Section




Comparison of 3 façade options

Changed parameters	Façade option 1: BIPV	Façade option 2: Sun-shading with PV	Façade option 3: Living Wall System with BIPV
			
R-value	4.2 m ² K/W	No change	5.9 m ² K/W
% Reduction in solar gain from windows	No change	50%	84%
PV yield	224 MWh/year	150 MWh/year	224 MWh/year
% Reduction in the total energy consumption of the building	12%	13%	19%

EWF system with refurbished façade and GSHP



Comparison between the 2 systems




74% less Ventilation energy


26.5% less Cooling energy

70% less Heating energy

50% Reduction Overall



Final Design



Before






After



Assembly Sequence of Solar Chimney



BENG Regulations

BENG CALCULATIONS						
Annual amount of energy used for the energy function: Scenario 1						
	COP	Non-Primary energy (kWh)	PEF	Primary Energy (kWh)	Auxiliary energy Non-Primary energy (kWh)	Auxiliary energy Primary energy (kWh)
Heating	5.4	82,284 kWh	1.45	119,311 kWh	36,425	52,816
Cooling	10	0 kWh	1.45	0 kWh	29,619 kWh	42,947 kWh
DHW	3	0 kWh	1.45	0 kWh	11,760 kWh	17,052 kWh
Fans & Pumps	-	28,300 kWh	1.45	41,035 kWh	0 kWh	0 kWh
Lighting	-	405,720 kWh	1.45	588,294	0 kWh	0 kWh
Total				748,640		112,815
Annual Primary Energy consumption						
Primary energy use including auxiliary energy				861,455		
Energy generated by PV				224,076		
Annual Primary Energy consumption (E_{tot primary})				637,379		
Annual amount of Renewable Energy						
Heating (E _{ren. heating})				362,053		
Cooling (E _{ren cooling})				266,571		
PV (E _{ren pv})				224,076		
Total amount of Renewable Energy (E_{tot ren})				852,700		
Surface						
Total Useable Floor Area (UFA)			17,640			
Surface area of Envelope (SAE)			18445			
Ratio			1.04			
Heating and cooling Energy (Fossil + renewable energy)						
Heating (Pre heating included) (E _{heating})			444,337 kWh		25.2	
Cooling (Pre cooling included) (E _{cooling})			492,883 kWh		28	
Energy Performance						
BENG 1	<90 kWh/m2	(E _{heating})+(E _{cooling})		53.2 kWh/m2	Satisfied	
BENG 2	<40 kWh/m2	(E _{tot primary})/ UFA		36.13 kWh/m2	Satisfied	
BENG 3	>30%	(E _{tot ren})/ (E _{tot ren} + E _{tot primary})		57.2%	Satisfied	


BENG CALCULATIONS						
Annual amount of energy used for the energy function: Scenario 2						
	COP	Non-Primary energy (kWh)	PEF	Primary Energy (kWh)	Auxiliary energy Non-Primary energy (kWh)	Auxiliary energy Primary energy (kWh)
Heating	5.4	135,064 kWh	1.45	195,842 kWh	59,879 kWh	86,824 kWh
Cooling	10	0 kWh	1.45	0 kWh	48,430 kWh	70,223 kWh
DHW	3	0 kWh	1.45	0 kWh	19,333 kWh	28,032 kWh
Fans & Pumps	-	46,524 kWh	1.45	67,459 kWh	0 kWh	0 kWh
Lighting	-	667,000 kWh	1.45	967,150	0 kWh	0 kWh
Total				1,230,451		185,079
Annual Primary Energy consumption						
Primary energy use including auxiliary energy				1,415,530		
Energy generated by PV				224,076		
Annual Primary Energy consumption ($E_{tot\ primary}$)				1,191,454		
Annual amount of Renewable Energy						
Heating ($E_{ren. heating}$)				594,186		
Cooling ($E_{ren cooling}$)				435,870		
PV ($E_{ren pv}$)				224,076		
Total amount of Renewable Energy ($E_{tot ren}$)				1,254,132		
Surface						
Total Useable Floor Area (UFA)			29000			
Surface area of Envelope (SAE)			21075			
Ratio			0.72			
Heating and cooling Energy (Fossil + renewable energy)						
Heating (Pre heating included) ($E_{heating}$)			729,350 kWh		25.2	
Cooling (Pre cooling included) ($E_{cooling}$)			807,650 kWh		28	
Energy Performance						
BENG 1	<90 kWh/m2	$(E_{heating})+(E_{cooling})$		53.2 kWh/m2	Satisfied	
BENG 2	<40 kWh/m2	$(E_{tot primary})/ UFA$		41.0 kWh/m2	Not Satisfied	
BENG 3	>30%	$(E_{tot ren})/ (E_{tot ren} + E_{tot primary})$		51.2%	Satisfied	

BENG CALCULATIONS						
Annual amount of energy used for the energy function: Scenario 3						
	COP	Non-Primary energy (kWh)	PEF	Primary Energy (kWh)	Auxiliary energy Non-Primary energy (kWh)	Auxiliary energy Primary energy (kWh)
Heating	5.4	135,064 kWh	1.45	195,842 kWh	59,879 kWh	86,824 kWh
Cooling	10	0 kWh	1.45	0 kWh	48,430 kWh	70,223 kWh
DHW	3	0 kWh	1.45	0 kWh	19,333 kWh	28,032 kWh
Fans & Pumps	-	46,524 kWh	1.45	67,459 kWh	0 kWh	0 kWh
Lighting	-	667,000 kWh	1.45	967,150	0 kWh	0 kWh
Total				1,230,451		185,079
Annual Primary Energy consumption						
Primary energy use including auxiliary energy				1,415,530		
Energy generated by PV				326,097		
Annual Primary Energy consumption ($E_{tot\ primary}$)				1,089,433		
Annual amount of Renewable Energy						
Heating ($E_{ren. heating}$)				594,186		
Cooling ($E_{ren cooling}$)				435,870		
PV ($E_{ren, pv}$)				326,097		
Total amount of Renewable Energy ($E_{tot ren}$)				1,356,153		
Surface						
Total Useable Floor Area (UFA)			29000			
Surface area of Envelope (SAE)			21075			
Ratio			0.72			
Heating and cooling Energy (Fossil + renewable energy)						
Heating (Pre heating included) ($E_{heating}$)			729,350 kWh		25.2	
Cooling (Pre cooling included) ($E_{cooling}$)			807,650 kWh		28	
Energy Performance						
BENG 1	<90 kWh/m2	$(E_{heating})+(E_{cooling})$		53.2 kWh/m2	Satisfied	
BENG 2	<40 kWh/m2	$(E_{tot primary})/ UFA$		37.56 kWh/m2	Satisfied	
BENG 3	>30%	$(E_{tot ren})/ (E_{tot ren} + E_{tot primary})$		51.2%	Satisfied	


Paris Proof Agreement

PARIS PROOF	
Annual Primary Energy consumption	
1,089,433 kWh	
Total amount of Renewable Energy	
PV on SW,SE & S facade	326,097 kWh
Required PV energy	763,336 kWh


Proposed locations to install PV



PV panels on the Statenzaal roof



PV panels in the Garden on the SW



PV panels on the parking deck

PARIS PROOF	
Annual Primary Energy consumption	
1,089,433 kWh	
Total amount of Renewable Energy	
PV on SW,SE & S facade	326,097 kWh
PV on the roof of the Statenzaal	185,923 kWh
PV panels in the garden (orientation SW)	228,978 kWh
PV on the parking deck	468,450 kWh
	1,209,448 kWh

The primary energy can be completely provided by the PV panels and energy neutrality is achieved on the basis of zero on the meter concept.

RECAP

How are the **design strategies** derived from the **Earth, Wind and Fire system**, implemented in the **refurbishment of an office building** in the Netherlands in order to **improve the energy performance**?

Basic Excel Model

EWF system can be implemented

No. of EWF elements

Building design and required pressure

Dynamic Design Builder Model

EWF system also reduces the energy consumption and improves thermal comfort

53 % energy reduction

Class B thermal comfort

Façade Refurbishment

EWF system with refurbished façade further reduces the energy consumption significantly

Further energy reduction by 19%

50% energy reduction with GSHP

EWF system is an efficient way to reduce the energy consumption of the Provinciehuis Utrecht building while also complying with all the BENG regulations along with achieving energy neutrality on the basis of zero on the meter concept.


In order to implement the EWF system for other buildings, the most influential design strategies to be considered are:




Building Height



Façade Refurbishment




Heat and Cold storage




Heat Recovery system

Further Recommendations



Study the effect of Ventec Roof



Varying Heights of Climate Cascade




Designer's tool

































Thank You!

Appendix

Methodology







































SOLAR CHIMNEY

Separate from the building	Connected to the building	In the facade	On the roof
 <p>Separate chimney's could function as sun shading device and to get more daylight into the building.</p>	 <p>A chimney could be designed like it bumped into the existing building. By combining it with an atrium the distribution of exhaust air could also be arranged.</p>	 <p>The niches in the building shape could be filled up with chimney. This doesn't make them very expressive but is effective from a climatic point of view by reducing the facade area.</p>	 <p>By adding a greenhouse on the roof of a building, air could be sucked out of the building due to the overpressure in the greenhouse.</p>
 <p>Reuse old material to construct the chimney. Put a small vented roof on top of the chimney to improve its performance.</p>	 <p>An expressive 'proboscis'-like chimney could be added to the building.</p>	 <p>The chimney could be expressed a bit in the facade by delicate changes in the shape of an extra facade layer.</p>	
 <p>A lot of small chimney's around the building would add character but compromise on its performance.</p>	 <p>The chimney's and supply/exhaust shunts could be made expressive/explicit in the shape of an extra facade layer that is wrapped around the building.</p>	 <p>The chimney(s) could be hidden behind an extra facade layer that is wrapped around the building.</p>	
 <p>One large separate chimney would have a better performance than a lot of small chimney's. Separation of the building would allow more daylight in the building.</p>	 <p>The collection of the exhaust air at the bottom of the building could be made expressive with big shunt channels that circle around the building.</p>	 <p>The chimney(s) could be hidden behind an extra facade layer that is wrapped around the building.</p>	
 <p>The diagrid structure could be emphasized with a swaying chimney and exhaust shunts in different directions around it.</p>	 <p>Separate facade elements with different characteristics (depths, material) could be designed for the different EWF elements.</p>	 <p>By creating a solar facade the building shape is kept the same but the building performance is improved.</p>	
 <p>Swaying chimney's around the building wouldn't compromise its performance but add more architectural identity. Add heat recovery on top incl. turbine to produce energy.</p>	 <p>A trapezium shaped chimney with integrated exhaust shunt could be used. The shape doesn't necessarily improve its performance.</p>	 <p>The chimney could be hidden in an extra facade layer but emphasized by an orientation of glass facade sheets.</p>	
	 <p>Whole floor elements could be removed to create an atrium with chimney's that stick out of the building.</p>	 <p>Space for the chimney's could be created by making cut outs in the structure if the structure allows this.</p>	
	 <p>Chromatic painting that fades due to temperature differences could be used to emphasize the working principle of the solar chimney.</p>	 <p>Space for the chimney could be created by cutting off a part of a corner of the structure if the structure allows this.</p>	
	 <p>A whole EWF unit could be connected to the building to control the natural air conditioning in the building.</p>		
	 <p>Repetitive positioning of the chimney's could be used to give the building shape more character.</p>		
	 <p>When the chimney is positioned in the corner of a building with a double facade de chimney could be emphasized by its shape.</p>		
	 <p>The level off expression in the facade could depend on the orientation of the facade. By doing so the building could get more connected with its surroundings.</p>		
	 <p>The facade elements could be placed at an angle and so the chimney's with their straight vertical appearance are emphasized.</p>		
	 <p>The chimney's could be 'pressed' outside to increase solar gains and to create space for exhaust shunts.</p>		
	 <p>In a diagrid structure the diagonal space between the load bearing structure could be filled up with chimney's.</p>		
	 <p>The temperature rise of the air could be emphasized with LED lights that are integrated in the chimney.</p>		
	 <p>Information about the performance of the chimney could be displayed on the glass of the chimney's.</p>		

CLIMATE CASCADE

In the building

In the facade

 <p>①</p>	<p>By making a cut out in the core of the building a space is created for the climate cascade. The inner ring is for the cascade, the outer ring for the supply of the air.</p>	 <p>②</p>	 <p>③</p>	<p>The cascade and supply shunts could be placed next to each other in a double facade. In this design integrated LED PV glass is used at the outer layer of the facade.</p>
 <p>④</p>	<p>Also a cut out design but the supply air is distributed through the space via a raised floor. By making the cascade transparent a climatic architectural element is created.</p>	 <p>⑤</p>	 <p>⑥</p>	<p>Cascade and supply shunts could be placed in front of each other in a double facade.</p>
 <p>⑦</p>	<p>By surrounding the cascade with staircases the interaction of the cascade with building occupants is increased.</p>	 <p>⑧</p>	 <p>⑨</p>	<p>The cascade could be placed behind an extra facade layer.</p>
 <p>⑩</p>	<p>A round cut out might be more efficient for the load bearing structure. The supply shunt are accommodated in existing vertical shafts.</p>	 <p>⑪</p>	 <p>⑫</p>	<p>An entrance can be enhanced by placing the cascades around it. The addition of a print on a glass panel could work as sun shading and function as a communication tool.</p>
 <p>⑬</p>	<p>The cut out could create space for both the climate cascade as well as the vertical distribution shafts for supply air.</p>	 <p>⑭</p>	 <p>⑮</p>	<p>Space could be created by making a cut out in the facade. By using transparent surfaces in the facade the cascade is made explicit, but this design is subtle.</p>
 <p>⑯</p>	<p>By creating more climate cascade ... ADD TEXT ...</p>	 <p>⑰</p>	 <p>⑱</p>	<p>The cascade and the supply shaft could be visualised together by adding to 'towers' the the building that are connected at the bottom.</p>
 <p>⑲</p>	<p>The climate cascade could be emphasized by making it more expressive inside the building.</p>	 <p>⑳</p>	 <p>㉑</p>	<p>The cascade could be made visible from both the inside and outside. Louvers could be used to reduce the heat load on the transparent surfaces.</p>
 <p>㉒</p>	<p>The vertical installation shafts in the existing building could be used for the climate cascade and supply shunts.</p>	 <p>㉓</p>	 <p>㉔</p>	<p>ETFE panels with a sunshading layer. In this way transparency is achieved without influencing the performance of the cascade.</p>
 <p>㉕</p>	<p>Automatically controlable horizontal sunblinds could be used to reduce the heat load on the cascade. By using LED lights the working principle of the cascade could be emphasized.</p>	 <p>㉖</p>	 <p>㉗</p>	<p>By keeping cascades as small as possible, the needed pump capacity to pump up the water is reduced together with the duct sizes.</p>
 <p>㉘</p>	<p>The cascades and ducts could be smoothly visualised by adding a layer around the ducts and EWF elements that changes the shape of a building.</p>	 <p>㉙</p>	 <p>㉚</p>	<p>The supply and exhaust ducts could be placed on the facade. This could be useful when the free floor height is limited.</p>
 <p>㉛</p>	<p>A whole EWF unit could be connected to the building to control the natural airconditioning in the building.</p>	 <p>㉜</p>	 <p>㉝</p>	<p>Small cascades separate from the building with vertical supply shunts could be created. By the reducing the size of the cascade the performance is improved.</p>
 <p>㉞</p>	<p>In this design a lot of small cascades and supply shunts are placed on the facade. In this way a vertically in the architectural design is achieved.</p>	 <p>㉟</p>	 <p>㊱</p>	<p></p>

Comparative analysis of case study buildings



Provinciehuis Utrecht , Utrecht
(flying holland.nl, n.d.)



Van Unnikgebouw, Utrecht
(Pepijntje, 2008)

BUILDING	PROVINCIEHUIS UTRECHT	WILLEM C. VAN UNNIKGEBOUW
Typology	Office Building ✓	Education and Office building ✗
Higher than surrounding building	✓	✓
Building height	85m ✓	75.5m ✓
Possibility to strip down the façade completely	✓	✗
Open able windows in the façade	-	✗
Load bearing façade system	-	✗
Easy disassembly	✗	✓
Poured pipes in the floor	✗	✗
Large column grid	✓	✓
Structural system can withstand additional façade loads	✗	✓
Possibility of cold and heat storage	✓	✓





BENG Regulations

	BENG 1 Energy requirement [kWh/m².yr]	BENG 2 Primary fossil energy consumption [kWh/m².yr]	BENG 3 share renewable energy [%]
2015 - NEN 7120	≤ 50	≤ 25	≥50
2018 - NTA 8800	$A_{ls}/A_g \leq 2,2 \rightarrow 90$ $A_{ls}/A_g > 2,2 \rightarrow 90 + 50 * (A_{ls}/A_g - 2,2)$	50	≥30
2019 - NTA 8800	$A_{ls}/A_g \leq 1,8$ BENG 1 ≤ 90 $A_{ls}/A_g > 1,8$ BENG 1 ≤ 90 + 30 * $(A_{ls}/A_g - 1,8)$	≤ 40	≥30

CLIMATE CASCADE: Single Cascade

CASE 1= 1 Climate Cascade & 1 Solar Chimney





CASE 3= 1 Climate Cascade & 2 Solar Chimneys



CLIMATE CASCADE: Double Cascade

CASE 2= 2 Climate Cascades & 2 Solar Chimneys

CASE 4= 2 Climate Cascades & 1 Solar Chimney




Additional Heating energy calculation


$$\text{Heating energy (kW)} = \frac{\text{Amount of air}}{3600} \times 1.2 \times \text{specific heat capacity of air} \times \text{Temperature difference}$$

CLIMATE CASCADE: GENERATED PRESSURE


CASE 1= 1 Climate Cascade & 1 Solar Chimney




CASE 2= 2 Climate Cascades & 2 Solar Chimneys



CASE 3= 1 Climate Cascade & 2 Solar Chimneys




CASE 4= 2 Climate Cascades & 1 Solar Chimney




SOLAR CHIMNEY: Thermal draught, Pressure loss and Tout


CASE 1= Single Chimney




CASE 2= Double Chimney



CASE 3 = Double Chimney




CASE 4= Single Chimney




SOLAR CHIMNEY: Fan energy


CASE 1= Single Chimney




CASE 2= Double Chimney




CASE 3 = Double Chimney



CASE 4= Single Chimney



Thermal zones in Design Builder Model



Design Conditions

DESIGN CONDITIONS								
		Constants						
		Total Pressure loss (Pa)	Supply temperature (°C)	Exhaust temperature (°C)	Supply water temperature (°C)	Relative humidity	Height (m)	Ventilation capacity (m ³ /h)
1	Climate cascade	150	18	-	13	55%	80	50000
2	Solar chimney	50	-	22	-	-	80	50000

CLIMATE CASCADE

Evaluation Parameters											
	Design Options	Supply/ Exhaust	Size (m)	Generated pressure (Pa)	Tout of CC (°C)	No. of Nozzles	Velocity of air (m/s)	Water/ Air Ratio (kg/kg)	Pump energy (kWh/year)	Fan Energy (kWh/year)	Additional heating energy (kWh/m2)
1	1 Climate cascade 1 Solar chimney	Decentralized supply, Centralized Exhaust	2.0 x 2.0	160 Pa (T_supply= 28°C; RH= 55%)	18.0°C (RH= 98%)	9	3.2 m/s	0.37	61650 kWh	200 kWh	13
2	2 Climate cascade 2 Solar chimney	Decentralized supply, Decentralized exhaust	1.35 x 1.35	156 Pa (T_supply= 28°C; RH= 55%)	18.4°C (RH= 96%)	4	3.8 m/s	0.33	54800 kWh	6700 kWh	12.7
3	1 Climate cascade 2 solar chimney	Decentralized supply, Centralized exhaust	2.0 x 2.0	160 Pa (T_supply= 28°C; RH= 55%)	18.0°C (RH= 98%)	Winter = 11 Summer = 9	3.2 m/s	Winter= 0.46 Summer = 0.37	73000 kWh	0.3 kWh	12
4	2 Climate cascade 1 Solar chimney	Decentralized supply, Centralized exhaust	1.35 x 1.35	156 Pa (T_supply= 28°C; RH= 55%)	18.4°C (RH= 96%)	Winter = 5 Summer = 4	3.8 m/s	Winter= 0.42 Summer = 0.33	66200 kWh	5000 kWh	12


SOLAR CHIMNEY

SOLAR CHIMNEY									
			Evaluation Parameters						
	Design Options	Supply/ Exhaust	Total Pressure loss (Pa)	Thermal Draught (Pa)	Velocity of air (m/s)	Tout at the top of chimney (°C)	Size (m)	Fan Energy (kWh)	Recovered Heat energy (kWh)
1	1 Climate cascade 1 Solar chimney	Decentralized supply, Centralized Exhaust	50 Pa	-4.0 Pa (T _{supply} = 22°C & T _{out} = 30°C)	1.2 m/s	35.2 °C	14.5 x 0.8	1200 kWh	592500
2	2 Climate cascade 2 Solar chimney	Decentralized supply, Decentralized exhaust	50 Pa	2.2 Pa (T _{supply} = 22°C & T _{out} = 28°C)	1.0 m/s	39.5°C	9.9 x 0.7	2000 kWh	653000
3	1 Climate cascade 2 solar chimney	Decentralized supply, Centralized exhaust	50 Pa	8 Pa (T _{supply} = 24°C & T _{out} = 28°C)	1.0 m/s	41.4°C	9.9 x 0.7	1800 kWh	700000
4	2 Climate cascade 1 Solar chimney	Decentralized supply, Centralized exhaust	50 Pa	1.7 Pa (T _{supply} = 24°C & T _{out} = 28°C)	1.2 m/s	37.2°C	14.5 x 0.8	1000 kWh	630000

Ventilation Capacity

	Max. amount of air needed per function (m3/h)	No. of occupants per function	Occupancy % per 3 hours								
			0:00	3:00	6:00	9:00	12:00	15:00	18:00	21:00	0:00
Offices	40,000	800	10%	5%	5%	85%	90%	85%	30%	15%	10%
Ground floor (Restaurant)	5,000	100	5%	5%	15%	85%	90%	85%	70%	30%	5%
First floor (Meeting rooms + Common areas)	5,000	100	5%	5%	10%	60%	85%	60%	70%	30%	10%
Required ventilation capacity according to occupant %	50,000	1000	4500	2500	3250	41250	44750	41250	19000	9000	4750
Required Pressure (Pa)	150		32	24	27	96	100	96	65	45	33

EWF HVAC Configuration



Supply of 18°C air

Navigate, Site Untitled, Building 1, HVAC System, Air Loop, Air Loop Supply Side, Air Loop Setpoint Manager

Site Components Templates Edit Visualise Heating design Cooling design Simulation CFD Daylighting Cost and Carbon

Untitled

- Building 1
 - <HVAC System>
 - Air Loop
 - Air Loop Demand Side
 - Air Loop Supply Side
 - Air Loop AHU
 - Air Loop Setpoint Manag
 - CHW Loop
 - HW Loop
 - Zone Group
 - Block1:Zone1
 - Block 1
 - Zone 1

Edit Setpoint manager -

Setpoint manager


Setpoint Manager

General	
Name	Air Loop Setpoint Manager
Type	1-Scheduled

Schedule	
Control variable	1-Temperature
Setpoint variable schedule	Always 18.0 C

Daily Frequency

1/1/2002 - 12/31/2002, Daily Frequency



Existing system without EWF daily simulation

Temperatures, Heat Gains and Energy Consumption - Province original situation, Building 1

EnergyPlus Output

1 Jan - 31 Dec, Daily

Evaluation



ENERGY CONSUMPTION: Without EWF


		Energy Consumption without EWF		
		Area (m2)	Primary Energy (kWh/year)	Primary energy (kWh/m2/year)
	Usable Floor area	17,640		
1	Space Heating		1,640,520	93
2	DHW		35,280	2
3	Cooling		740,880	42
4	Ventilation		864,360	49
5	Production Equipment		88,200	5
6	Lighting		405,720	23
	Total		3,774,960	214

New system with EWF daily simulation

EnergyPlus Output

1 Jan - 31 Dec, Daily

Student



ENERGY COMPARISON


		Energy Consumption without EWF		Energy consumption with EWF			
		Area (m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Reduction %
	Usable Floor area	17,640					
1	Space Heating		1,640,520	93	447,660	25.3	72%
2	DHW		35,280	2	35,280	2	-
3	Cooling		740,880	42	469,404	26.6	36%
4	Ventilation		864,360	49	322,400	18.3	62.7%
5	Production Equipment		88,200	5	88,200	5	-
6	Lighting		405,720	23	405,720	23	-
	Total		3,774,960	214	1,768,664	100.3	53.1%

Improved system with EWF hourly simulation

EnergyPlus Output

1 Jan - 31 Dec, Hourly

Evaluation




ENERGY COMPARISON: Improved EWF system							
		Energy Consumption without EWF			Energy consumption with Improved EWF		
		Area (m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Reduction %
	Usable Floor area	17,640					
1	Space Heating		1,640,520	93	574,524	32.6	64%
2	DHW		35,280	2	35,280	2	-
3	Cooling		740,880	42	385,290	21.8	48%
4	Ventilation		864,360	49	323,100	18.3	62.7%
5	Production Equipment		88,200	5	88,200	5	-
6	Lighting		405,720	23	405,720	23	-
	Total		3,774,960	214	1,809,414	102.6	52%

PV Yield Calculations		
Location	South, SW, SE	
Total Surface area available to install PV (m2)	4350	
PV Panel power (WP)	300	
PV size/panel (m2)	1.5	
Angle [?]	35°	
System size (kW)	400	
Module material	c-Si	
Module efficiency	15%	
PV Annual energy (kWh)	224076	
Energy Consumption: Façade Option 1		
	Primary Energy (kWh)	Reduction Factor
Energy Consumed by EWF	1,768,664	-
PV Yield from Façade option 2	224076	-
Energy Reduction	1,544,588	12%

PV Yield Calculations		
Location	South, SW, SE	
Total Surface area available to install PV (m2)	4350	
PV Panel power (WP)	300	
PV size/panel (m2)	1.5	
Angle [°]	35°	
System size (kW)	400	
Module material	c-Si	
Module efficiency	15%	
PV Annual energy (kWh)	150237	
Energy Consumption: Façade Option 2		
	Primary Energy (kWh)	Reduction Factor
Energy Consumed by EWF	1,768,664	-
Energy Consumed by EWF: after refurbished façade	1,684,820	
PV Yield from Façade option 2	150237	-
Energy Reduction	1,534,583	13%

Thermal Insulation Improvements					
R-Value				Wall-Window Ratio	
Existing Façade- Opaque part (m2K/W)	Existing Façade- complete unit (m2K/W)	Refurbished Façade- Opaque part (m2K/W)	Refurbished Façade- complete unit (m2K/W)	Wall-Window Ratio: Existing	Wall-Window Ratio: Refurbished
4.2	2	5.9	3.6	75%	30%
Energy Consumption: Façade Option 3					
				Primary Energy (kWh)	Reduction Factor
Energy Consumed by EWF: before refurbished facade				1,768,664	-
Energy Consumed by EWF: after refurbished façade				1,654,616	-
PV Yield from Façade option 3				224076	-
Energy Reduction				1,430,540	19%

Improved system with EWF and GSHP




Improved system with EWF and GSHP daily simulation

Temperatures, Heat Gains and Energy Consumption - EWF test file, Building 1

EnergyPlus Output

1 Jan - 31 Dec, Daily

Evaluation



ENERGY COMPARISON: Refurbished Façade option 3 with GSHP

		Energy Consumption without EWF and with GSHP			Energy consumption with EWF and GSHP		
		Area (m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Primary Energy (kWh)	Primary energy (kWh/m2)	Reduction %
	Usable Floor area	17,640					
1	Heating		846,000	48	247,644	14.0	70%
2	DHW		35,280	2	35,280	2	-
3	Cooling		403,200	22.8	296,190	16.7	26.5%
4	Ventilation		864,360	49	224,993	12.75	74%
5	Production Equipment		88,200	5	88,200	5	-
6	Lighting		405,720	23	405,720	23	-
	Total		2,642,760	150	1,298,027	73.6	50.8%



THANK YOU



Earth



Wind



Fire