

Open-Access Model of a PV–BESS System

Quantifying Power and Energy Exchange for Peak-Shaving and Self Consumption Applications

Alpizar Castillo, Joel; Vega-Garita, Victor ; Narayan, Nishant ; Ramirez Elizondo, Laura

DOI

[10.3390/en16145480](https://doi.org/10.3390/en16145480)

Publication date

2023

Document Version

Final published version

Published in

Energies

Citation (APA)

Alpizar Castillo, J., Vega-Garita, V., Narayan, N., & Ramirez Elizondo, L. (2023). Open-Access Model of a PV–BESS System: Quantifying Power and Energy Exchange for Peak-Shaving and Self Consumption Applications. *Energies*, 16(14), Article 5480. <https://doi.org/10.3390/en16145480>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.

Article

Open-Access Model of a PV–BESS System: Quantifying Power and Energy Exchange for Peak-Shaving and Self Consumption Applications

Joel Alpízar-Castillo ^{1,2,†,*} , Victor Vega-Garita ^{3,†} , Nishant Narayan ^{4,†}  and Laura Ramirez-Elizondo ^{2,†} 

¹ Electrical Engineering Department, Fidélitas University, San Pedro, San José 11501, Costa Rica

² DC Systems, Energy Conversion and Storage Group at TU Delft, 2628CD Delft, The Netherlands; l.m.ramirezelizondo@tudelft.nl

³ Electrical Engineering Department, University of Costa Rica, San Pedro, San José 11501-2060, Costa Rica; victor.vegagarita@ucr.ac.cr

⁴ Sustainable Energy for All, 1220 Vienna, Austria; sn.nishant@gmail.com

* Correspondence: j.j.alpizarcastillo@tudelft.nl

† These authors contributed equally to this work.

Abstract: Energy storage is vital for a future where energy generation transitions from a fossil fuels-based one to an energy system that relies heavily on clean energy sources such as photovoltaic (PV) solar energy. To foster this transition, engineers and practitioners must have open-access models of PV systems coupled with battery storage systems (BESS). These models are fundamental to quantifying their economic and technical merits during the design phase. This paper contributes in this direction by carefully describing a model that accurately represents the power directions and energy dealings between the PV modules, the battery pack, and the loads. Moreover, the general model can be implemented using two different PV generation methods, the Gaussian model and the meteorological data-based model (MDB). We found that the MDB model is more appropriate for short-term analysis compared to the Gaussian model, while for long-term studies, the Gaussian model is closer to measured data. Moreover, the proposed model can reproduce two different energy management strategies: peak-shaving and maximizing self-consumption, allowing them to be used during PV–BESS sizing stages. Furthermore, the results obtained by the simulation are closed when compared to a real grid-tied PV–BESS, demonstrating the model's validity.

Keywords: PV–BESS modeling; solar–battery systems; PV–BESS



Citation: Alpízar-Castillo, J.; Vega-Garita, V.; Narayan, N.; Ramirez-Elizondo, L. Open-Access Model of a PV–BESS System: Quantifying Power and Energy Exchange for Peak-Shaving and Self Consumption Applications. *Energies* **2023**, *16*, 5480. <https://doi.org/10.3390/en16145480>

Academic Editor: Syed Abdul Moiz

Received: 14 June 2023

Revised: 13 July 2023

Accepted: 17 July 2023

Published: 19 July 2023



Copyright: © 2023 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (<https://creativecommons.org/licenses/by/4.0/>).

1. Introduction

As the adverse effects that climate change pose to humanity become more evident due to extreme weather events, mitigation actions are fundamental and must occur promptly. Definitely, the way and pace at which developed countries have consumed energy is not sustainable. Therefore, the actions to mitigate climate change must be directly related to a drop in the world energy demand and an increase in clean energy generation in the near future [1]. Among those actions are the electrification of transport and heating. However, such components of the energy transition urge a dramatic, but planned, expansion of the installed power capacity from renewable energy sources and energy storage systems. As detailed in [2], renewable energy sources (RES) spread in low-voltage distribution networks can cause overvoltages, and the increasing power demand created by the electrification of heat and transportation can cause congestion. This way, energy storage systems can contribute to avoiding such issues on the distribution network. Thus, combining renewable energy sources with energy storage technologies is expected to grow exponentially in the coming years [3]. Particularly, photovoltaic (PV) energy has been identified as one of the most prominent RES technology, as it is accessible to everyone and has low maintenance

costs. The PV system's upfront costs have been decreasing [4] continuously. Likewise, battery energy storage systems (BESS) are becoming more reliable and profitable and, therefore, more attractive to investors [5].

Given the massive rise expected in the amount of PV systems worldwide, it is crucial to develop models that help engineers and practitioners during the design process of the PV system. Among the processes needed for a correct design, energy yield simulations and profitability studies must be performed [6]. For doing so, the power flow between a PV system's components—PV modules, grid, and battery pack—and the criteria defined by the Energy Management Systems must be simulated to calculate the energy exchange.

There are several commercial PV-related software available. For instance, PVSYS[®] was one of the first programs developed to evaluate PV potential, considering the location and meteorological data while also including a database of products—e.g., PV modules, inverters, battery packs, optimizers, and charge controllers—that better suit the PV system to be installed [7]. Additionally, PV*SOL[®] is a simulation program that allows designing PV systems with energy storage with the possibility of 3D visualization and shading analysis [8]. In the case of PVSYS[®], the professional license costs around 675 USD per year, while the license for PV*SOL[®] is 1295 USD with an updating scheme. Thus, to facilitate the adoption of PV systems in place where buying this proprietary software is too high, it is fundamental to have open-access models and libraries that provide free tools, which are essential in enabling the adoption of PV systems in places where the cost of purchasing proprietary software is prohibitive for many people.

1.1. Relevant Literature

During the last few years, multiple papers have described methods to model the output power of PV systems. Authors have proposed several mathematical tools for forecasting short, medium, and long periods of PV generation. For instance, in [9], a 15 min ahead method based on a higher Markov chain is proposed to obtain the PV generation's probability distribution function, considering temperature and irradiance to determine the PV system operation points. Similarly, in [10], a PV power forecasting method was implemented for ranges between 5 min to 36 h, including in situ measurements and satellite images as inputs. These approaches are beneficial for PV power predictions, especially in the context of smart grids, as reported in [11], where having a reliable estimation of PV power for the electricity grid's stability is fundamental. Convolutional neural networks are also proposed by [12] to forecast PV output based on historical operation and meteorological data from power plants in the region.

Despite the increasing research in modeling renewable energy sources, they alone cannot create strong grids due to their dependency on weather conditions. Therefore, energy storage systems should be coupled to ensure stability [13]. While historical data is essential to validate such tools for designing a well-sized PV system (viz., adequate installed PV peak power and battery storage capacity, quantification of economic benefits), recent works have proposed different approaches for modeling the interaction between RES and battery energy storage systems, as shown in Table 1. For instance, ref. [14] proposed a multifunctional control strategy for a battery energy storage system, in which minimizing the PV power ramp rate was proposed. An improved electric system cascade analysis to optimize a PV system with a BESS for a residential load based on historical data, with results comparable with HOMER, was presented in [15]. In contrast, proprietary software such as Matlab-Simulink[®], DIgSILENT[®], and HOMER[®] have been used in different case studies involving the power flow within a PV system and other distributed energy sources.

Table 1. Reported PV–BESS models

BESS Model	PV Model	Control	Requirements	Language	Ref.
Simulink [®] block	Simulink [®] block	Rule-based	Irradiance, temperature, PV system rating, BESS rating	Matlab-Simulink [®]	[13]
Energy balance	-	Multifunctional control	PV generation data, BESS rating	Matlab [®] , RSCAD-RTDS [®]	[14]
Energy balance	Analytical approximation	Electric system cascade analysis (ESCA) (rule-based)	Irradiance, temperature, sun altitude, latitude,	Matlab [®]	[15]
Energy balance	Isotropic solar radiation	Mixed-integer linear programming (MILP)	Irradiance, temperature, latitude, PV system rating, BESS rating	Matlab [®]	[16]
Energy balance	-	Monte-Carlo	PV generation data, BESS rating	Not indicated	[17]
Proprietary software	Proprietary software	Proprietary software	Irradiance, latitude and longitude, PV system rating, BESS rating	HOMER [®]	[18]
Voltage source in series with an internal resistor	-	PQ control	PV generation data, BESS rating	DIgSILENT [®]	[19]

One can notice the importance of accurate data for PV–BESS models from Table 1. As can be seen, most of the models require measurements of temperature and irradiance for an appropriate output. These data can be obtained from multiple sources of software such as Meteonorm[®] or SolarGIS[®], local meteorological institutes and international projects, as well as the ERA-Interim [20]. Nevertheless, forecasts are required to accurately predict the behavior of the system.

Although previous research has been published under the open access scheme, the complete details of how to implement the model presented have not been made available in its entirety [21–24]. Moreover, most of the literature uses proprietary software requiring a license purchase, as shown in Table 1. Therefore, this paper introduces an open-access platform (the repository can be found in [25]) for modeling and simulating a PV–battery system that can be included in the publicly available options for designing and understanding the dynamics of a PV–battery system for solar engineers and practitioners. Additionally, this article provides the possibility of choosing among two PV generation models based on the data available and the objective of the analysis.

1.2. Contributions

This paper contributes by

- Describing in detail two open-access models for PV systems that can be coupled with a BESS model, detailing how all the parts integrate into a general PV–BESS model;
- Proposing the most suitable uses for each PV system model, based on their inherent advantages and drawbacks and available data;
- Making available a model for two different modes of operation, i.e., a PV–BESS for peak-shaving applications and a PV–BESS system that maximizes self-consumption; and
- Demonstrating the dynamics of a PV–BESS system using both integrated models for peak-shaving and self-consumption applications, validating them with measurements of a PV system in Costa Rica.

2. PV-BESS Model

The open-access model consists of several parts, as shown in Figure 1. The PV modeling part is carried out to obtain the PV power. The energy management system (EMS) manages the energy flow between all the system components according to the mode of operation defined. The battery modeling keeps track, among other things, of the battery state-of-charge (SoC) to determine whether it can deliver, receive, or stay idle according to the energy management system. The PV model is considered an optimal orientation method, which provides the optimum tilt and azimuth of the PV array to obtain the maximum energy yield annually.




Figure 1. Block diagram of the PV-BESS model, considering the parameters for each instant k .

2.1. PV Modeling

In this section, we explain two approaches to calculating the power generated by a PV system: the meteorological data-based model and the Gaussian model. Both methods need a different set of inputs and have different advantages and limitations. This way, one can use the model that fits better according to the information available and project requirements.

2.1.1. Meteorological Data-Based Model

This model consists of three main parts: the solar calculator, PV system optimum orientation block for a specific objective (e.g., maximizing annual yield, yield during winter, or production during peak demand hours), and the thermal model. The inputs for the solar calculator are the location (latitude and longitude) of the PV system and the time frame where the analysis will be performed (date), as shown in Figure 2. Based on that, and following the procedure reported in [26], it is possible to express the position of the sun in terms of altitude (a_s) and azimuth (A_s). These two coordinates are calculated every time step k and are the PV system optimum orientation block inputs. This block also takes annual irradiance information to estimate the total irradiance over a PV module (G_m) for a specific orientation, i.e., azimuth (A_m) and inclination of the module (a_m). Note that the values of A_m and a_m are changed to find the combination that yields the maximum energy (in kWh/m²) over a year. This way, it is possible to study modules not optimally oriented due to installation constraints such as roof orientation.

Several equations are used as intermediate steps to arrive at the annual energy yield E_m . First, the cosine of the angle of incidence (θ_m) is calculated as

$$\cos(\theta_m(k)) = \cos(a_m) \cos(a_s(k)) \cos(A_m - A_s(k)) + \sin(a_m) \sin(a_s(k)). \quad (1)$$

Once angle of incidence is obtained based on the position of the sun using the solar calculator, one can calculate the direct irradiance (G_{direct}) as a function of the direct normal irradiance (DNI) as

$$G_{\text{direct}}(k) = \text{DNI}(k) \cos(\theta_m(k)). \quad (2)$$

Then, the diffuse irradiance (G_{diffused}) is calculated as

$$G_{\text{diffuse}}(k) = \text{DHI}(k) V_{\text{sky,factor}}(k), \quad (3)$$

where DHI is the global horizontal irradiance and $V_{\text{sky,factor}}$ is the sky view factor (fraction of the PV module facing the sky), calculated as

$$V_{\text{sky,factor}}(k) = \frac{1 + \cos(\theta_m(k))}{2}. \quad (4)$$

Moreover, the reflected irradiance results from the albedo (α), considered constant at a value of 0.2 in this article, and the global horizontal irradiance (GHI) can be calculated as

$$G_{\text{reflected}}(k) = \text{GHI}(k) \alpha [1 - V_{\text{sky,factor}}(k)]. \quad (5)$$

All the contributions of the irradiance over the plane of an array (G_m) can be computed as

$$G_m(k) = G_{\text{direct}}(k) + G_{\text{diffused}}(k) + G_{\text{reflected}}(k). \quad (6)$$

This gives the value of the irradiance falling into the PV modules for every timestep.

By integrating it, the total energy that can be potentially converted into electricity over a period of time is determined as

$$E_m = \int G_m(k) dt. \quad (7)$$

Once G_m is known, the power of the PV module can be calculated using

$$P_{\text{PV}}(k) = G_m(k) A_{\text{PV}} \eta_{\text{PV}}(k), \quad (8)$$

where the efficiency of the module is represented by η_{PV} , and A_{PV} is the area of the PV module. However, η_{PV} is heavily influenced by the temperature of the PV module. Therefore, the thermal model introduced by Duffie and Beckman in [27] considers it by including ambient temperature and wind speed. This model consists of an iterative process that assumes an initial temperature, and it is run through a loop until T_m converges to a particular value. With a known (T_m), the final efficiency of the PV module to be later used by Equation (8) is given by

$$\eta_{\text{PV}}(k) = \eta_{\text{STC}} [1 + \beta (T_m(k) - T_{\text{STC}})], \quad (9)$$

where η_{STC} is the efficiency at STC (standard test conditions), T_{STC} is the module temperature at standard test conditions (25 °C), and β is a temperature coefficient. For monocrystalline PV modules, β is normally taken as $-0.0035/^\circ\text{C}$.

As mentioned by [16], few studies estimated the effect of tilted PV arrays. The proposed meteorological data-based model considers it in two approaches: it can either estimate the optimal tilt angle for the modules or the output for any given tilt angle. This is especially useful for designers, as using the optimal tilt angle is not always possible. Moreover, the inputs required for this model are similar to other methods in the state-of-the-art (see Table 1), requiring temperature, irradiance, longitude and latitude, and the ratings of the PV and the BESS; and as it is a non-iterative process, the computational cost is very low. On the other hand, the outputs for real-time applications will not be precise if historical data is used. However, the output is expected to be accurate if measurements are used as input instead of historical data. Likewise, if the intention is to use the model to forecast, its

accuracy will highly depend on the quality of the predicted values for temperature and irradiance.




Figure 2. Block diagram of the meteorological data-based model to determine the optimal orientation for a given objective.

2.1.2. Gaussian Model

The stochastic behavior of the weather variables, such as temperature, wind speed, and irradiance, make it difficult to forecast the output of a PV system accurately. As indicated in Section 1.1, and demonstrated with the meteorological data-based model, a representative behavior is an alternative for precise calculations. On the other hand, ref. [28] proposed a simplified approximation for the ideal clear-sky solar curve, called *envelope curve*. The model is based on the Gaussian bell equation, associating the probability density with the daily specific energy production and using the error function, $erf(x)$, to adjust the output near sunrise and sunset. Using this approach, the maximum theoretical power during sun hours can be estimated as

$$P_s(t) = \frac{E_{PV}}{\sigma\sqrt{2\pi}} e^{-\frac{(t-\mu)^2}{2\sigma^2}} erf\left[-\frac{\alpha_1(t-t_{sr})}{\sigma\sqrt{2}}\right] erf\left[-\frac{\alpha_2(t-t_{ss})}{\sigma\sqrt{2}}\right], \quad (10)$$

where t_{sr} is the sunrise time, t_{ss} is the sunset time, and μ is the mean power time. E_{PV} is the output energy from the system given by

$$E_{PV} = P_{PV}^p E_{sd} \quad (11)$$

where P_{PV}^p is the peak power of the system and E_{sd} is the daily specific energy production per unit of power.

The Equation (10) also considers two fitting factors that can be adjusted based on previous meteorological measurements: α , related to the slope of the bell near the sunrise (α_1) and sunset time (α_2), and σ , related with the width of the bell. To avoid residual power values outside the sun hours, Equation (10) can be rewritten as

$$P_{PV}(t) = \begin{cases} 0 & t < t_{sr} \\ P_s(t) & t_{sr} < t < t_{ss} \\ 0 & t > t_{ss} \end{cases}. \quad (12)$$

Figure 3 shows the algorithm to implement the Gaussian model. First, one needs a dataset with measurements of the power output of a reference PV system, P_{PV}^{ref} , as well as the specific energy production, $E_{s,D}^{month, ref}$, sunrise time, $t_{sr}^{month, ref}$, and sunset time, $t_{ss}^{month, ref}$ for that location. Then, the fitting factors σ , α_1 , and α_2 have to be adjusted so the resulting envelope curve correlates with the envelope curve of the reference dataset. Once tuned, the model can be extrapolated for systems close to the reference system since the radiation conditions and the sunrise and sunset times would be similar.




Figure 3. Block diagram of the Gaussian model.

Unlike the meteorological-based (MDB) model, this model's results are helpful for preliminary energy-based approximations thanks to its low computational requirements and because it assumes evenly distributed meteorological data during specific timeframes. Note that the model's accuracy depends directly on the accuracy of the measurements, both the meteorological and the reference PV system datasets. Nevertheless, this model is not recommended for real-time control, as it does not consider the effect of cloudiness and temperature on instant power. This is a major drawback compared with the MDB model or the models reported in the literature (for example, the cases presented in Table 1). Still, this model was proposed for initial estimations instead of precise instant power calculations, so designers have a fast tool to estimate the yearly energy output of a PV system.

2.1.3. Battery Modeling

Among the main challenges of the massive deployment of PV systems in distribution networks is their non-controllable behavior. Such behavior causes sudden changes in the energy flow, leading to overvoltages or congestion issues [29]. Battery energy storage systems provide a solution, as they act as filters for those sudden changes, absorbing the surplus of energy and compensating deficits [30], providing flexibility to the electrical network. Furthermore, the advantages of BESS installed with PV systems go beyond the distribution system owner (DSO), as they can also benefit their owner economically. If the energy price varies in time, the storage system can purchase energy from the grid when the prices are lower, avoiding or reducing the purchase when the price is higher.

Consistently with most of the literature, we used an energy-balance approach to model the BESS. The energy stored in a BESS at a particular moment depends on its previous state and the amount of power extracted or provided between sampling times. This way, the state equation of the energy stored in the BESS can be written as

$$E_{\text{BESS}}(k+1) = C_{\text{BESS}}(k) \text{SoC}(k) + \frac{P_{\text{BESS}}(k)}{\eta^{c,d}} \Delta t - E_{\text{BESS}}^{\text{SD}}(k), \quad (13)$$

where E_{BESS} is the future amount of energy stored in the battery, C_{BESS} is the capacity of the battery, SoC is the state-of-charge of the battery, $\eta^{c,d}$ is the charge or discharge efficiency as it corresponds, P_{BESS} is the charge or discharge power as it corresponds, Δt is the sampling time, and $E_{\text{BESS}}^{\text{SD}}$ is the self-discharge of the battery between time samples.

Note that most of the variables from Equation (13) depend on external conditions. The capacity and charge and discharge efficiencies depend on the temperature and the depth of charge or discharge. Moreover, they decrease as the battery ages [31]. On the other hand, the state-of-charge cannot be calculated but has to be estimated. This estimation

will depend on the BESS technology, but in most cases, it can be estimated based on the battery's voltage [31].

For this work, we evaluated the models for two applications: maximize self-consumption and peak-shaving. For the first application, the EMS will meet the demand first by the PV and then by the BESS. If the combined power of the PV and BESS inverters is insufficient to supply the demand, the remaining power will be purchased to the grid. For the second application, the batteries will only cover the power demand above a certain threshold when the PV is insufficient and will charge only with the surplus of energy from the PV. Similar to the first application, the power from the BESS will be restrained by its inverter capacity, both for charging and discharging the batteries.

The flowchart in Figure 4 depicts the general control scheme. Note that both applications will follow the same logic, governed by two constraints: the state-of-charge of the battery and the permitted power from the grid, P_{Grid}^{perm} . The main difference is that the self-consumption will have a permitted power from the grid of 0 kW, whereas the peak-shaving will have a permitted power above 0 kW.




Figure 4. Flowchart for the peak-shaving algorithm.

3. Inputs to the Models

Figures 2 and 3 depict the algorithms behind the meteorological data-based and Gaussian models. The source code for both codes can be found in [25].

The meteorological-based model takes inputs such as ambient temperature, all the components of the solar irradiance (DNI, DHI, and GHI), and wind speed, as seen in Equations (2), (3), (5), (6) and (8). For this work, we used the software Meteonorm© as the source for a yearly (1 h timestep) dataset. It is essential to point out that the output datasets from Meteonorm© are constructed taking meteorological stations as a reference; thus, the data are adjusted based on location. Therefore, although the datasets correctly reflect the meteorological conditions of a particular place, they only partially fit datasets measured at the site of interest, as the data from meteorological software give information on a typical year while measuring data changes from year to year.

The Gaussian model only uses the daily average irradiance and requires a dataset of power output to tune the Gaussian bell equation. However, we used the same parameters used in [28] for two reasons: first, both systems are close enough, and second, because the purpose of this work is to provide models that can be used with available information before installing the system.

3.1. PV System Installed

We used measurements from a PV system installed at the University of Costa Rica to validate the results obtained with the models. This system comprises 17 modules of 265 W_p Canadian Solar, each connected to a P400 SolarEdge power optimizer and arranged in a single string to a 7.6 kW SolarEdge SE7600A-US inverter.

3.2. Load

The electrical load used was based on [32], where the average weekdays' electrical consumption for Costa Rica was reported. Two peaks characterize the load profile. One occurs at noon, while the other is at 6:00 pm, close to sunset (see Figure 5). This load can be easily replaced or used as a reference to be scaled up or down to study different cases.




Figure 5. Representative section of the electrical load considered for the test (graph created from the data provided in [32]).

To quantify the cost savings projected with the two models and compare them with the actual cost savings, we used a timeframe tariff shown in Table 2.

Table 2. Timeframe energy tariff considered.

Period	Timeframe	Cost (\$/kWh)
Night	00:01–06:00	0.04646
	20:01–00:00	
Valley	06:01–10:00	0.11102
	12:31–17:30	
Peak	10:01–12:30	0.27079
	17:30–20:00	

4. Results and Discussion

4.1. PV Generation


Figure 6 shows a representative week from the simulated year, considering simulation parameters indicated in Table 3. As can be seen, the Gaussian model considers a uniform curve throughout the month. As it does not consider cloudiness, its accuracy for real-time predictions is very low, as on June 26. Still, it can perform relatively well on sunny days, as on July 1. On the other hand, the meteorological data-based model depends on weather conditions. This way, it can recreate sudden changes in power due to meteorological conditions, as on July 2. We must highlight that the results of the meteorological data-based model do not coincide with the real-time variations because we used historical data. However, the MDB includes the seasonal effects on PV generation from an energy and power perspective.

Table 3. Parameters for the simulations.

Parameter	Symbol	Value	Unit
BESS			
Energy	E_{BESS}	10.78	kWh
Power of the converter	$p_{\text{BESS}}^{\text{max}}$	0.5	kW
Charging efficiency	η^c	97	%
Discharging efficiency	η^d	97	%
Initial state-of-charge	$\text{SoC}(0)$	50	%
Minimum state-of-charge	SoC_{min}	20	%
Maximum state-of-charge	SoC_{max}	80	%
PV system			
Peak power	P_{PV}^p	5.525	kW
Power of the inverter	P_{inv}	7.6	kW
Tilt of the modules	a_m	10.5	°
Azimuth of the modules	A_m	200	°
Albedo coefficient	α	0.2	
Module efficiency at STC	η_{STC}	16.19	%
Thermal coefficient	β	−0.0035	

As tools for preliminary assessment of monthly PV generation, the models showed an acceptable accuracy, as detailed in Figure 7. For this purpose, the Gaussian model performed better, with a monthly error ranging from −20.7% and 25.3%, with an average of 1.456%. The MDB model, on the other hand, had a monthly error ranging from −15.8% and 37.18%, with an average of 17.74% (the error was considered as the difference between the total accumulated energy resulting from the measurements and each model, divided by the total accumulated energy from the measurements). The reason behind this behavior is similar to the analysis of the real-time comparison presented above. Since the Gaussian model is based on monthly values gathered from PV power measurements from previous years, the representative behavior of more extended periods (such as months) performs better than short periods (such as specific days). Similarly, it is less sensitive than the MDB model, which depends on meteorological data that vary yearly.

In the case of having actual measured meteorological data as inputs to the MDB model, it will undoubtedly perform better than using historical data as provided by the software Meteonorm© or the Gaussian Model. Similarly, the PV generation curves from the MDB model represent more realistically the behavior of partially cloudy days than the Gaussian Model. The Gaussian model and the MDB adequately represent the behavior expected during sunny days regarding the PV generation profile.

**Figure 6.** Comparison of the instant power measured and the results obtained with the Gaussian model and the meteorological data-based model during a representative week.




Figure 7. Comparison of the measured monthly accumulated energy and forecasted by the Gaussian model and the MDB meteorological data-based model.

4.2. PV-BESS

We also modeled a BESS to evaluate its combined behavior with the PV system with two objectives: maximize self-consumption and perform peak-shaving. The inverter of the PV system and the inverter of the BESS are connected with an AC coupling. The proposed models allow the designer to adjust the different parameters for the PV and BESS systems.

Table 3 shows the parameters used to simulate the BESS. With this information, the power flow balance is implemented to make decisions regarding the operation of the battery pack, i.e., charging (positive power), discharging (negative power), or idle (zero output power). It is important to note that the battery capacity can be easily changed. Thus, an iterative process can be performed to progressively increase the battery capacity to quantify energy exchange and electricity costs. This way, the optimal PV-battery system sizing can be determined.

4.2.1. Self-Consumption

As mentioned before, the EMS can influence the power magnitude and direction, ensuring a specific mode of operation to fulfill a predefined objective. In this case, the main objective is to supply the electrical load only via the PV system and the BESS. Therefore, the energy purchased from the grid can be minimized.

To validate the performance of the models under self-consumption schemes, we defined a permitted purchase power of 0 W ($P_{\text{perm}} = 0$). This way, the algorithm will always prioritize supplying the demand from the BESS. Figure 8 shows a representative section of the simulated year. As expected, the BESS cannot supply the load entirely in the absence of PV availability, as the power demand is higher than the capacity of the BESS inverter. Thus, power is purchased from the grid. Similarly, when the available PV power surpasses the load, the BESS is charged, constrained by the inverter's nominal capacity, returning the excess to the grid.

Complementary to the power exchange shown in Figure 8, the behavior of the SoC of the BESS is shown in Figure 9 for the measured PV power and the two models. One can notice that the SoC curves overlap at the beginning until the PV power becomes available. Given the uniformity of the Gaussian model, the charge and discharge behavior is consistent between days. For the MDB model, the effects of the meteorological conditions are present when the PV power drops below the load near sunset. The power used to charge the BESS drops for short periods, usually during the evening.



Figure 8. Comparison of (a) the instant power measured and the results obtained with (b) the Gaussian model and (c) the meteorological data-based model during a representative week, considering a self-consumption scenario.

The costs associated with coupling the PV and BESS systems for each PV curve (measurements, Gaussian model, and MDB model) are presented in Table 4. As can be seen, both models propose lower costs than the reference scenario. The reference scenario considers the measured PV instant power.




Figure 9. SoC of the battery during the self-consumption operation.

The Gaussian model predicts costs 2.89% less than the reference scenario, while the MDB model predicts 17.49% lower costs than the reference scenario. This difference can be explained because of the input variables for each model. As demonstrated in Section 4.1, the Gaussian model uses representative available irradiance per month. Thus, the overall results are expected to be closer to the reference scenario. The MDB model, on the other hand, depends on more variables, making it less preferable to predict long periods.

Table 4. Comparison of the monthly energy costs considering an average daily consumption of 40 kWh under a self-consumption operation.

Month	Measurements (\$)	Gauss Model (\$)	MDB Model (\$)
January	75.36	53.29	47.70
February	47.63	45.02	40.24
March	27.31	49.66	48.68
April	44.98	63.52	48.01
May	83.08	74.59	55.72
June	83.69	74.44	66.90
July	84.48	80.29	64.87
August	76.90	76.49	65.02
September	62.45	71.46	57.17
October	77.60	79.52	70.55
November	79.77	74.98	60.49
December	87.74	63.69	60.28
Total	830.98	806.95	685.64

4.2.2. Peak-Shaving

To perform peak-shaving, we attempted to keep the load under a specific value by reducing the power supplied from the grid. In this case, we considered a maximum permitted load of 1.5 kW. To do so, the PV power is directly fed to the load, and if the PV power is not enough to satisfy the load, the battery pack delivers the remaining power to the load if the SoC is above 20%.

The results are presented in Figure 10. As can be seen, the BESS provides power to supply part of the load only when it surpasses the threshold of 1.5 kW. Nevertheless, if the load is above 2 kW, the difference should be provided from the grid, as the BESS inverter is at its maximum capacity of 500 W. As a result, the power from the grid is drastically reduced during the day, and once the PV generation reduces, the BESS delivers power to fulfill the 2 kW goal.

Increasing or decreasing the maximum peak power from the grid affects the SoC behavior of the BESS and the battery inverter. Figure 10b shows that the BESS never reaches the minimum SoC allowed. Likewise, near noon, the BESS charges completely. This way, the BESS distributes its energy more effectively throughout the day. In this

case, the battery is not fully cycled for the nominal PV capacity defined during the day. Therefore, parameters such as the maximum load peak or battery inverter power rating can be changed to optimize the system sizing.




Figure 10. Power exchange using as a reference measured instant power measured (a), and (b) SoC of the battery during the peak-shaving operation, considering a maximum allowed power purchased from the grid of 1.5 kW.

5. Conclusions

It is fundamental to have open-access to simulation tools able to reproduce the dynamic behavior of PV-BESS, especially for practitioners. Accordingly, this paper gives a detailed description of all the stages needed to adequately express the nature of the PV-BESS system in terms of power and energy. Two models to estimate PV generation were documented and compared to an experimental dataset. Such models use similar data inputs to the models reported in the literature and are not computationally expensive, thanks to their non-iterative nature. Choosing one model over another is related to the data availability of the particular site of interest and the user's purpose. Based on our results, the Gaussian model is beneficial for yearly energy-based estimations. In contrast, the meteorological data-based model is better for understanding the variable behavior of PV systems and can be used for real-time control if measurements are available as inputs instead of historical data. Moreover, the MDB model considers the PV modules' tilt to determine the optimal angle or evaluate the modules on any given angle, a condition omitted in many models in the literature. Since we used historical data, the results of the MDB model do not coincide with the real-time variations. Still, for more prolonged analysis, it can resemble the seasonality effect regarding cloudiness and temperature. Nevertheless, it would be suitable for short-term predictions if predicted values for the meteorological variables are provided.

Then, we evaluated two EMS operation modes for the PV-BESS system: maximize self-consumption and peak-shaving. In both cases, the model allocates the power without violating the maximum BESS power. In our case scenario, the Gaussian model performed better on energy estimation, with an average error of 1.456% vs. the 17.74% of the MDB model, both compared to monthly energy measurements. When coupling the BESS model, the predicted energy costs with the Gaussian model were 2.89 and less than the actual costs, while the MDB model predicted costs of 17.49% more than the actual costs. Both behaviors are explained by the input data and how the model performs in the longer term. As the Gaussian model considers an evenly distributed energy production per month, it is expected to represent better periods as months or years. On the other hand, in the short term, it becomes less accurate, as it does not consider weather conditions. In those cases, the MDB model outperforms the Gaussian model.

Further research includes the development of accurate short-term weather predictions so that the EMS can use the MDB model for predictive control. Additionally, implementing other ancillary services than peak-shaving can be useful to evaluate the flexibility PV-BESS systems can provide to the grid.

Author Contributions: J.A.-C. and V.V.-G.: conceptualization, formal analysis methodology, software, original draft preparation, and review and editing L.R.-E. and N.N.: review and editing. All authors have read and agreed to the published version of the manuscript.

Funding: This research received no external funding.

Data Availability Statement: Publicly available datasets were analyzed in this study. This data can be found here: https://github.com/jjac13/PV_BESS_model.

Acknowledgments: This investigation was carried out under the research project “Detección de fallas, control e integración de sistemas de energías renovables no convencionales con almacenamiento energético para redes inteligentes” number C1467 of the University of Costa Rica.

Conflicts of Interest: The authors declare no conflict of interest.

Abbreviations

The following abbreviations are used in this manuscript:

BESS	Battery Energy Storage System
DG	Distributed Generation
DR	Demand Response
DSO	Distribution System Operators
EMS	Energy Management Systems
ESS	Energy Storage Systems
RES	Renewable Energy Sources
SoC	State-of-Charge

References

- IRENA. *World Energy Transitions Outlook: 1.5 °C Pathway*; IRENA: Masdar City, United Arab Emirates, 2021; pp. 1–312.
- Alpizar-Castillo, J.; Ramírez-Elizondo, L.; Bauer, P. The Effect of Non-Coordinated Heating Electrification Alternatives on a Low-Voltage Distribution Network with High PV Penetration. In Proceedings of the 2023 IEEE 17th International Conference on Compatibility, Power Electronics, and Power Engineering (CPE-POWERENG), Tallinn, Estonia, 14–16 June 2023.
- Alpizar-Castillo, J.; Ramirez-Elizondo, L.; Bauer, P. Assessing the Role of Energy Storage in Multiple Energy Carriers toward Providing Ancillary Services: A Review. *Energies* **2023**, *16*, 379. [CrossRef]
- IRENA. *Renewable Power Generation Costs in 2021*; IRENA: Masdar City, United Arab Emirates, 2022.
- Alotaibi, I.; Abido, M.A.; Khalid, M.; Savkin, A.V. A comprehensive review of recent advances in smart grids: A sustainable future with renewable energy resources. *Energies* **2020**, *13*, 6269. [CrossRef]
- Van Sark, W. Photovoltaic System Design and Performance. *Energies* **2019**, *12*, 1826. [CrossRef]
- PVsyst—Logiciel Photovoltaïque. 2023. Available online: <https://www.pvsyst.com/fr/> (accessed on 17 February 2023).
- PV*SOL—Plan and Design Better pv Systems with Professional Solar Software | PV*SOL and PV*SOL Premium. 2023. Available online: <https://pvsol.software/en/> (accessed on 17 February 2023).

9. Sanjari, M.J.; Gooi, H.B. Probabilistic Forecast of PV Power Generation Based on Higher Order Markov Chain. *IEEE Trans. Power Syst.* **2017**, *32*, 2942–2952. [\[CrossRef\]](#)
10. Carriere, T.; Vernay, C.; Pitaval, S.; Kariniotakis, G. A Novel Approach for Seamless Probabilistic Photovoltaic Power Forecasting Covering Multiple Time Frames. *IEEE Trans. Smart Grid* **2020**, *11*, 2281–2292. [\[CrossRef\]](#)
11. Bessa, R.J.; Trindade, A.; Silva, C.S.; Miranda, V. Probabilistic solar power forecasting in smart grids using distributed information. *Int. J. Electr. Power Energy Syst.* **2015**, *72*, 16–23. [\[CrossRef\]](#)
12. Li, G.; Guo, S.; Li, X.; Cheng, C. Short-term Forecasting Approach Based on bidirectional long short-term memory and convolutional neural network for Regional Photovoltaic Power Plants. *Sustain. Energy Grids Netw.* **2023**, *34*, 101019. [\[CrossRef\]](#)
13. Rana, M.M.; Romlie, M.F.; Abdullah, M.F.; Uddin, M.; Sarkar, M.R. A novel peak load shaving algorithm for isolated microgrid using hybrid PV-BESS system. *Energy* **2021**, *234*, 1157. [\[CrossRef\]](#)
14. Rezaul Alam, M.; Alam, M.; Saha, T.K.; Sohrab Hasan Nizami, M. A PV variability tolerant generic multifunctional control strategy for battery energy storage systems in solar PV plants. *Int. J. Electr. Power Energy Syst.* **2023**, *153*, 109315. [\[CrossRef\]](#)
15. Singh, R.; Bansal, R.; Singh, A.R. Optimization of an isolated photo-voltaic generating unit with battery energy storage system using electric system cascade analysis. *Electr. Power Syst. Res.* **2018**, *164*, 188–200. [\[CrossRef\]](#)
16. Duman, A.C.; Erden, H.S.; Gönül, Ö.; Güler, Ö. Optimal sizing of PV-BESS units for home energy management system-equipped households considering day-ahead load scheduling for demand response and self-consumption. *Energy Build.* **2022**, *267*, 112164. [\[CrossRef\]](#)
17. Hassan, M.U.; Saha, S.; Haque, M.E. A framework for the performance evaluation of household rooftop solar battery systems. *Int. J. Electr. Power Energy Syst.* **2021**, *125*, 106446. [\[CrossRef\]](#)
18. Kim, I.; James, J.A.; Crittenden, J. The case study of combined cooling heat and power and photovoltaic systems for building customers using HOMER software. *Electr. Power Syst. Res.* **2017**, *143*, 490–502. [\[CrossRef\]](#)
19. Li, Q.; Tao, Y.; Li, Z.; Zhang, Y.; Zhang, Z. Simulation and modeling for active distribution network BESS system in DIgSILENT. *Energy Rep.* **2022**, *8*, 97–102. [\[CrossRef\]](#)
20. ERA-Interim. *Climate Data Guide*; National Center for Atmospheric Research: Boulder, CO, USA, 2018.
21. Narayan, N.; Papakosta, T.; Vega-Garita, V.; Qin, Z.; Popovic-Gerber, J.; Bauer, P.; Zeman, M. Estimating battery lifetimes in Solar Home System design using a practical modelling methodology. *Appl. Energy* **2018**, *228*, 1629–1639. [\[CrossRef\]](#)
22. Vega-Garita, V.; Hanif, A.; Narayan, N.; Ramirez-Elizondo, L.; Bauer, P. Selecting a suitable battery technology for the photovoltaic battery integrated module. *J. Power Sources* **2019**, *438*, 227011. [\[CrossRef\]](#)
23. Narayan, N.; Vega-Garita, V.; Qin, Z.; Popovic-Gerber, J.; Bauer, P.; Zeman, M. A modeling methodology to evaluate the impact of temperature on Solar Home Systems for rural electrification. In Proceedings of the 2018 IEEE International Energy Conference, ENERGYCON 2018, Limassol, Cyprus, 3–7 June 2018. [\[CrossRef\]](#)
24. Vega-Garita, V.; De Lucia, D.; Narayan, N.; Ramirez-Elizondo, L.; Bauer, P. PV-battery integrated module as a solution for off-grid applications in the developing world. In Proceedings of the 2018 IEEE International Energy Conference, ENERGYCON 2018, Limassol, Cyprus, 3–7 June 2018. [\[CrossRef\]](#)
25. Alpízar-Castillo, J.; Vega-Garita, V. PV BESS Model. 2023. Available online: https://github.com/jjac13/PV_BESS_model (accessed on 6 of June 2023).
26. US Naval Observatory Astronomical Applications Department. Computing Approximate Solar Coordinates. 2023. Available online : https://aa.usno.navy.mil/faq/sun_approx (accessed on 17 February 2023).
27. Duffie, J.A.; Beckman, W.A. *Solar Engineering of Thermal Processes*; Wiley: Hoboken, NJ, USA, 2013; p. 936.
28. Alpízar-Castillo, J. Simplified Model to Approach the Theoretical Clear Sky Solar PV Generation Curve through a Gaussian Approximation. *Niger. J. Technol.* **2021**, *40*, 44–48. [\[CrossRef\]](#)
29. Wang, L.; Yan, R.; Saha, T.K. Voltage regulation challenges with unbalanced PV integration in low voltage distribution systems and the corresponding solution. *Appl. Energy* **2019**, *256*, 113927. [\[CrossRef\]](#)
30. Datta, U.; Kalam, A.; Shi, J. Smart control of BESS in PV integrated EV charging station for reducing transformer overloading and providing battery-to-grid service. *J. Energy Storage* **2020**, *28*, 113927. [\[CrossRef\]](#)
31. Stecca, M.; Elizondo, L.R.; Soeiro, T.B.; Bauer, P.; Palensky, P. A comprehensive review of the integration of battery energy storage systems into distribution networks. *IEEE Open J. Ind. Electron. Soc.* **2020**, *1*, 46–65. [\[CrossRef\]](#)
32. ICE. *Plan de Expansión de la Generación Eléctrica 2018–2034*; Technical Report; ICE: London, UK, 2019.

Disclaimer/Publisher’s Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.