

Guidance to assess ventilation performance of a classroom based on CO2 monitoring

Zhang, D.; Ding, Er; Bluysen, P.M.

DOI

[10.1177/1420326X211058743](https://doi.org/10.1177/1420326X211058743)

Publication date

2022

Document Version

Final published version

Published in

Indoor and Built Environment

Citation (APA)

Zhang, D., Ding, E., & Bluysen, P. M. (2022). Guidance to assess ventilation performance of a classroom based on CO2 monitoring. *Indoor and Built Environment*, 31(4), 1107-1126.
<https://doi.org/10.1177/1420326X211058743>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.



Guidance to assess ventilation performance of a classroom based on CO₂ monitoring

Dadi Zhang , Er Ding and Philomena M. Bluysen

Abstract

Since the COVID-19 pandemic, the ventilation of school buildings has attracted considerable attention from the general public and researchers. However, guidance to assess the ventilation performance in classrooms, especially during a pandemic, is still lacking. Therefore, aiming to fill this gap, this study conducted a full-scale laboratory study to monitor the CO₂ concentrations at 18 locations in a classroom setting under four different ventilation regimes. Additionally, a field study was carried out in two Dutch secondary schools to monitor the CO₂ concentrations in the real classrooms with different ventilation regimes. Both the laboratory and field study findings showed that CO₂ concentrations varied a lot between different locations in the same room, especially under natural ventilation conditions. The outcome demonstrates the need of monitoring the CO₂ concentration at more than one location in a classroom. Moreover, the monitored CO₂ concentration patterns for different ventilation regimes were used to determine the most representative location for CO₂ monitoring in classrooms. For naturally ventilated classrooms, the location on the wall opposite to windows and the location on the front wall (nearby the teacher) were recommended. For mechanically ventilated classrooms, one measurement location seemed enough because CO₂ was well-mixed under this ventilation regime.

Keywords

CO₂ concentration, monitoring guidance, measurement locations, ventilation regimes, classrooms

Accepted: 22 October 2021

Introduction

The ongoing pandemic of the Coronavirus disease 2019 (COVID-19) has created public concern about indoor air quality (IAQ) and room ventilation, especially in public spaces with many people such as school buildings. To determine whether such a space is ventilated properly, the CO₂ concentration is monitored and used as a proxy for ventilation performance.¹ The history of CO₂ as an indicator of the amount of ventilation can be traced back to 1858.^{2,3} Later, CO₂ monitoring became gradually a convenient way to monitor IAQ.^{4–6} A CO₂ concentration of 1800 mg/m³ (or 1000 ppm) was often taken as the upper limit for a good IAQ, according to the previous version of ASHRAE (American Society of Heating, Refrigerating and Air-Conditioning Engineers) Standard 62-1989, Ventilation for Acceptable Indoor Air Quality. Currently, relevant standards⁷ mainly use minimum ventilation rates as the

design criteria, while CO₂ is the most commonly used tracer gas for calculating ventilation rate.^{8–10} To date, many studies have been conducted to measure the CO₂ concentration in school classrooms around the world to examine whether the ventilation performance in classrooms fulfils the requirements.^{9,11–13} However, CO₂ monitoring protocols used in these studies varied a lot: the selected number and location of sensors mainly depended on researchers'

Chair Indoor Environment, Faculty of Architecture and the Built Environment, Delft University of Technology, Delft, The Netherlands

Corresponding author:

Dadi Zhang, Chair Indoor Environment, Faculty of Architecture and the Built Environment, Delft University of Technology, Delft 2600 AA, the Netherlands.
Email: d.zhang-2@tudelft.nl

personal experiences.¹⁴ It seems that no consistent guidance for CO₂ monitoring exists, yet.

One of the key standards for CO₂ monitoring is the ISO 16000-26,¹⁵ according to which the sampling location is suggested to be at the centre of the room with a height of 1.0–1.5 m above the floor, representing the breathing zone of occupants. However, in ANSI/ASHRAE Standard 62.1,¹⁶ the height of the breathing zone is described as 0.75–1.8 m above the floor and based on that the LEED recommends 0.9–1.8 m above the floor as the sampling height for CO₂.¹⁷ In terms of the horizontal location, instead of the centre, ASTM International (former American Society for Testing and Materials)¹⁰ stipulates that the measurement point should be 2.0 m away from occupants to avoid local effects. Apart from the location of the sampling point, little information about the number of measurement points can be found in current standards.

In the Netherlands, the Fresh Schools 2021 program (Programma van Eisen Frisse Scholen 2021) is the most used guidance on the indoor environment quality in school buildings. In this guidance, the ventilation rate is suggested for three different levels: level A, B and C.¹⁸ However, no requirement regarding the monitoring protocol, including the number and location of the measurement point, can be found in this guidance. This lack of clear guidance on CO₂ monitoring can lead to inaccurate results since the indoor CO₂ concentration might vary per location.¹⁹

Several studies have proposed that a single measurement location could be appropriate for rooms with high ventilation rates and constant occupancy.^{20–22} Accordingly, many researchers only selected one measurement point, usually at the centre of the room or in the occupied area.^{23–25} For example, both the study conducted by Hou et al.²⁴ in four classrooms of two primary schools in Beijing, China, and the study carried out by Schibuola et al.²³ in three classrooms of two secondary schools in Italy, measured the CO₂ concentration in the middle of classrooms. Similarly, Bako-Biro et al.²⁶ also measured the CO₂ concentration only at one point near occupants in 16 classrooms of eight primary schools in the UK to investigate the ventilation conditions in these classrooms. However, based on the results found by Cao et al.²⁷ and Mui et al.,²⁸ the CO₂ distribution in a room is not spatially consistent, which means that measurements at a single point cannot be representative of the average concentration in the whole room. Such disadvantage was taken into consideration by several other studies, in which the authors selected multi-points to increase the measurement accuracy.^{29–31} For example, the study carried out by Franco and Lecces³² in which four locations were selected in the larger classrooms to minimise the influence of the location of the sensors. The studies performed by Wargocki^{33,34} in two classrooms in which the CO₂ concentrations were measured at three locations: supply, exhaust and occupied areas to achieve an accurate calculation of ventilation rates. The CFD

simulation studies conducted by Cao et al.²⁷ and Ren and Cao³⁵ in which at least three sensors were recommended to be used to obtain more information.

Apart from the number of measurement points, the height of measurement points selected by previous researchers also varied among different studies, due to a lack of consistent guidance. The most common measurement points were near the seated height in classrooms,^{26,31,36,37} 1.1 m^{30,38,39} and 1.2 m,^{24,40,41} while the highest could be 2.2 m^{33,34} and the lowest could be 0.65 m⁴² above the floor. Besides these studies, other researchers did not provide clear information about measurement locations.^{11,12,43}

In addition to measurement locations, researchers' opinions on the monitoring of outdoor CO₂ concentration also do not concur. Some researchers measured the CO₂ level at one outdoor location per school together with the indoor ones,⁴⁴ others measured outside the windows of each of the target classrooms⁴⁵ and some just used the empirical constant such as 350 or 400 ppm as the outdoor CO₂ concentration.⁴⁶ Since the outdoor CO₂ concentration can also vary depending on the location and the time,⁴⁷ the different outdoor CO₂ monitoring procedures may affect the accuracy of the investigation. Moreover, considering the influence of occupants' number, age and activities on CO₂ generation, the related inspection and recording should be specified as well.⁴⁷

Given the fact that the CO₂ concentration might vary between different indoor locations,¹⁹ and the CO₂ distribution might be different under different ventilation regimes, a detailed CO₂ monitoring protocol including different strategies that are applicable for different ventilation regimes is needed to better assess the ventilation conditions in classrooms. To achieve that, full-scale experiments with multiple measurement locations, as suggested by Mahyuddin and Awbi,¹⁴ should be carried out under different ventilation conditions. Therefore, this study aims to (1) conduct a full-scale experiment in the SenseLab⁴⁸ to better understand the CO₂ distribution in a room under different ventilation regimes; (2) develop consistent CO₂ monitoring guidance and (3) to perform a field study to validate and improve this guidance.

Methods

Full-scale experiment

The full-scale monitoring of the CO₂ distribution was conducted on the 9th of March 2020 in the Experience room of the SenseLab at Delft University of Technology.⁴⁸ The Experience room has a size of 6.5 (l) × 4.2 (b) × 2.6 (h) m³, with two windows and one door, and the interior design was set as a classroom. Six subjects (three males and three females) were seated in the Experience room. All the subjects were graduate students from the Delft University of

Technology aged between 26–32 years and in good health. Before the experiment began, a short introduction was given to the subjects, and they were asked to sit at fixed locations (with 1.5 m between each other) and perform sedentary work during the whole experiment. The detailed experimental procedure and ventilation regimes are shown in Table 1.

The CO₂ measurements were conducted for four different ventilation regimes: (1) mixing ventilation with a ventilation rate of 600 m³/h (air exchange rate of 8.8 h⁻¹ with air velocity of 0.03 m/s measured at air inlets, which was chosen based on the adjustable range of the ventilation system of the SenseLab and the level suggested by ASHRAE (air exchange rate 4–6 h⁻¹);¹⁶ (2) natural ventilation with windows open; (3) no ventilation, with the mechanical system turned off and windows and door closed and (4) natural ventilation with windows and door open. Each regime lasted 50 minutes, which is approximately the duration of one normal lesson at Dutch secondary schools (based on the observation in the field study). To reset the CO₂ concentration to the default level (outdoor concentration), a ten-minute break between two test conditions was introduced. Considering the ventilation capacity of the system used in the Experience room and the time constraints, the ventilation rate was set to 1200 m³/h during the break. The CO₂ concentration was measured and recorded every 30 s by HOBO[®] CO₂ loggers (type: MX1102), with an accuracy of ±50 ppm ±5% of reading in the range of 0–5000 ppm.

To get a comprehensive understanding of the CO₂ distribution, 18 indoor and one outdoor measurement points were selected to perform the monitoring simultaneously. As shown in Figure 1, six sensors were placed on desks at a height of 1.1 m above the floor (position ‘D’); two sensors were placed at the centre of the room (position ‘C’) at a height of 1.1 m and 1.6 m above the floor (to represent the height of the head when sitting and standing, respectively); two sensors were placed at the teacher’s location (position ‘T’) at a height of 1.1 m (sitting) and 1.6 m (standing) above the floor; eight sensors were placed on the four walls (position ‘W’) also at a height of 1.1 m and 1.6 m above the floor and one sensor was placed outside one window (position ‘O’) to measure the outdoor CO₂ concentration.

Field study

After agreement with school principals, a field study was carried out in two secondary schools located in two cities in the Netherlands, during April and May 2021. The first school, located in the urban area of Hilversum, was built in 1975 and renovated in 2006. The second school, located in the rural area of Amersfoort, was built in 1960 and renovated in 2013. In total, seven classrooms with different ventilation regimes were selected to represent four commonly used ventilation regimes (namely, natural (N), mechanical

supplied (MS), mechanical exhausted (ME) and mechanical balanced (MB) ventilation) in Dutch secondary school classrooms. All classrooms had similar educational furniture and were designed for similar occupancy (around 30 school children and one teacher). Basic information of selected classrooms is presented in Table 2.

Based on the results of the full-scale experiment, three to four indoor locations were selected for CO₂ measurements in each classroom. Consistent with the experiment, the HOBO[®] CO₂ loggers were used to monitor CO₂ concentrations. To avoid interfering with students’ normal activities and the risk of equipment damage, all indoor measurement points were selected away from the active area. Therefore, as shown in Figure 2, all sensors were installed on the wall using adhesive strips. Apart from indoor measurement points, two outdoor points (one in front of the school building, the other one in the schoolyard) were selected to collect the real-time data of outdoor CO₂. Measurements were conducted over 1 day per school, starting from the first lesson until the last lesson on the day.

To track the occupancy and the operation of windows and doors in the investigated classrooms, observations were performed by researchers once per hour during the monitoring period. Besides, detailed information of school buildings, especially about ventilation systems used in classrooms, was collected by interviewing the school facility managers and with building inspections. Furthermore, teachers in investigated classrooms were asked to fill out an observational questionnaire which included the number of students and their actions (open/close windows/doors) during each lesson.

Data analysis


For the experiment, all collected data were imported and analysed in five steps using SPSS version 23.0 (SPSS Inc. Chicago, IL, USA). First, the results collected from the last 5 minutes of each condition were compared with each other using one-way ANOVA to check whether they reach a steady state. Second, basic information (e.g., the mean and standard deviation of these parameters) was analysed with descriptive statistics. Third, the difference between CO₂ concentrations at two different heights was compared at five locations (four walls and the centre), separately, with paired samples t-test. Then, CO₂ concentrations between different horizontal locations at the same height were compared with one-way ANOVA. Finally, CO₂ concentrations were compared between different ventilation regimes with one-way ANOVA.

For the field study, the collected data were imported and analysed using SPSS in four different steps. First, as with the lab study, the steady state of CO₂ concentrations during the last 5 minutes of each lesson period at each classroom was checked with one-way ANOVA. Second, data screening

Table 1. Experimental procedure and ventilation regimes.

Time interval	Ventilation regimes
13:00–13:20	Introduction (outside the Experience room)
13:20–14:10	1) Mechanical ventilation: 600 m ³ /h mixing ventilation
14:10–14:20	Break ^a , 1200 m ³ /h mixing ventilation
14:20–15:10	2) Natural ventilation: open windows
15:10–15:20	Break, 1200 m ³ /h mixing ventilation
15:20–16:10	3) No ventilation
16:10–16:20	Break, 1200 m ³ /h mixing ventilation
16:20–17:10	4) Natural ventilation: open windows and door

^aDuring each break the subjects were asked to leave the room to flush the indoor air.

**Figure 1.** Distribution of sensors in the Experience room.**Table 2.** Characteristics of the investigated classrooms.

School no	Classroom no	Dimensions, l × w × h, (m)	Volume (m ³)	Design occupant load	No. of operable windows	Orientation of the windows	Ventilation regime
1	C1-1	10.0 × 5.2 × 2.7	140.4	30	4	North	MB
	C1-2	8.3 × 6.4 × 2.8	148.7	30	2	South	N
	C1-3	8.3 × 6.4 × 2.8	148.7	30	2	North	N
	C1-4	8.3 × 5.3 × 3.6	158.4	30	1	West	MS
2	C2-1	6.8 × 7.0 × 3.4	161.8	30	5	Southwest	ME_CO ₂
	C2-2	7.2 × 7.1 × 3.2	163.6	30	6	Northeast	MS
	C2-3	11.9 × 8.4 × 2.8	279.9	30	3	Southeast	ME

MB: mechanical balanced ventilation; N: natural ventilation; MS: mechanical supplied ventilation; ME: mechanical exhaust ventilation; ME_CO₂: CO₂ controlled mechanical exhaust ventilation.




Figure 2. Example of CO₂ measurement locations in real classrooms.

was performed based on z-scores, where all the data with a z-score (absolute value) higher than 3 were seen as outliers and thus eliminated.⁴⁹ Third, a series of descriptive analyses were carried out to get a preliminary understanding of the data. Lastly, the comparisons among different sampling points within the same classrooms were conducted by one-way ANOVA.

Results

Full-scale experiment

The variation of CO₂ concentrations in 18 measurement points (17 indoor and 1 outdoor) during different monitoring periods is shown in Figure 3. The results recorded by the device located at the teacher's location (1.1 m) was excluded because of an operational error. CO₂ concentrations at the outdoor point hardly changed during the whole time. For indoor points, generally speaking, the variation trend of CO₂ at different points were similar: during the first condition ('600 m³/h mixing'), CO₂ concentrations were relatively steady and low. During the 'break' period, CO₂ concentrations were reduced by a small margin. Under the second condition with 'open windows', CO₂ concentrations

were increased at the beginning but were kept steady later. Under the third condition with 'no ventilation', CO₂ concentrations were increased substantially and with a large amplitude. Under the last condition of the experiment with 'open windows and door', CO₂ concentrations were reduced sharply at the beginning and then became steady at the end.

General results. Results of the one-way ANOVA tests showed differences in CO₂ concentration between last 10 measurements (i.e., 5 min) of all tested conditions and were not significant. This indicated that the CO₂ concentration reached a steady state in the last 5 minutes of measurements in all conditions. Therefore, results obtained during last 5 minutes of measurements under all conditions were the main focus of this study, and the descriptive analysis results of the CO₂ concentration monitored during these periods are shown in Figure 3. For all indoor measurement points, conditions under 'mixing ventilation (600 m³/h)' and 'open windows and door' showed the best performance, in terms of keeping the lowest CO₂ concentration, followed by 'open windows', while the 'no ventilation' condition was the worst. The average CO₂ concentrations at 17 indoor points were similar under 'mixing ventilation' (570 ppm) and 'open




Figure 3. CO₂ concentrations monitored at different locations in a classroom setting. *Note:* The CO₂ concentrations were monitored at 17 points in a classroom setting with six occupants under four ventilation regimes: ‘600 m³/h mixing ventilation’, ‘open windows’, ‘no ventilation’ and ‘open door and windows’. The orange boxes represent the breaks (1200 m³/h, without occupants) between each monitored condition. Note: C: centre, two heights (1.1 m and 1.6 m); D: desk, 1.1 m; O: outdoor, 1.1 m; T: teacher, two heights (1.1 m and 1.6 m); and W: wall, two heights (1.1 m and 1.6 m).




Figure 4. CO₂ distribution in the Experience room with different ventilation regimes.

windows and door' (593 ppm). However, the variation range among these points was much larger under the condition 'open windows and door' (497–711 ppm) than under 'mixing ventilation' (515–626 ppm). This demonstrates the uneven distribution of CO₂ under natural ventilation.

Among 18 measurement points, the lowest CO₂ concentration always appeared at the outdoor point, and the result measured at this point remained stable during the whole monitoring, no matter under which type of ventilation. However, if only indoor points are taken into account, the lowest CO₂ concentration always appeared at the point above desk E, while the highest CO₂ concentration always appeared at the point on the back wall at 1.6 m (except for the 'no ventilation' condition where it was on the right wall at 1.6 m).

Figure 4 illustrates the distribution of CO₂ concentrations in the Experiment room under different ventilation regimes. The diameters of the bubbles represent the difference between indoor and outdoor CO₂ concentrations at each measurement point. The indoor CO₂ concentration was much higher than other ventilation regimes under 'no ventilation'.

Distribution of CO₂ concentration. As shown in Figure 3 and Table 3, in most cases, the CO₂ concentration

was higher at a higher location in the room. To further test whether differences between the CO₂ concentrations measured at two heights (1.1 m and 1.6 m) were significant, a series of paired samples t-tests was applied to analyse the differences under the steady state (the last 5 minutes) of each tested condition. As shown in Table 4, almost all differences in CO₂ concentrations measured at two heights were significant (p -values were less than 0.05), except for centre locations of the condition 'open windows and door'. Additionally, in most cases, CO₂ concentrations were higher at the higher location (t -values were negative), except at centre locations of the condition 'open windows' and the locations on the left wall of the condition 'no ventilation'.

In terms of the horizontal distribution, the CO₂ concentration was relatively uneven between measurement locations. The number of measured locations at 1.1 m was higher than that at 1.6 m. Therefore, to better compare the horizontal distribution at these two heights, the ANOVA tests were first conducted among all locations at 1.1 m and 1.6 m (see Figures 5(a) and (b)), and then they were also conducted among five commonly chosen locations at these two heights (see Figures 5(c) and (d)). According to results, differences in CO₂ concentrations between locations at the same height were statistically significant ($p < 0.05$)

Table 3. Average CO₂ concentrations measured at different locations under different ventilation regimes.

Location ^a	600 m ³ /h mixing	Open windows	No ventilation	Open windows and door
	14:05–14:10 ^b	15:05–15:10 ^b	16:05–16:10 ^b	17:05–17:10 ^b
T-1.6	559 (9)	822 (12)	1317 (19)	586 (9)
C-1.6	586 (6)	778 (11)	1350 (19)	577 (12)
C-1.1	539 (9)	795 (8)	1293 (25)	589 (13)
D _A (desk-A)	547 (7)	763 (9)	1306 (23)	530 (11)
D _B (desk-B)	551 (8)	768 (12)	1328 (27)	548 (12)
D _C (desk-C)	565 (8)	787 (12)	1336 (19)	623 (18)
D _D (desk-D)	558 (11)	815 (12)	1330 (25)	564 (12)
D _E (desk-E)	515 (7)	677 (11)	1235 (21)	497 (10)
D _F (desk-F)	554 (9)	729 (15)	1342 (17)	520 (12)
W-front-1.1	534 (9)	794 (19)	1295 (28)	538 (8)
W-front-1.6	616 (8)	867 (15)	1392 (23)	640 (8)
W-right-1.1	556 (9)	816 (10)	1403 (30)	568 (13)
W-righ-1.6	584 (8)	843 (14)	1429 (36)	639 (17)
W-back-1.1	591 (8)	872 (7)	1386 (29)	678 (10)
W-back-1.6	626 (10)	904 (16)	1425 (21)	711 (15)
W-left-1.1	600 (8)	809 (10)	1374 (20)	631 (17)
W-left-1.6	615 (11)	837 (6)	1356 (23)	643 (16)
O (outdoor)	411 (8)	403 (9)	407 (7)	409 (5)
Average	570 (32)	804 (54)	1347 (55)	593 (59)
Max	626	904	1429	711
Min	515	677	1235	497

^aT: teacher, C: centre, D: desk, W: wall, O: outdoor.

^bonly the results collected at the last 5 minutes of each period, as the steady state, were taken into account.

Table 4. Comparisons of CO₂ concentrations between two heights for different ventilation regimes.

Device location	600 m ³ /h mixing	Open windows	No ventilation	Open windows and door
	14:05–14:10	15:05–15:10	16:05–16:10	17:05–17:10
C	t (9) = -12.3 (<0.001)	t (9) = 5.2 (0.001)	t (9) = -8.8 (<0.001)	t (9) = 2.1 (0.065)
W-front	t (9) = -23.7 (<0.001)	t (9) = -20.9 (<0.001)	t (9) = -14.0 (<0.001)	t (9) = -32.3 (<0.001)
W-right	t (9) = -6.9 (<0.001)	t (9) = -5.8 (<0.001)	t (9) = -5.2 (0.001)	t (9) = -16.3 (<0.001)
W-back	t (9) = -8.3 (<0.001)	t (9) = -7.1 (<0.001)	t (9) = -6.8 (<0.001)	t (9) = -6.4 (0.004)
W-left	t (9) = -3.6 (0.006)	t (9) = -7.0 (<0.001)	t (9) = 2.8 (0.021)	t (9) = -3.3 (0.010)

All results were obtained from independent t-tests; p-values are shown in parentheses; results in bold means statistically significant difference ($p < 0.05$).

for all ventilation regimes (see Figure 5). Similar to the vertical distribution, for ‘natural ventilation’, the horizontal distribution of CO₂ was the most uneven (with higher F-values), while the most even horizontal distribution of CO₂ was in the ‘no ventilation’ condition (with lower F-values).

Impact of ventilation regimes on CO₂ concentrations. As shown in Figure 6, the result of the one-way ANOVA test indicated that there was a statistically significant difference in CO₂ concentrations among ventilation regimes ($F(3676) = 8522, p < 0.001$).

According to the post-hoc tests – Bonferroni test – under the significant result of ANOVA (see Table 5), a significant difference in CO₂ concentrations was found between almost each of two different ventilation regimes, except for between ‘600 m³/h mixing’ and ‘open windows and door’. The difference in CO₂ concentration between these two conditions was less than 50 ppm, which is the accuracy of HOBO. The average CO₂ concentration measured at 17 indoor locations during last 5 minutes of the ‘600 m³/h mixing’ regime was significantly lower than that of ‘open windows’ and ‘no ventilation’, but similar to that of ‘open windows and door’.




Figure 5. Comparison of CO₂ concentrations between locations with same heights.




Figure 6. Comparisons of CO₂ concentrations between different ventilation regimes.

Proposed CO₂ monitoring guidance in the field study. In real classrooms, it is not feasible to measure the CO₂ concentration at so many locations as it was done in the SenseLab. Therefore, the four wall locations at 1.1 m were recommended because of the following reasons:

- (1) Since CO₂ cannot be fully mixed in the room, there will always be a most unfavourable point where the CO₂ concentration is the highest among all indoor locations. The most unfavourable point should be given more attention during the measurement in the

Table 5. The difference of mean CO₂ concentrations between each of two different ventilation regimes.

	Open windows	No ventilation	Open windows and door
600 m ³ /h mixing	-234 (<0.001)	-776 (<0.001)	-22 (<0.001)
Open windows		-542 (<0.001)	211 (<0.001)
No ventilation			753 (0.001)

The results were obtained by the Bonferroni test; p-value < 0.05 are in bold.

field. If the CO₂ concentration at this point could fulfil the requirement, then the whole room can be considered safe, which is known as the worst-case design.⁵⁰ In the current study, locations on walls were considered as unfavourable points because higher CO₂ concentrations were always measured on walls, regardless of ventilation regimes (see Table 3).

- (2) Considering the real situation in school classrooms, locations on walls are less prone to equipment damage by students than locations on top of desks or at the centre of the classroom, especially for long-term measurements.

Table 6. Comparison of the average CO₂ concentrations under different ventilation regimes.

	600 m ³ /h mixing	Open windows	No ventilation	Open windows and door
Average CO ₂ level measured at	14:05–14:10	15:05–15:10	16:05–16:10	17:05–17:10
All the indoor locations	570	804	1347	593
All the locations at 1.1 m	555	784	1330	571
Four walls at 1.1 m	570	823	1365	604
All the locations at 1.6 m	598	842	1378	633
Four walls at 1.6 m	610	863	1401	658

- (3) As shown in Table 6, the average CO₂ concentration measured on four walls was similar to the average of all locations with the same height, and the average value on four walls at 1.1m was similar to the average of all indoor locations.

Therefore, if the condition allows, it is better to do the measurement on all walls at 1.1 m. If the number of devices is limited, then it is better to do the measurement at the least favourable location which, however, might be different among classrooms because of different layouts and ventilation regimes.

Field study

To validate the proposed CO₂ monitoring guidance, a series of CO₂ measurements was conducted in seven real-life classrooms with different ventilation regimes which could cover almost all ventilation regimes used in Dutch schools. Four wall locations were selected in classrooms using natural ventilation while three to four walls were selected in those using hybrid ventilation (only mechanical supplied or only mechanical exhausted) or mechanical balanced ventilation. Figure 7 presents the variation of CO₂ concentrations at different measurement locations in classrooms. The lesson blocks are separated with vertical lines, and two boxes in each figure represent the breaks. Generally speaking, variation trends of CO₂ concentrations at different locations in the same classroom were similar, and fluctuations in the natural ventilated classrooms (C1-2 and C1-3) were more obvious than those in classrooms with other ventilation regimes.

Note: the lesson periods are separated with the vertical lines and the boxes represent the breaks; the occupied hours are marked in bold

General results. According to results of the one-way ANOVA tests, there is no significant difference in CO₂ concentration between the last 10 measurements of all the lessons, which indicated the CO₂ concentration reached a steady state at last 5 minutes of all lesson periods. Therefore, it was decided to use the average CO₂ concentration of last 5 minutes of each lesson to calculate the

ventilation rate (l/s) of each classroom based on equation (1)^{9,10,12}

$$\text{Ventilation rate} = \frac{10^6 \cdot n \cdot G_p}{C_{\text{steady}} - C_{\text{out}}} \quad (1)$$

where n is the number of persons in the classroom; G_p is the average CO₂ generation rate per person, which was estimated as 0.0041 L/s (15 L/h) for pupils^{23,51}; C_{steady} is the average measured indoor CO₂ concentration (ppm) and C_{out} is the outdoor CO₂ concentration (ppm).

As shown in Table 7, average ventilation rates of all investigated classrooms were much higher than minimum values required by ISO 17772-1 (i.e., 4 L/s/p or 0.4 L/s/m²).⁷ These high ventilation rates were most likely caused by the low occupancy. During the time of the field study, the occupancy of classrooms was reduced to half (or less than half) of the normal level due to the COVID-19 (Temporary Measures) Act.⁵² If only considering the ventilation rate per person during occupied hours, the mechanical exhaust ventilation system performed the best (26.7 L/s/p and 19.6 L/s/p in C2-1 and C2-3, respectively), while the natural ventilation regime performed the worst (9.3 L/s/p and 7.9 L/s/p in C1-2 and C1-3, respectively).

Comparison of CO₂ concentrations between locations within the same classrooms. One-way ANOVA resulted in statistically significant differences of CO₂ levels among different sampling locations in almost every classroom, except for classroom C1-1 and classroom C2-1 (see Figure 8), which were only classrooms with a mechanical balanced ventilation system and CO₂ controlled mechanical exhaust ventilation system, respectively. As illustrated in Figure 8, the CO₂ concentration was always the lowest on the wall with windows location (except for classroom C2-2), while it was always the highest on the wall opposite windows. The following post-hoc multiple comparison test results indicate that the CO₂ concentration is well-mixed in the classrooms C1-1 and C2-1, as no significant difference was found between sampling locations in these classrooms. In other classrooms, statistically significant differences in CO₂ concentrations were always found between the left and




Figure 7. CO₂ concentrations measured at different points in the real classrooms. *Note:* the lesson periods are separated with the vertical lines and the boxes represent the breaks; the occupied hours are marked in bold.

right walls (see Table 8). However, almost no significant difference was found between the front and the back in almost all classrooms, except for classroom C1-4. In this classroom, the CO₂ concentration measured on the front wall was significantly higher than that on the back wall, which might be because there is a ventilation grill close to the back wall.

Besides comparisons between indoor locations, the difference in the CO₂ concentration between two outdoor locations was also examined by paired samples t-tests. The results showed statistically significant differences between two outdoor locations in both schools (school 1: $t(543) = 3.0, p = 0.003$; school 2: $t(591) = 22.4, p < 0.001$). However, differences in CO₂ concentrations between two

locations were smaller than the accuracy value of the device – 50 ppm (see Table 7), which means that these differences might be an instrumental error.

Revised CO₂ monitoring guidance based on the field study. According to the real situation in the field and the results obtained from the field study, the proposed CO₂ monitoring guidance was revised as follows:

- (1) The locations on four walls were still the better choices considering the abovementioned practical and safety reasons. However, if the number of measurement devices cannot meet the requirement




Figure 7. Continued.

of four devices in one classroom, then the most unfavourable point should be chosen first. According to the results of the field study, CO₂ concentrations on the wall opposite windows were always the highest, no matter which type of ventilation regime.

- (2) The outdoor CO₂ concentration should be included, and one location should be enough because only a small difference (less than 50 ppm) was found between the two outdoor locations in the field study.
- (3) The occupancy and the number of open windows and doors should be recorded per lesson since all this information could cause a remarkable difference in CO₂ concentrations/ventilation rates in classrooms.

Therefore, as mentioned, if the condition permits, it is better to measure the CO₂ on all four walls. If the number of devices is limited, then the most unfavourable location should be considered first. Outside CO₂ concentration should be measured at one location. Besides, information of

indoor occupancy and opening windows and doors should be recorded corresponding to the classroom schedule.

Discussion

Impact of ventilation regimes on CO₂ concentrations

In this study, CO₂ concentrations were measured at 18 indoor points and one outdoor point in a semi-laboratory classroom where different ventilation regimes could be applied. To identify the impact of the ventilation regimes on CO₂ concentrations, four different ventilation regimes were monitored in the same room with same participants. Based on the results collected during the last 5 minutes of each regime, there were statistically significant differences between each of two different ventilation regimes, except for between ‘600 m³/h mixing’ and ‘open windows and door’. For these two regimes, significantly lower CO₂ concentrations were observed, not only at the average levels but also at




Figure 7. Continued.

almost all sampling locations in the monitored room, than for the other ventilation regimes. This demonstrated that natural ventilation, under certain conditions, can provide the same ventilation as mechanical ventilation. However, this is not always the case. Many factors (such as the size of windows and doors, the airflow of the mechanical ventilation, the layout of the room, etc.) can affect this result. For example, as shown in the experiment, when only windows were open, CO₂ concentrations measured in the Experience room of the SenseLab were much higher than the results measured during mechanical ventilation. Also, in the field study, CO₂ concentrations measured in natural ventilated classrooms were much higher than in mechanically ventilated classrooms, consistent with the conclusion of a field study conducted by Toftum et al.²⁶ For the ‘no ventilation’ regime, the measured CO₂ concentration was the highest of all regimes tested, it kept increasing and did not reach a steady state at the end of the monitoring period. For schools without mechanical balanced ventilation, we recommend all their windows and doors should be kept wide open.

Apart from average concentrations, the temporal change of CO₂ concentrations was also illustrated ((see Figures 3 and 7), respectively for the lab and field studies) and compared between different ventilation regimes in both the lab and field studies. The results showed that the variation of CO₂ concentration in the naturally ventilated classrooms (either ‘open windows and door’ or ‘open windows’) was more obvious than the variation in the mechanically ventilated classrooms, which is consistent with results reported by Wohlgenuth and Christensen.²⁷ This demonstrated two characteristics of CO₂ concentration: (1) its sensitive response to changes of ventilation regimes and (2) its consistent trend at different measurement points in the same room. These characteristics have confirmed CO₂ concentration as a qualified indicator for assessing ventilation performance in classrooms.

The distribution of CO₂ under different ventilation regimes

For the vertical distribution of CO₂, significant differences in the CO₂ concentrations were found between two different heights (1.1 m and 1.6 m) at most locations under all ventilation regimes, except for the centre locations under ‘open windows and door’. In most cases, the CO₂ concentration was significantly higher at 1.6 m, especially under the mechanical ventilation regime ‘600 m³/h mixing’. This was not in agreement with the conclusion drawn by Mahyuddin et al.,⁵³ who claimed that in the mechanically ventilated classroom (with 3–4 air changes per hour), the effect of the height on CO₂ concentration was not significant. The different findings might be related to the fact that in the study conducted by Mahyuddin et al.,⁵³ there was an

extra fan operating in the classroom which increased the mixing of air and contributed to the uniformity of CO₂ distribution. The air velocity measured in their study was two to three times of that measured in the current study.

Additionally, significant differences were also found among different locations with same heights, namely, the uneven distribution of CO₂ was also identified in the horizontal direction, no matter under which ventilation regime. Based on the analysis results, the most uneven horizontal distribution of CO₂ was found for natural ventilation (either ‘open windows’ or ‘open both windows and door’), while the relatively less uneven distribution was found for ‘no ventilation’. The same is seen for the vertical distribution of CO₂. In general, CO₂ concentrations were higher at locations that were relatively far from windows (see Figure 4). Similar results were also found in the field study.

The most unfavourable location in real classrooms

According to the CO₂ concentration measured in the field study, the wall opposite to the windows was found to be the most unfavourable location with always the highest CO₂ concentration in the classroom studied, no matter under which ventilation regime. This result differed from the result obtained in the lab study. In the Experience room, the maximum CO₂ concentration always appeared on the back wall instead of the right wall (the wall opposite the windows), which might be caused by the different size and layout of the Experience room as compared to a real classroom. Specifically, the distance between windows and the opposite wall is much further away in a real classroom, which might reduce the chance for the fresh air coming from windows to reach the opposite wall. The wall opposite to windows becomes then the most unfavourable location in the classroom. However, the choice is not always fixed, which can be changed based on the layout of each individual classroom.

Guidance for CO₂ monitoring in the field

Although trends in the variation of CO₂ concentration over time were similar at all indoor measurement points (see Figure 2), differences in CO₂ concentrations between different points cannot be ignored, especially under natural ventilation regimes. Differences between two measurement points, in some cases, exceeded 300 ppm (or 40%) in the natural ventilated classrooms. These findings confirmed the conclusion drawn by Seppänen et al.⁴⁷ and Mahyuddin et al.⁵³ that CO₂ was spatially nonuniform distributed, which indicates the importance of choosing the ‘right’ number of measurement points and the ‘right’ measurement locations.

To avoid interfering with students’ classroom activities, this study recommends measurement locations on walls for

Table 7. Information about the CO₂ monitoring in seven classrooms of two Dutch secondary schools.

School	Classroom	Lesson NO.	Student	Number of ^a			Outdoor CO ₂ (ppm)			Indoor CO ₂ (ppm) ^b			Ventilation rate ^c		
				Open window	Open door	Front entrance	Courtyard	Front	Left	Right	Back	Average	(l/s/ p)	(l/s/ m ²)	
1	C1-1	1	13	3	1	407	424	624	/	587	590	600	308.2	23.7	5.6
		2	15	3	1	422	426	609	/	551	534	565	451.6	30.1	8.2
		3	14	1	1	429	432	848	/	841	924	871	132.8	9.5	2.4
		4	11	1	1	428	426	643	/	665	635	647	207.4	18.9	3.8
		5	9	1	1	433	429	683	/	704	725	704	136.2	15.1	2.5
		6	5	0	1	452	405	880	/	956	867	901	42.0	8.4	0.8
	Average	11	2	428	424	714	/	717	712	715	159.9	17.6	3.9		
C1-2	1	15	2	1	407	424	761	832	676	708	744	195.4	13.0	3.7	
	2	15	1	1	422	426	955	1061	836	833	921	126.2	8.4	2.4	
	3	14	1	1	429	432	817	903	770	779	817	151.4	10.8	2.9	
	4	15	0	1	428	426	1036	1182	1048	1099	1091	94.0	6.3	1.8	
	5	11	0	1	433	429	947	1058	1016	1017	1009	78.9	7.2	1.5	
	6	14	1	1	452	405	864	961	591	876	823	139.5	10.0	2.6	
	Average	14	1	428	424	897	999	823	885	901	122.2	9.3	2.5		
C1-3	1	13	0	1	407	424	937	751	1072	983	936	105.9	8.1	2.0	
	2	13	0	1	422	426	1063	759	1150	1125	1024	90.6	7.0	1.7	
	3	14	2	1	429	432	1024	736	992	975	932	116.6	8.3	2.2	
	4	/	2	1	428	426	686	515	671	673	636	/	/	/	
	5	14	2	1	433	429	989	726	1047	1011	943	113.4	8.1	2.1	
	6	/	2	0	452	405	623	467	574	541	551	/	/	/	
	Average	14	1	428	424	887	659	918	885	837	136.1	7.9	2.0		
C1-4	1	/	0	0	407	424	627	552	/	567	582	/	/	/	
	2	11	0	1	422	426	971	850	/	952	924	92.0	8.4	2.1	
	3	/	0	0	429	432	688	591	/	622	634	/	/	/	
	4	3	0	0	428	426	800	669	/	700	723	42.1	14.0	1.0	
	5	2	0	0	433	429	649	549	/	585	594	50.4	25.2	1.1	
	6	2	0	0	452	405	670	574	/	604	616	39.5	19.7	0.9	
	Average	5	0	428	424	734	631	/	672	679	73.5	16.8	1.3		

(continued)

Table 7. (continued)

School	Classroom	Lesson NO.	Student	Number of ^a			Outdoor CO ₂ (ppm)			Indoor CO ₂ (ppm) ^b			Ventilation rate ^c		
				Open window	Open door	Front entrance	Courtyard	Front	Left	Right	Back	Average	(l/s/ p)	(l/s/ m ²)	
2	C2-1	1	/	/	439	416	475	474	487	479	479	/	/	/	/
		2	/	/	452	437	466	469	479	466	470	/	/	/	/
		3	8	1	437	438	931	867	966	939	926	68.3	8.5	1.4	1.4
		4	2	2	445	434	580	553	576	569	570	61.5	30.7	1.3	1.3
		5	/	/	460	440	481	481	490	470	481	/	/	/	/
		6	/	/	445	454	452	449	452	438	448	/	/	/	/
C2-2	Average	5	2	446	436	564	549	575	560	562	64.9	19.6	1.4	1.4	
	1	7	3	439	416	619	641	680	638	644	127.8	18.3	2.5	2.5	
	2	7	3	452	437	697	732	892	782	775	86.3	12.3	1.7	1.7	
	3	/	/	437	438	452	486	458	475	468	/	/	/	/	
	4	/	/	445	434	400	442	425	440	427	/	/	/	/	
	5	/	/	460	440	416	452	485	459	453	/	/	/	/	
C2-3	Average	7	3	445	454	411	435	426	445	429	/	/	/	/	
	1	14	3	445	427	658	686	786	710	710	107.0	15.3	2.1	2.1	
	2	4	3	439	416	785	661	854	675	744	178.1	12.7	1.8	1.8	
	3	13	3	452	437	499	519	499	516	508	236.1	59.0	2.4	2.4	
	4	13	3	437	438	599	557	595	579	582	374.3	28.8	3.7	3.7	
	5	11	3	445	434	554	600	547	626	582	366.2	28.2	3.7	3.7	
6	Average	11	3	460	440	990	787	1034	833	911	97.2	8.8	1.0	1.0	
	1	12	3	445	454	682	617	707	550	639	270.5	22.5	2.7	2.7	
	2	11	3	446	436	685	623	706	630	661	207.2	26.7	2.5	2.5	

^aThe numbers of students, open windows and open doors were observed and recorded once per lesson.

^bThe results were the average CO₂ concentrations monitored during the last 5 minutes of each lesson.

^cVentilation rates were calculated based on CO₂ concentrations and the number of students.




Figure 8. Comparison of CO₂ concentrations between different locations in the same classrooms.

Table 8. The mean difference of CO₂ concentrations between two different locations.

School 1	C1-1	Door/Right		Back	
		Front	-2.8 (1.000)	2.0 (1.000)	
	C1-2	Door/Right		4.7 (1.000)	
		Door/Left		Back	
		Front	-102.85 (<0.001)	73.7 (0.017)	11.3 (1.000)
	C1-3	Door/Left		176.5 (<0.001)	114.2 (<0.001)
		Window/Right			-62.4 (.068)
		Window/Left		Back	
	C1-4	Door/Right		Window/Left	Back
		Front	-30.6 (1.000)	228.1 (<0.001)	2.4 (1.000)
		Door/Right		258.7 (<0.001)	33.0 (1.000)
	C1-4	Window/Left			-225.8 (<0.001)
Front			Window/Left	Back	
Window/Left			103.6 (<0.001)	62.6 (0.015)	
School 2	C2-1	Door/Right		Back	
		Front	-16.0 (1.000)	45.4 (1.000)	
		Door/Right		61.4 (1.000)	17.7 (1.000)
	C2-2	Window/Left			-43.7 (1.000)
		Door/Right		Window/Left	Back
		Front	-128.3 (<0.001)	-28.7 (1.000)	-52.0 (.170)
	C2-3	Door/Right		99.6 (<0.001)	76.3 (0.009)
		Window/Left			-23.3 (1.000)
		Front	-21.3 (1.000)	61.6 (0.120)	55.0 (0.224)
	C2-3	Door/Right		82.8 (0.011)	76.3 (0.024)
		Window/Left			-6.6 (1.000)
		Window/Left			

The results were obtained by the Bonferroni test; p-value < 0.05 are in bold.

monitoring in real classrooms. Additionally, to increase the credibility of results, more than one measurement point is recommended in the field study, especially under natural ventilation or no ventilation regimes. For classrooms with natural ventilation, at least two points are recommended: (1) the point on the wall opposite to windows because CO₂ concentrations measured at this point were the highest in the classroom and (2) the point on the front wall of the classroom because the results measured at this point were relatively close to the average level. For classrooms with hybrid

ventilation systems (only mechanical supply or only exhaust), the same points are recommended. For classrooms with mechanical balanced ventilation systems, one measurement point seems enough because CO₂ is relatively well-mixed under this ventilation regime. This is consistent with the conclusion made by Racks et al.²² that CO₂ concentrations were homogenous in mechanically ventilated areas because the standard deviation of CO₂ concentrations between different locations could be covered by sensor error. ‘No ventilation’, given the fact that this ventilation regime is hardly seen in real

classrooms according to observations in the field study, is not further discussed in this study.

Furthermore, concerning other aspects of CO₂ measurements referred to in previous studies,^{14,47} future studies are recommended to (1) use continuous instead of instantaneous measurements, with as long as possible measurement intervals, especially in naturally ventilated classrooms; (2) measure the outdoor CO₂ concentration and (3) record occupants' information (e.g., numbers and age group, etc.) and behaviour (e.g., opening windows and door) during the measurement period.

Conclusions

A full-scale experiment was conducted in the Experience room of SenseLab to investigate the distribution of CO₂ concentration under different ventilation regimes. Based on the experimental results, four measurement points on the four walls with a height of 1.1 m (the height of the head of a sitting person) were recommended to be selected in future studies on CO₂ concentrations to obtain results that are closer to the average level and to understand the worst situation.

To test the feasibility of that recommendation, a field study was thereafter carried out in seven classrooms of two Dutch secondary schools. Both the lab and the field study confirmed the uneven distribution of CO₂ in classrooms, especially under natural ventilation. Therefore, it is recommended to select multiple points in future studies.

For classrooms with natural or hybrid ventilation, at least two measurement points (one on the wall opposite to windows, as the most unfavourable point, and the other one on the front wall, as the average point) are recommended. For classrooms with mechanically balanced ventilation, one measurement point on the wall opposite to the windows is acceptable since CO₂ is relatively evenly distributed under this ventilation regime.

Next to the selection of indoor measurement points, this study suggests future investigations to also measure the outdoor CO₂ concentration and record the number and behaviour of occupants during the measurement.

Acknowledgements

This study is a part of the ZonMw funded project "SARS-CoV-2 transmission in secondary schools and the influence of indoor environmental conditions" (no. 50-56300-98-689) coordinated by University Medical Centre Utrecht in the Netherlands. Participants are Erasmus Medical Centre in Rotterdam, the Netherlands; University of Utrecht, the Netherlands and Delft University of Technology.

Authors' contribution

Dadi Zhang contributes in conceptualization, methodology, investigation, data analysis, writing-original draft preparation, writing-review and editing. Er Ding contributes in investigation, writing-review and editing. Philomena Bluysen contributes in

conceptualization, methodology, supervision, writing-original draft preparation, writing-review and editing.

Declaration of conflicting interests

The author(s) declared no potential conflicts of interest with respect to the research, authorship, and/or publication of this article.

Funding

The author(s) disclosed receipt of the following financial support for the research, authorship, and/or publication of this article: This research was supported by ZonMw (50-56300-98-689).

ORCID iDs

Dadi Zhang  <https://orcid.org/0000-0002-1293-0542>

Er Ding  <https://orcid.org/0000-0002-4688-0950>

Philomena M. Bluysen  <https://orcid.org/0000-0002-5732-5362>

References

1. Bluysen PM. *The Healthy Indoor Environment: How to Assess Occupants' Wellbeing in Buildings*. London, UK: Routledge; 2013.
2. Olsson D. *History of Ventilation: Carbon Dioxide as an Indicator of Indoor Air Pollution in 1858!*, HQ Kvänum, Sweden: Swegon Air Academy. <https://www.swegonairacademy.com/2015/12/30/history-of-ventilation-carbon-dioxide-as-an-indicator-of-indoor-air-pollution-in-1858/> (2015, accessed 30 May 2021).
3. Locher WG Max von Pettenkofer (1818–1901) as a pioneer of modern hygiene and preventive medicine. *Environ Health Prev Med* 2007; 12: 238–245.
4. Nielsen O. Quality of air and the amount of fresh air in classrooms. *Indoor Air Build Ventil Therm Clim* 1984; 5: 221–226.
5. Potting J, Van de Sandt P, ter Haar Romeny-Wachter C, Brunekreef B, Boleij J and Hazebroek-Kampschreur A. Health complaints, CO₂ levels and indoor climate in Dutch schools. In: Int Symp School and University Health and Medicine. Prague, Czechoslovakia, 7 July 1987, pp. 148.
6. Myhrvold A, Olsen E and Lauridsen O. Indoor environment in schools—pupils health and performance in regard to CO₂ concentrations. *Indoor Air* 1996; 96: 369–371.
7. International Organization for Standardization. *ISO 17772-1: 2017. Energy Performance of Buildings — Indoor Environmental Quality — Part 1: Indoor Environmental Input Parameters for the Design and Assessment of Energy Performance of Buildings*. Geneva, Switzerland: The International Organization for Standardization, 2017.
8. Scheff PA, Paulius VK, Huang SW and Conroy LM. Indoor air quality in a middle school, part i: use of CO₂ as a tracer for effective ventilation. *Appl Occup Environ Hygiene* 2000; 15: 824–834.
9. Batterman S. Review and extension of CO₂-based methods to determine ventilation rates with application to school classrooms. *Int J Environ Res Public Health* 2017; 14: 145.

10. ASTM International. *ASTM D6245-07. Standard Guide for Using Indoor Carbon Dioxide Concentrations to Evaluate Indoor Air Quality and Ventilation*. West Conshohocken, PA: ASTM International, 2007.
11. Haverinen-Shaughnessy U, Moschandreas D and Shaughnessy R. Association between substandard classroom ventilation rates and students' academic achievement. *Indoor Air* 2011; 21: 121–131.
12. Shaughnessy RJ, Haverinen-Shaughnessy U, Nevalainen A and Moschandreas D. A preliminary study on the association between ventilation rates in classrooms and student performance. *Indoor Air* 2006; 16: 465–468.
13. Toftum J, Kjeldsen BU, Wargocki P, Menå HR, Hansen EMN and Clausen G. Association between classroom ventilation mode and learning outcome in Danish schools. *Building Environ* 2015; 92: 494–503.
14. Mahyuddin N and Awbi H. A review of CO₂ measurement procedures in ventilation research. *Int J Ventil* 2012; 10: 353–370.
15. ISO. *ISO_16000-26. Indoor Air—Part 26: Sampling Strategy for Carbon Dioxide (CO₂)*. Geneva, Switzerland: ISO, 2012.
16. ASHRAE. *ASHRAE Standard 62.1–2016. Ventilation for Acceptable Indoor Air Quality*. Atlanta, GA: ASHRAE, 2016.
17. Taylor S. LEED® and Standard 62.1. *ASHRAE J* 2005; 47: S4.
18. *Programma van Eisen Frisse Scholen*. Zwolle, the Netherlands: Rijksdienst voor Ondernemend Nederland (RVO), 2021, <https://www.arbocatalogus-vo.nl/media/1149/programma-van-eisen-frisse-scholen-2021.pdf>.
19. Mahyuddin N and Awbi H. The spatial distribution of carbon dioxide in an environmental test chamber. *Building Environ* 2010; 45: 1993–2001.
20. Fox A, Harley W, Feigley C, Salzberg D, Sebastian A and Larsson L. Increased levels of bacterial markers and CO₂ in occupied school rooms. *J Environ Monitoring* 2003; 5: 246–252.
21. Persily AK, Dols WS and Nabinger SJ. Air change effectiveness measurements in two modern office buildings. *Indoor Air* 1994; 4: 40–55.
22. Rackes A, Ben-David T and Waring MS. and Environment TftB. Sensor networks for routine indoor air quality monitoring in buildings: impacts of placement, accuracy, and number of sensors. *Sci Technol Built Environ* 2018; 24: 188–197.
23. Schibuola L, Scarpa M and Tambani C. Natural ventilation level assessment in a school building by CO₂ concentration measures. *Energy Proced* 2016; 101: e64.
24. Hou Y, Liu J and Li J. Investigation of indoor air quality in primary school classrooms. *Proced Eng* 2015; 121: 830–837.
25. Guo H, Morawska L, He C and Gilbert D. Impact of ventilation scenario on air exchange rates and on indoor particle number concentrations in an air-conditioned classroom. *Atmos Environ* 2008; 42: 757–768.
26. Bakó-Biró Z, Clements-Croome DJ, Kochhar N, Awbi HB and Williams MJ. Ventilation rates in schools and pupils' performance. *Building Environ* 2012; 48: 215–223.
27. Cao S-J, Ding J and Ren C. Sensor deployment strategy using cluster analysis of Fuzzy C-Means algorithm: towards online control of indoor environment's safety and health. *Sustain Cities Soc* 2020; 59: 102190.
28. Mui KW, Wong LT and Ho WL. Evaluation on sampling point densities for assessing indoor air quality. *Building Environ* 2006; 41: 1515–1521.
29. Cheong KWD, Djunaedy E, Chua YL, Tham KW, Sekhar SC, Wong NH and Ullah MB. Thermal comfort study of an air-conditioned lecture theatre in the tropics. *Building Environ* 2003; 38: 63–73.
30. Clements-Croome DJ, Awbi HB, Bakó-Biró Z, Kochhar N and Williams M. Ventilation rates in schools. *Building Environ* 2008; 43: 362–367.
31. Godwin C and Batterman S. Indoor air quality in Michigan schools. *Indoor Air* 2007; 17(2): 109–121.
32. Franco A and Leccese F. Measurement of CO₂ concentration for occupancy estimation in educational buildings with energy efficiency purposes. *J Building Eng* 2020; 32: 101714.
33. Wargocki P and Wyon D. The effects of moderately raised classroom temperatures and classroom ventilation rate on the performance of schoolwork by children (RP-1257). *HVAC&R Res* 2007; 13: 193–220.
34. Wargocki P. Improving indoor air quality improves the performance of office work and school work and provides economic benefits. In: proceedings of ASHRAE-IAQ 2007 : Healthy and Sustainable Buildings, Baltimore, MD, 15 October 2007: pp. 15–17.
35. Ren J and Cao S-J. Incorporating online monitoring data into fast prediction models towards the development of artificial intelligent ventilation systems. *Sustain Cities Soc* 2019; 47: 101498.
36. Chatzidiakou L, Mumovic D and Summerfield AJ. What do we know about indoor air quality in school classrooms? A critical review of the literature. *Intell Build Int* 2012; 4: 228–259. DOI: [10.1080/17508975.2012.725530](https://doi.org/10.1080/17508975.2012.725530).
37. Fromme H, Twardella D, Dietrich S, Heitmann D, Schierl R, Liebl B and Rüden H. Particulate matter in the indoor air of classrooms-exploratory results from Munich and surrounding area. *Atmos Environ* 2007; 41: 854–866.
38. Turanjanin V, Vučićević B, Jovanović M, Mirkov N and Lazović I. Indoor CO₂ measurements in Serbian schools and ventilation rate calculation. *Energy* 2014; 77: 290–296.
39. Mumovic D, Palmer J, Davies M, Orme M, Ridley I, Oreszczyń T, Judd C, Critchlow R, Medina HA, Pilmoor G, Pearson C and Way P. Winter indoor air quality, thermal comfort and acoustic performance of newly built secondary schools in England. *Building Environ* 2009; 44: 1466–1477.
40. Krawczyk DA, Rodero A, Gładyszewska-Fiedoruk K and Gajewski A. CO₂ concentration in naturally ventilated classrooms located in different climates-Measurements and simulations. *Energy Build* 2016; 129: 491–498.
41. Mi Y-H, Norbäck D, Tao J, Mi Y-L and Ferm M. Current asthma and respiratory symptoms among pupils in Shanghai, China: influence of building ventilation, nitrogen dioxide,

- ozone, and formaldehyde in classrooms. *Indoor Air* 2006; 16: 454–464.
42. Luther MB, Horan P and Tokede O. Investigating CO₂ concentration and occupancy in school classrooms at different stages in their life cycle. *Arch Sci Rev* 2018; 61: 83–95.
 43. Kim JL, Elfman L, Mi Y, Johansson M, Smedje G and Norbäck D. Current asthma and respiratory symptoms among pupils in relation to dietary factors and allergens in the school environment. *Indoor Air* 2005; 15: 170–182.
 44. Chatzidiakou L, Mumovic D and Summerfield A. Is CO₂ a good proxy for indoor air quality in classrooms? Part 1: the interrelationships between thermal conditions, CO₂ levels, ventilation rates and selected indoor pollutants. *Building Serv Eng Res Technol* 2015; 36: 129–161.
 45. You Y, Bai Z, Jia C, Hu X, Ran W, Zhang J and Yang J. Ventilation conditions and the related symptoms in selected indoor environments in a University. In: The 6th International Conference on Indoor Air Quality, Ventilation & Energy Conservation in Buildings IAQVEC 2007, Citeseer Sendai, Japan, 28–31 October 2007.
 46. Griffiths M and Eftekhari M. Control of CO₂ in a naturally ventilated classroom. *Energ Build* 2008; 40: 556–560.
 47. Seppänen OA, Fisk WJ and Mendell MJ. Association of ventilation rates and CO₂ concentrations with health and other responses in commercial and institutional buildings. *Indoor Air* 1999; 9: 226–252.
 48. Bluysen PM, van Zeist F, Kurvers S, Tenpierik M, Pont S, Wolters B, van Hulst L and Meertins D. The creation of sense lab: a laboratory for testing and experiencing single and combinations of indoor environmental conditions. *Intell Buildings Int* 2018; 10: 5–18.
 49. Sincich T. *Business Statistics by Example*. San Francisco, CA: Goodreads, 1996.
 50. Rustem B and Howe M. *Algorithms for Worst-Case Design and Applications to Risk Management*. Princeton, NJ: Princeton University Press, 2009.
 51. Coley DA and Beisteiner A. Carbon dioxide levels and ventilation rates in schools. *Int Journal Ventilation* 2002; 1: 45–52.
 52. Government of the Netherlands. *Dutch Measures against COVID-19. The Netherlands: Government of the Netherlands, 2021*, <https://www.government.nl/topics/coronavirus-covid-19/tackling-new-coronavirus-in-the-netherlands> (accessed 30 May 2021).
 53. Mahyuddin N, Awbi HB and Alshitawi M. The spatial distribution of carbon dioxide in rooms with particular application to classrooms. *Indoor Built Environ* 2014; 23: 433–448.