


HOTSPRING FOR PARKSTAD

Synergy between a datacenter and hotspring in the Sibelco quarry



LOCATION IBA PARKSTAD

RESEARCH

DESIGN


LANDSCAPE

BUILD

CONCLUSION

LOCATION IBA PARKSTAD







NATURE



TOURISM



INDUSTRIAL HISTORY




“Onder de noemer Open Oproep zocht IBA Parkstad de afgelopen maanden naar buitengewone ideeën om de Limburgse regio nog meer op de kaart te zetten”


RESEARCH



1. RESEARCH TYPOLOGY



2. RESEARCH RESIDUAL HEAT




3. MAPPING DATA CENTERS



DATACENTERS 2017
commercial data centers +/- 260
total floor area +/- 770.000 m2
average electricity use +/- 3,46 MWh/m2/y
total energy use +/- 2,7 TWh/y
-> +/- 1 million households

 = 1 million houses



1. ANONYMOUS BOX



2. SOURCE OF RESIDUAL HEAT

RESEARCH QUESTION



What are the challenges and opportunities for achieving energetic synergy by implementing a data center in **IBA-Parkstad** and **what requirements does this set for the architectural design?**

2. RESIDUAL HEAT USERS



Datacenter	Heat supply	Cold demand
Demand [kWh/year/m2]		21900
T _{evaporator} [°C]	35 °C	
T _{condensor} [°C]	45 °C	



Office buildings	Heat demand	Cold demand
Demand [kWh/year/m2]	44 - 127	6,1
Demand hours per year [h]	2618	441
Equivalent peak hours [h]	321	126
Peak demand [W/m2]	137	49
T _{condensor} [°C]	45°C	
Required temperature	18 °C - 23 °C	



Congress buildings	Heat demand	Cold demand
Demand [kWh/year/m2]	141	4,6
Demand hours per year [h]	4210	445
Equivalent peak hours [h]	833	86
Peak demand [W/m2]	169	53
T _{condensor} [°C]	45°C	
Required temperature	x	




Housing	Heat demand	Cold demand
Demand [kWh/year/m2]	48,5	
Demand hours per year [h]	x	
Equivalent peak hours [h]	1200	
Peak demand [W/m2]	40,4	
T _{condensor} [°C]	45°C	
Required temperature	18 °C - 23 °C	



Healthcare buildings	Heat demand	Cold demand
Demand [kWh/year/m2]	84	4,9
Demand hours per year [h]	3792	334
Equivalent peak hours [h]	778	128
Peak demand [W/m2]	108	38
T _{condensor} [°C]	45°C	
Required temperature	x	




Swimming pools	Heat demand	Cold demand
Demand [kWh/year/m2]	459 - 1500	
Demand hours per year [h]	8760	
Equivalent peak hours [h]	3648	
Peak demand [W/m2]	126	
T _{condensor} [°C]	x	
Required temperature	28°C - 32°C	



Sports buildings	Heat demand	Cold demand
Demand [kWh/year/m2]	55	22,6
Demand hours per year [h]	3783	613
Equivalent peak hours [h]	709	205
Peak demand [W/m2]	78	111
T _{condensor} [°C]	45°C	
Required temperature	15°C - 25°C	



Schools	Heat demand	Cold demand
Demand [kWh/year/m2]	102	3,45
Demand hours per year [h]	1143	232
Equivalent peak hours [h]	432	276
Peak demand [W/m2]	237	45
T _{condensor} [°C]	45°C	
Required temperature	x	



Fish farms	Heat demand	Cold demand
Demand [kWh/year/m2]	3305	
Demand hours per year [h]	8760	
Equivalent peak hours	x	
Peak demand [W/m2]	x	
T _{condensor} [°C]	x	
Required temperature	30°C	




Greenhouses	Heat demand	Cold demand
Demand [kWh/year/m2]	518	495
Demand hours per year [h]	x	x
Equivalent peak hours [h]	2590	848
Peak demand [W/m2]	200	584
T _{condensor} [°C]	45 °C	
Required temperature	x	



Algae farms	Heat demand	Cold demand
Demand [kWh/year/m2]	x	
Demand hours per year [h]	8760	
Equivalent peak hours [h]	x	
Peak demand [W/m2]	x	
T _{condensor} [°C]	x	
Required temperature	25°C - 28 °C	



OVERALL DESIGN QUESTION



How can a datacenter manifest its societal importance in the public realm and **what** opportunities does this offer for architectural, urban and energetic synergies in IBA-Parkstad?














2030




DATA CENTER EXISTING SITUATION




DATA CENTER EXISTING SITUATION




DATA CENTER WITH HOTSPRING




DATA CENTER WITH HOTSPRING




DATA CENTER WITH HOTSPRING



DATA CENTER WITH HOTSPRING



DATA CENTER WITH HOTSPRING




DATA CENTER WITH HOTSPRING



COOLING TOWERS



COOLING TOWERS



HOT SPRING

DESIGN






DESIGN LOCATION








MODELLING STUDY OF LANDSCAPE




1. FORMING THE TOWER




thermal core for updraft heat

1. FORMING THE TOWER




thermal core for updraft heat




shaping the core to a hexagon for maximum surface thermal core...


1. FORMING THE TOWER



thermal core for updraft heat




shaping the core to a hexagon for maximum surface thermal core...




create a cold ring around the thermal core to cool the servers...


1. FORMING THE TOWER




thermal core for updraft heat



shaping the core to a hexagon for maximum surface thermal core...








create a cold ring around the thermal core to cool the servers...



use loadbearing shell to create open floorplan and regulate climate inside...

2. RATIO DATA CENTER - HOTSPRING







LANDSCAPE




SITUATION 2017




SIBELCO QUARRY 2030




SIBELCO QUARRY 2030




SIBELCO QUARRY 2030




SIBELCO QUARRY 2030



SIBELCO QUARRY 2030





COMPOSITION IN LANDSCAPE




**PARKING
VISITORS**

ROUTING






ROUTING




WATER



groundwater
15°C


WATER



groundwater
15°C

cooling of tower =
heating of groundwater!

WATER




groundwater
15 °C

cooling of tower =
heating of groundwater!

clear groundwater 35 °C

helophyte field

WATER




- ENTRANCE HOTSPRING
- SHOWERS

PROGRAM




- RESTAURANT
- CHANGING ROOMS
- STAFF

PROGRAM



PROGRAM




- ENTRANCE DATA TOWER
- TECHNICAL SPACE
- SERVER SPACE
- OFFICE AND VIEWPOINT

PROGRAM







MASTERPLAN 1:1000




FLOORPLAN 1:500











level 5 - server space / 1:100




level 12 - technical space / 1:100


FLOORPLANS 1:100




12th FLOOR




12th FLOOR



12th FLOOR



12th FLOOR



12th FLOOR

BUILD



LOCAL PINE WOOD BRUNSUMMERHEIDE


RESEARCH |

LOCATION |

DESIGN |


BUILD |

REFLECTION




BUILDING ORDER


- 1 prefabricating parts with hardwood
beech dowels
- 2 modular parts to building site
- 3 assemble first floor
- 4 place the floors in the wood shell



BRETTSTAPEL METHODE



50 % less wood in straight parts






LOADBEARING CONSTRUCTION BEAM GRID

- 1 540/115 mm glulam beam
- 2 laminated pine wood




H1 - HORIZONTAL SECTION SCALE 1:5


ISOMETRIC WALL CONSTRUCTION




WOODEN SHELL FORMS BALCONY





**CUTOUT IN WOODEN SHELL GIVES
TRANSPORTATION EXIT FOR EQUIPMENT**




**WOODEN SHELL STANDS ON CONCRETE
BASE ON THE WATER**








SECTION 1:20



INVISIBLE DOOR

DETAIL TRANSPORTATION DOOR 1:5



MINIMAL EDGE

DETAIL BALCONY 1:5





CONCLUSION

