

Document Version

Final published version

Licence

Dutch Copyright Act (Article 25fa)

Citation (APA)

Jarosz, A., Baranowski, J., & Zagorowska, M. (2025). The Future of Offshore Wind Energy - Analyzing HVDC and HVAC Solutions. In *Proceedings of the 7th Novel Intelligent and Leading Emerging Sciences Conference, NILES 2025* (pp. 41-44). IEEE. <https://doi.org/10.1109/NILES68063.2025.11232056>

Important note

To cite this publication, please use the final published version (if applicable).
Please check the document version above.

Copyright

In case the licence states "Dutch Copyright Act (Article 25fa)", this publication was made available Green Open Access via the TU Delft Institutional Repository pursuant to Dutch Copyright Act (Article 25fa, the Taverne amendment). This provision does not affect copyright ownership.
Unless copyright is transferred by contract or statute, it remains with the copyright holder.

Sharing and reuse

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights.
We will remove access to the work immediately and investigate your claim.

The Future of Offshore Wind Energy – Analyzing HVDC and HVAC Solutions

Anna Jarosz
Dept. of Process Control
AGH University of Krakow
Krakow, Poland
anjarosz@agh.edu.pl

Jerzy Baranowski
Dept. of Automatic Control & Robotics
AGH University of Krakow
Krakow, Poland
jb@agh.edu.pl

Marta Zagorowska
DCSC
TU Delft
Delft, Netherlands
m.a.zagorowska@tudelft.nl

Abstract—The expansion of offshore wind energy necessitates efficient power transmission systems, with High Voltage Direct Current (HVDC) and High Voltage Alternating Current (HVAC) being the primary technologies. While HVAC has been traditional for shorter distances, HVDC is increasingly favored for longer transmissions due to its improved efficiency and reduced losses. This article provides a comparative analysis of both technologies, focusing on their technical, economic, and environmental implications. The goal is to guide stakeholders in selecting the most suitable solution for offshore wind energy projects.

Index Terms—HVAC, HVDC, Offshore Wind Energy

I. INTRODUCTION

The growth of offshore wind energy has accelerated over the past decade, fueled by technological advancements, increased investments, and supportive government policies. Recognized as a key player in the renewable energy transition, offshore wind capacity has expanded, particularly in countries like the United Kingdom, Germany, and China [18]. Offshore wind farms benefit from stronger and more consistent wind speeds, making them a substantial and reliable source of clean energy. However, the distance between offshore wind farms and onshore grids can lead to energy losses, necessitating efficient transport systems [15]. In this work, we compare High Voltage Direct Current (HVDC) and High Voltage Alternating Current (HVAC) cables as transmission solutions for offshore wind energy [3].

This paper is structured as follows. Section II compares the two types of cables and the differences are discussed in Section III. Recommendations and conclusions close the paper in Section IV.

II. DIRECT CURRENT AND ALTERNATING CURRENT SOLUTIONS FOR OFFSHORE APPLICATIONS

A. Integration with offshore wind turbines

As shown in Figure 1, the cables are needed to connect the wind turbine system and loads. Key challenges include high

Work of Anna Jarosz and Jerzy Baranowski was partially supported by the project titled “Process Fault Prediction and Detection”, financed by The National Science Centre (decision no. UMO-2021/41/B/ST7/03851) and partially supported by program “Excellence initiative – research university” for the AGH University of Kraków under the project “DUDU - Diagnostyka Uszkodzeń i Degradacji Urządzeń”. M. Zagorowska kindly acknowledges the funding from Delft Technology Fellowship.

infrastructure costs, harsh marine conditions affecting cable integrity, the need for effective energy storage, and integration with existing electrical grids. This figure illustrates how the HVDC and HVAC systems are integrated within the offshore wind farm setup.

B. Comparison of technical parameters

When comparing High Voltage Alternating Current (HVAC) and High Voltage Direct Current (HVDC) transmission systems, several key points highlight their differences, advantages, and applications. Figure 2 illustrates the structural differences between HVAC and HVDC systems, showcasing how each system operates.

Both systems require specialized components. HVAC systems use transformers and alternating current cables, while HVDC systems rely on converters, rectifiers, and direct current cables. The choice of components significantly impacts the overall efficiency and cost of the transmission system. HVAC systems require additional equipment, such as reactive power compensators, to maintain voltage stability over long distances. This increases the complexity and environmental footprint of the installation. On the other hand, HVDC systems require fewer substations and transformers, simplifying the installation process and reducing the overall spatial and environmental impact. HVDC systems are generally more efficient for long-distance power transmission, as they experience significantly lower energy losses compared to HVAC systems. This makes HVDC particularly advantageous for offshore wind farms located far from shore, where the distance between generation and consumption is substantial [8]. Additionally, HVDC requires only two conductors, reducing material costs and installation complexity, especially in challenging offshore environments. HVDC systems also offer better control over power flows, enhancing grid stability and facilitating the integration of variable renewable energy sources like wind.

In contrast, HVAC systems are more suitable for shorter distances and moderate power capacities due to their simpler design and lower initial installation costs [3]. However, HVAC systems experience higher losses over long distances due to reactive power and cable capacitance effects, which can significantly impact efficiency for offshore wind farms located farther from shore [17]. HVAC systems require three con-




Fig. 1. Connections of cables to the wind turbine system and loads




Fig. 2. Schemes of HVAC (a) and HVDC (b) structures adapted from [2] (CC-BY)

ductors (three-phase configuration), which increases material costs and installation complexity compared to HVDC. Despite these limitations, HVAC remains a practical and cost-effective solution for projects closer to shore, where its efficiency and power handling capabilities are sufficient.

The technical comparison in Table I highlights the advantages of HVDC systems for offshore wind turbine connections. HVDC is particularly well-suited for long-distance transmission, which is often required for offshore wind farms located far from the shore. Additionally, HVDC systems offer lower power losses and better grid stability, making them ideal for integrating variable renewable energy sources like wind power. On the other hand, HVAC systems are more practical for shorter distances due to their simpler design and lower initial costs.

TABLE I

COMPARISON OF TECHNICAL PARAMETERS BETWEEN HVAC AND HVDC SYSTEMS

Parameter	HVAC	HVDC
Transmission Distance	Effective for short distances	Ideal for long distances
Power Losses	Higher due to reactive power	Lower due to direct current
Number of Conductors	Three-phase system (3 conductors)	Two conductors
Grid Stability	Limited control over power flows	Enhanced control over power flows
Integration with Renewable Energy	Less suitable for variable sources	Highly suitable for variable sources

C. Comparison of economic and environmental factors

While technical parameters are essential, economic and environmental factors also play a significant role in determining the feasibility of HVAC and HVDC systems for offshore wind turbine connections. These aspects include installation costs, maintenance requirements, and environmental impact, which are critical for long-term sustainability and cost-effectiveness. Table II provides a detailed comparison of these factors.

Economic and environmental considerations further emphasize the benefits of HVDC systems for offshore wind turbine connections. As shown in Table II, although HVDC systems have higher initial installation costs, they become more cost-effective over time due to reduced maintenance requirements and lower power losses. Additionally, HVDC systems have a smaller environmental footprint and emit lower electromagnetic fields (EMF), making them a more sustainable choice for large-scale offshore wind projects. HVAC systems,

TABLE II
COMPARISON OF ECONOMIC AND ENVIRONMENTAL FACTORS BETWEEN
HVAC AND HVDC SYSTEMS

Parameter	HVAC	HVDC
Infrastructure Complexity	Requires more equipment (e.g., transformers, compensation devices)	Simpler infrastructure
Installation Cost	Lower for short distances	Higher initial cost, but cost-effective for long distances
Maintenance Requirements	Higher due to complex infrastructure	Lower due to simpler design
Environmental Impact	Larger footprint, higher EMF emissions	Smaller footprint, lower EMF emissions

while cheaper for short distances, may not be as environmentally friendly or cost-effective in the long run for offshore applications.

Table II illustrates that HVAC systems are more suitable for shorter distances and local distribution networks due to their lower initial costs and established infrastructure. However, they suffer from higher power losses and require additional equipment for reactive power compensation, which increases complexity and environmental impact. On the other hand, HVDC systems excel in long-distance power transmission, offering lower losses, better grid stability, and enhanced integration with renewable energy sources. While the initial installation costs of HVDC systems may be higher, their long-term cost-effectiveness and reduced environmental footprint make them a preferred choice for offshore applications.

III. DISCUSSION AND RECOMMENDATIONS

High-voltage direct current cables offer numerous advantages for the transmission of electricity generated by offshore wind farms [16]. These advantages can be categorized into four main areas, such as efficiency, cost-effectiveness, environmental impact, and operational flexibility.

A. Efficiency

HVDC systems significantly minimize resistive losses due to their direct current nature, making them particularly advantageous for long-distance power transmission [1]. This efficiency is crucial for maximizing the utilization of energy generated from offshore wind farms, as it allows more of the produced energy to reach consumers without substantial losses. The compact design of HVDC cables enables them to carry more power within a smaller cross-sectional area compared to traditional HVAC cables [14]. This efficient use of space is further enhanced by the multi-terminal capability of HVDC systems, which allows multiple offshore wind farms to connect to a single transmission line, optimizing power transfer. HVDC systems provide enhanced stability by offering better control over voltage levels, which is essential for maintaining grid stability [19]. Additionally, their responsiveness to fluctuations in power demand or generation ensures a reliable energy supply, facilitating the integration of variable renewable energy sources like wind power into the grid.

B. Cost-effectiveness

HVDC systems typically require fewer substations and transformers, which leads to reduced initial capital expenditures [11]. The simplified installation process associated with HVDC technology also contributes to lower costs and faster deployment, making it an economically attractive option. HVDC technology becomes cost-effective at shorter distances compared to HVAC systems, making it suitable for various offshore applications [13]. Furthermore, its efficiency in transmitting power over long distances reduces the overall cost per megawatt-hour delivered, enhancing its economic viability over time. The advanced materials used in the construction of HVDC cables enhance their durability and longevity, reducing degradation over time [5]. This robust design not only leads to fewer failures and lower maintenance needs but also results in significant cost savings associated with cable replacement and system upgrades.

C. Environmental Impact

The compact design of HVDC cables means they are thinner and lighter than HVAC cables, requiring less space for installation [6]. This smaller footprint minimizes environmental disturbance during installation, helping to preserve natural habitats and reduce the overall ecological impact. HVDC systems produce lower electromagnetic fields compared to HVAC systems, which can be beneficial for marine ecosystems [4]. This reduction in electromagnetic interference helps protect marine life and habitats near offshore installations, contributing to sustainability. HVDC technology is specifically designed to connect offshore wind farms to the grid, promoting the use of renewable energy sources [9]. By effectively integrating these renewable sources, HVDC systems help stabilize the overall energy grid and reduce reliance on fossil fuels, leading to lower carbon emissions.

D. Operational Flexibility

HVDC technology allows for the interconnection of different power grids that operate at varying frequencies, enhancing overall grid reliability [7]. This capability facilitates energy trading between regions, optimizing resource use and improving resilience against outages and disruptions. HVDC systems can manage power flows dynamically based on real-time demand and generation conditions, allowing for enhanced load management across the grid [12]. This flexibility also enables the effective integration of energy storage solutions, which is crucial for managing intermittent renewable sources. Designed to operate reliably in challenging offshore environments, HVDC systems ensure consistent power delivery even under adverse conditions [10]. Their inherent design minimizes the risk of outages, contributing to a more reliable energy supply and supporting future expansion without significant overhauls.

IV. CONCLUSIONS AND FUTURE DIRECTIONS

This paper presented a comparative analysis of HVAC and HVDC transmission systems for offshore wind energy. The study indicates that HVDC offers substantial advantages

over HVAC when longer transmission distances are involved. Specifically, HVDC systems exhibit 40–50% lower power losses than HVAC for distances above 80–100 km, which makes them the preferred option for large-scale offshore wind farms situated far from shore. While HVAC remains more practical for shorter connections due to its lower initial installation costs and simpler design, its efficiency decreases significantly with distance, limiting its competitiveness for offshore applications beyond near-shore projects.

From an economic perspective, HVAC can be attractive for projects within about 80 km of the coast, yet HVDC becomes more cost-effective in the long term because of reduced maintenance requirements, lower operational losses, and the possibility of simplified infrastructure. In addition, HVDC solutions present a smaller environmental footprint, lower electromagnetic emissions, and enhanced compatibility with marine ecosystems. The ability of HVDC technology to provide improved grid stability, enable multi-terminal configurations, and integrate variable renewable sources further reinforces its suitability for future offshore projects.

Overall, HVDC can be considered the most advantageous solution for long-distance, high-capacity offshore wind transmission, while HVAC remains viable for near-shore developments with lower capacity requirements. Future work is expected to focus on modular HVDC architectures and advanced converter technologies, which may further enhance cost-effectiveness, scalability, and sustainability, thereby supporting the accelerated integration of offshore wind energy into modern power systems.

REFERENCES

- [1] G.P. Adam and B.W. Williams. “Multi-pole voltage source converter HVDC transmission systems”. In: *IET Generation, Transmission and Distribution* 10.2 (2016), pp. 496–507.
- [2] Byeonghyeon An et al. “Selection of an Optimal Frequency for Offshore Wind Farms”. In: *Energies* 17.10 (2024), p. 2440. DOI: 10.3390/en17102440.
- [3] Ali Bidafar et al. “Coordinated Control of HVDC and HVAC Power Transmission Systems Integrating a Large Offshore Wind Farm”. In: *Energies* 12.18 (2019). Open Access Article, p. 3435. DOI: 10.3390/en12183435.
- [4] C.A. Charalambous et al. “Modeling and Assessment of Short-Term Electromagnetic Interference on a Railway System from Pole-to-Ground Faults on VSC-HVDC Cable Networks with Sea Electrodes”. In: *IEEE Transactions on Industry Applications* 57.1 (2021), p. 121.
- [5] X. Cui et al. “Electrical Lifespan Prediction of HVDC Relay Based on the Accumulated Arc Erosion Mass”. In: *IEEE Transactions on Components, Packaging and Manufacturing Technology* 8.3 (2018), pp. 356–363.
- [6] P. Hu, Y. Liang, and X. Wang. “Topology and control of a new line commutated converter-modular multilevel converter hybrid bipolar high-voltage direct current transmission system”. In: *International Transactions on Electrical Energy Systems* 27.11 (2017), e2402.
- [7] Imdadullah, A.R. Beig, and M.S.J. Asghar. “Performance Evaluation and Reliability of Flexible Asynchronous AC Link and LCC-HVDC Link under Fault Conditions”. In: *IEEE Access* 8 (2020), p. 120562.
- [8] J. Jones and I. Childs. “Floating substations for commercial-scale floating windfarms”. In: *Society of Petroleum Engineers - SPE Offshore Europe Conference and Exhibition 2021, OE 2021* (2021).
- [9] Y. Li et al. “Engineering practices for the integration of large-scale renewable energy VSC-HVDC systems”. In: *Global Energy Interconnection* 3.2 (2020), pp. 149–157.
- [10] U. Oh et al. “Probabilistic reliability based HVDC expansion planning of power system including wind turbine generators”. In: *Transactions of the Korean Institute of Electrical Engineers* 67.1 (2018), pp. 8–15.
- [11] L. Reed et al. “Converting existing transmission corridors to HVDC is an overlooked option for increasing transmission capacity”. In: *Proceedings of the National Academy of Sciences of the United States of America* 116.28 (2019), pp. 13879–13884.
- [12] K. Rouzbehi, S.S. Heidary Yazdi, and N. Shariati Moghadam. “Power Flow Control in Multi-Terminal HVDC Grids Using a Serial-Parallel DC Power Flow Controller”. In: *IEEE Access* 6 (2018), p. 56934.
- [13] G. Samorodov et al. “Technical and economic comparison between direct current and half-wavelength transmission systems for very long distances”. In: *IET Generation, Transmission and Distribution* 11.11 (2017), pp. 2871–2878.
- [14] M. Wang, G. Zhang, and Z. Zhang. “Impact of HVDC transmission capacity on multi-send HVDC system voltage stability”. In: *Energy Reports* 8 (2022), p. 1004.
- [15] M. Wang et al. “Impedance Modeling and Stability Analysis of All-DC Delivered Offshore Wind Farm”. In: *IEEE Journal on Emerging and Selected Topics in Circuits and Systems* 12.1 (2022), pp. 20–28.
- [16] S. Wang et al. “A maximum available power algorithm for multi-infeed HVDC system based on equivalent impedance”. In: *International Journal of Electrical Power and Energy Systems* 129 (2021), p. 106829.
- [17] N.T.H. Yen, C. Hongkun, and L.N. Giang. “Study on VSC-HVDC grid topology of offshore wind farms”. In: *Cluster Computing* 22 (2019), pp. 14803–14810.
- [18] J. Zhang and H. Wang. “Development of offshore wind power and foundation technology for offshore wind turbines in China”. In: *Ocean Engineering* 266 (2022), p. 113256.
- [19] J. Zhao et al. “Coordinated DC voltage control strategy of hybrid HVDC with multi-infeed MMC inverters considering commutation failures”. In: *International Transactions on Electrical Energy Systems* 31.5 (2021), e12881.