

The Dual Model under Pressure

How Robust Is Leak Detection under Uncertainties and Model Mismatches?

Campbell, Enrique; Abraham, Edo; Koslowski, Johannes; Piller, Olivier; Steffelbauer, David B.

10.3390/engproc2024069089

Publication date

Document Version Final published version

Published in Engineering Proceedings

Citation (APA)

Campbell, E., Abraham, E., Koslowski, J., Piller, O., & Steffelbauer, D. B. (2024). The Dual Model under Pressure: How Robust Is Leak Detection under Uncertainties and Model Mismatches? *Engineering* Proceedings, 69(1), Article 89. https://doi.org/10.3390/engproc2024069089

Important note

To cite this publication, please use the final published version (if applicable). Please check the document version above.

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy

Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.





Proceeding Paper

The Dual Model under Pressure: How Robust Is Leak Detection under Uncertainties and Model Mismatches? †

Enrique Campbell 1,* D, Edo Abraham 2 D, Johannes Koslowski 1 D, Olivier Piller 3 D and David B. Steffelbauer 1

- Group for Hydroinformatics, Urban Systems Department, KWB—Kompetenzzentrum Wasser Berlin gGmbH, 10825 Berlin, Germany; johannes.koslowski@kompetenz-wasser.de (J.K.); david.steffelbauer@kompetenz-wasser.de (D.B.S.)
- Department of Water Management, Faculty of Civil Engineering and Geosciences, Delft University of Technology, 2628 CN Delft, The Netherlands; e.abraham@tudelft.nl
- ³ INRAE Institut National de Recherche Pour L'Agriculture, L'Alimentation et L'Environnement, Aqua Devition, Environnement Territoires et Infrastructures Research Unit, Gazinet, F-33612 Cestas, France; olivier.piller@inrae.fr
- * Correspondence: enrique.campbell@kompetenz-wasser.de
- Presented at the 3rd International Joint Conference on Water Distribution Systems Analysis & Computing and Control for the Water Industry (WDSA/CCWI 2024), Ferrara, Italy, 1–4 July 2024.

Abstract: This paper investigates the robustness of one innovative model-based method for leak detection, namely the Dual Model. We evaluate the algorithm's performance under various leakage scenarios in the L-Town network, despite uncertainties and model mismatches in (i) base demand, (ii) pipe roughness, (iii) the number of sensors, and (iv) network topology. Our investigation results indicate that the *Dual Model* is highly sensitive to discrepancies in the first three parameters. However, the impact can be mitigated through sensor-specific calibration, such as adjusting sensor elevations. Moreover, the *Dual Model* has demonstrated robustness to minor topology mismatches, like those introduced by closed valves.

Keywords: leak detection; dual model; simulation model; robustness



Citation: Campbell, E.; Abraham, E.; Koslowski, J.; Piller, O.; Steffelbauer, D.B. The Dual Model under Pressure: How Robust Is Leak Detection under Uncertainties and Model Mismatches? *Eng. Proc.* **2024**, *69*, 89. https://doi.org/10.3390/engproc2024069089

Academic Editors: Stefano Alvisi, Marco Franchini, Valentina Marsili and Filippo Mazzoni

Published: 9 September 2024



Copyright: © 2024 by the authors. Licensee MDPI, Basel, Switzerland. This article is an open access article distributed under the terms and conditions of the Creative Commons Attribution (CC BY) license (https://creativecommons.org/licenses/by/4.0/).

1. Introduction

Model-based methods, which integrate hydraulic models with measurement data, have emerged as an efficient alternative to conventional leakage detection techniques, offering the potential for significant reductions in labor costs through automation. Among these methods, the pressure–leak duality method [1], also known as the Dual Model, provides a novel approach by incorporating virtual reservoirs at sensor locations and setting the reservoir head to the measured pressure levels. As a consequence, this approach converts leak-induced pressure drops into virtual leakage flows, effectively amplifying the signal of a leak, leading to strong localized signals affecting sensors close to the leak, and the sum of all virtual flows provides a good first approximation of the actual magnitude of the leak. The concept of the Dual Model is loosely based on linear programming. Here, a primal linear program can be transformed into a dual linear program by converting variables into constraints, and vice versa. In the Dual Model, mass or flow conservation constraints are relaxed by allowing virtual inflows and outflows into the virtual reservoirs. At the same time, virtual leak flows become new variables. Pressures at sensor locations, initially treated as measurement variables, become constraints in the Dual Model, as they are considered fixed reservoir heads. As per this tradition, we refer to the original hydraulic model without virtual reservoirs as the *Primal Model*, aligning with linear programming terminology.

The *Dual Model* has demonstrated high effectiveness in detecting leaks under realistic conditions, as evidenced by its first-place award in the Battle of Leakage Detection and Isolation Methods (BattLeDIM) [2]. However, the BattLeDIM network (L-Town) includes a high number of pressure sensors and was very well calibrated (i.e., with respect to demand

Eng. Proc. **2024**, 69, 89

and roughness). Thus, arise two questions: what would happen if the input parameters of the model are not well known? What are the limitations of a model that violates the laws of mass conversation, as the *Dual Model* does, considering that there is generally no free lunch?

This work aims to stress-test the *Dual Model* systematically by introducing perturbations to near-ideal conditions in Area A from the L-Town network. This includes the following: (1) uncertainties in the hydraulic model input parameters, such as variations in base demand and pipe roughness; (2) changes to network topology by opening and closing pipes; and (3) reduction in the number of available pressure sensors. The impact of these perturbations on the capacity of the *Dual Model* to reconstruct the inserted leakages was assessed. For that purpose, the Root Mean Squared Error (*RMSE*) between the leakage flow in the *Primal Model* (Q_{Leak}) and the sum of all the virtual flows ($Q_{virtual}$) in the *Dual Model* was computed.

2. Methodology

We created a set of 12 incipient leakage scenarios distributed across area A of the L-Town network [start time: 8 January 2018 00:00:00, Peak time: 22 January 2018 00:00:00, size: 0.01 mm, peak flow: \sim 2.7 L/s, end time: 31 January 2018 00:00:00]. Each leakage was inserted into the *Primal Model* as a node in the middle of a pipe. This node was associated with a demand pattern of a 31-day period (5 min interval). Following the insertion of the leakage, we conducted simulations to capture pressure dynamics within the *Primal Model*. Pressure "readings" were then extracted from 30 representative Pressure Sensor Nodes (*PSNs*) over the simulation period. To construct the *Dual Model*, we connected virtual reservoirs (*VRs*) with a total head of 1 to each *PSN* through Throttle Control Valves (*TCV*). A head pattern corresponding to the pressure values from the previous period plus the *PSN* elevations were incorporated into each *VR*. Then, the *Dual Model* was simulated, and the sum of all $Q_{virtual}$ values was quantified. This sum was then compared to Q_{Leak} by means of *RMSE*.

Perturbations in the Dual Model

In ideal conditions (calibrated base demand and roughness, no topological mismatches, and a large number of sensors), the sum of the $Q_{virtual}$ values corresponds almost perfectly (RMSE 0.0009) with Q_{Leak} (Figure 1a). In other words, the Dual Model is capable of resembling Q_{Leak} almost to perfection. Additionally, the VRs closest to the leak account for the highest percentage in the sum of the $Q_{virtual}$ values, ~91% (~22% + ~52% + ~9% + ~8%).




Figure 1. The *Dual Model* detecting one leakage in ideal conditions. (**left**) The sum of all $Q_{virtual}$ values resembles almost perfectly (gray and dashed line) Q_{Leak} . (**right**) The *VR*s closest to the leak account for the largest percentage of $Q_{virtual}$.

Eng. Proc. 2024, 69, 89

The following perturbations were tested: *the variation in base demand and roughness*: both parameters were increased by 0.1%, 0.5% and 1%, and decreased by the same percentages. The *change of topology*: the shutdown of a set of 11 pipes (one at a time) with high network centrality values. For every closure, all 12 leak scenarios were evaluated. *The reduction in the number of sensors*: three scenarios were tested: (1) one with 22 sensors (sensors too close to each other were eliminated, leaving only 1); (2) one with 6 sensors (close to pipes with high centrality); and (3) one with only 4 sensors (close to the reservoirs *R1* and *R2*, to the pressure regulation valve of *Area B*, and to the entrance of *Area C*).

3. Results

The results indicate that variations in pressure between the Primal and *Dual Model* play a crucial role in the performance of the *Dual Model*. Perturbing base demand generates greater head loss in the pipes and reduces the pressure at the nodes. This leads to a reduction in network head compared to the *VRs*, resulting in $Q_{virtual}$ flows from the *VRs* to the network (negative flows). Figure 2(left) clearly depicts this effect. Conversely, when the base demand is reduced, the network exhibits higher hydraulic head compared to the *VRs*, resulting in an excessive increase in $Q_{virtual}$ from the network to the *VRs*, even during periods without leakage. Based on this observation, it is expected that an adjustment in the elevation to get rid of constant offsets or the pattern factors of the *VRs* to minimize the noise will be able to counteract this effect. For example, during leak-free periods, the factors must be adjusted in such a way that $Q_{virtual}$ becomes minimal. This would represent a highly attractive alternative to the traditional calibration of base demand and roughness, highly dependent on abundant and precise measurement data. It is worth noting that a variation of 0.1% in both parameters does not generate significant *RMSE* values; however, a variation of +/-0.5% already produces substantial values of the latter.




Figure 2. Effect of perturbing base demand and roughness. (**left**) Comparison of sum of $Q_{virtual}$ and Q_{Leak} in different base demand perturbation scenarios. (**right**) Comparison of sum of $Q_{virtual}$ and Q_{Leak} in different roughness perturbation scenarios.

Figure 3 depicts an *RMSE* comparison between Q_{Leak} and the sum of $Q_{virtual}$ s for 12 leakages in different perturbation scenarios. It is worth noting that despite the errors being of the same order of magnitude, those generated by perturbation in base demands remain very constant, different to the case of the perturbation of roughness. This relates to the fact that for base demand, the variations were applied directly to the demand multiplier. This means that the perturbations were applied uniformly to all nodes. In the case of roughness, Monte Carlo simulation was used to generate random samples around the initial roughness factors. Concerning variation in topology, for most scenarios, the *RMSE* between Q_{Leak} and the sum of $Q_{virtual}$ s is near to zero, apart from "leak p866", which exhibits a slight increase in *RMSE*, as in Figure 4(left). Regarding the reduction in the number of sensors, the *RMSE* becomes highly significant in the scenarios with only four and six sensors, as in Figure 4(right).

Eng. Proc. **2024**, 69, 89




Figure 3. *RMSE* comparison for 12 leakage scenarios. (**left**) Perturbations of base demand. (**right**) Perturbations of roughness.




Figure 4. (**left**) The effect of shutting down a set of 11 pipes (one at a time). (**right**) The *RMSE* for four "amount of sensors scenarios".

4. Conclusions

This research systematically assessed the robustness of the pressure–leak duality method for detecting water leakages in water supply networks, emphasizing its performance under various perturbations and uncertainties. While the *Dual Model* demonstrates high accuracy under ideal conditions with well-calibrated parameters and sufficient pressure sensor coverage, it exhibits high sensitivity to sensor availability and mismatches in base demand and roughness. Simple changes in network topology have a minor impact on detection accuracy, whereas reductions in sensor numbers significantly compromise performance. Future research should focus on refining the *Dual Model* to enhance its robustness to parameter uncertainties and sensor limitations, thereby improving its practical utility in real-world leak detection applications.

Author Contributions: Conceptualization, E.C. and D.B.S.; methodology, E.C.; software, E.C.; validation, D.B.S., E.A. and O.P.; formal analysis, E.C.; investigation, E.C.; resources, E.C.; data curation, J.K.; writing—original draft preparation, E.C.; writing—review and editing, E.C., D.B.S., O.P., E.A. and J.K.; visualization, E.C.; supervision, D.B.S.; project administration, D.B.S.; funding acquisition, D.B.S. All authors have read and agreed to the published version of the manuscript.

Eng. Proc. 2024, 69, 89 5 of 5

Funding: This work is part of the iOLE project and receives funding from the Federal Ministry of Education and Research (BMBF) within the funding measure "Digital GreenTech—Environmental Engineering meets Digitalisation" as part of the "Research for Sustainability (FONA) Strategy" (funding code: 02WDG1689A).

Institutional Review Board Statement: Not applicable.

Informed Consent Statement: Not applicable.

Data Availability Statement: Data supporting the conclusions will be made available on request.

Conflicts of Interest: The authors declare no conflicts of interest.

References

1. Steffelbauer, D.B.; Deuerlein, J.; Gilbert, D.; Abraham, E.; Piller, O. Pressure-Leak Duality for Leak Detection and Localization in Water Distribution Systems. *J. Water Resour. Plan. Manag.* **2022**, *148*, 04021106. [CrossRef]

2. Vrachimis, S.G.; Eliades, D.G.; Taormina, R.; Kapelan, Z.; Ostfeld, A.; Liu, S.; Kyriakou, M.; Pavlou, P.; Qiu, M.; Polycarpou, M.M. Battle of the Leakage Detection and Isolation Methods. *J. Water Resour. Plan. Manag* **2022**, *148*, 04022068. [CrossRef]

Disclaimer/Publisher's Note: The statements, opinions and data contained in all publications are solely those of the individual author(s) and contributor(s) and not of MDPI and/or the editor(s). MDPI and/or the editor(s) disclaim responsibility for any injury to people or property resulting from any ideas, methods, instructions or products referred to in the content.