

Desiccant Integrated Facade System

P5 Presentation

Natchai Suwannapruk
4738128

9 July 2019




“ If our house is falling apart you wouldn't say that you have the situation under control..


*And place the living conditions of all species in the hand of „
inventions that are yet to be invented.*

Greta Thunberg, 2019

Global Land-Ocean Temperature Index




World Energy Consumption for Space Cooling



Drivers for Cooling Demand

v



Drivers of energy use for cooling

High levels of humidity tend to increase the need for cooling to achieve a given level of thermal comfort

Driver for Cooling Demand

Population and Economic Growth


"In hot countries, rising incomes and population are pushing up demand for cooling."



Population Growth Rate



Office Area Growth Rate



*"without new cooling technologies or strategies, **air conditioning** alone would be accounted for 40% of South East Asia's electricity demand"*

Research Objective

Elaborate the challenges imposed by the hot and humid climate context


Explore the potential of existing dehumidification technologies, cooling technologies, and heat prevention strategies

Develop a facade scheme by assembling the applicable system

Develop and evaluate an integration strategy of the facade scheme

“How can the **desiccant cooling facade system** be integrated into the built environment to reduce cooling load of **office buildings** in a **hot and humid climate?**”

Design Strategy



Disassembly




Redesign



Integration


Research Structure



Research Structure

Contextual Framework

Contextual Framework




Tropical Climate

A. Tropical

High and constant net solar radiation throughout the year.

Temperature difference between day and night is greater than that between the warmest and the coolest month.



1175
kWh/m²
Direct Radiation




71%
Average
Humidity



28.8°C
Average
Temperature

38.7°C
Maximum
Temperature

Office Building Completion Timeline




Office Area Growth Rate

662,676

sq.m

Will be completed in 2019-2021




Bangkok's
Built Context

Facade Classification

Facade Typologies



Thin Skins




Thick Skins

Office Building Typology

Office Building over 100m

1982



Bangkok Bank Tower

1993




Sinn Sathorn Tower

1994



TMB Bank Tower



Sathorn City Tower



Vanity Tower

1995




Bangkok's
Built Context



United Center Tower

1996



RS Tower



SiamBank Tower



Tipco Tower

1996



Abdulrahim Place



Thai Wah Tower



Jewelry Trade Tower



Ital Thai Tower



Elephant Tower

1997



U Chu Liang Tower



Emporium Suites Tower



Sathorn House Tower



Capitol Tower



Shinawatra III Tower

1997

2000

2001



CRC Tower



State Tower



Office at Central World



Exchange Tower



Chamchuri Square Tower

2004

2008

2011



Park Venture Tower



Sathorn Square Tower

2016

2017



Pearl Tower



Gaysorn Tower



Square Tower

Office Building Typology

Future Trend

2018



Krungsri Ploenchit Tower



Samyan Mitrtown



Ari Hill Tower

2019



T1 Tower



MS Siam Tower



Singha Complex


The result of improvements in
the window U-value

Shift of architectural trend from
conventional to modern ones

Building's technological
advancement


Challenges

Efficiency of Energy Saving Strategy



Challenges

Efficiency of Energy Saving Strategy



Thermal Comfort

Acceptable Thermal Condition

Case Study I : John F. Busch

770

Office Workers



No. of Surveys

1.1
MET

0.56
clo

24.7°C
ET
Mean Temperature

24.3°C
SET
Mean Temperature



Metabolic | Clothing



Temperature

22°C-28°C
Acceptable Range



Humidity



Air Speed

1520

Office Worker

1.2
MET

25.6°C
Mean Temperature

24.5°C-27.4°C
Acceptable Range

50%-60%
Humidity

0.2
m/s
Wind Speed

Average Value

24.9°C

Mean Temperature

25.5°C

Acceptable Range



55%
Humidity

0.2
m/s
Wind Speed

Thermal Comfort

Acceptable Thermal Condition

Case Study I : John F. Busch



Case Study II : Yamtraipat et.al

1520 Office Worker



No. of Surveys

1.2 MET



Metabolic | Clothing

25.6°C Mean Temperature



Temperature

24.5°C-27.4°C Acceptable Range



Humidity

50%-60%
Humidity



Air Speed

0.2 m/s Wind Speed

Average Value

24.9°C
Mean Temperature



25.5°C
Acceptable Range




55%
Humidity



0.2 m/s Wind Speed


Research Structure

Cooling System Framework




Research Structure

Cooling System Framework



Cooling Strategies

Passive Cooling Strategies




Summary of simulated scenarios for Singapore climate (Prieto et al., 2018)

**Ventilation strategy is not suitable for a
warm-humid climate**

Cooling Strategies

Passive Cooling Strategies



Smaller glazed area is highly recommended in a warm-humid climate


Shading and glazing type should be considered according to the façade requirements

Dehumidification Strategy


Desiccant System



Desiccants work based on the principle of moisture transfer due to the difference of vapor pressure between the air and the desiccant




Dehumidification



Regeneration

Solid Desiccant System



Desiccant Coated Heat Exchanger (DCHE)



Desiccant Coated Heat Exchanger (DCHE)


DCHE is fabricated by coating the desiccant material directly onto the fin side of a conventional fin tube heat exchanger.

- Developed to deal with the limitations of the conventional desiccant packages
- Regeneration could be done with relatively higher efficiency



Regeneration System

Photovoltaic-Thermal System



Liquid PVT Collector

7.54%

Electrical
Efficiency


70%

Thermal
Efficiency

Evaporative Cooling Strategy

Maisotsenko-cycle

Riangvilaikul and Kumar




Maisotsenko Cycle (M-Cycle)

63-85%


Dew-point
Effectiveness


100-115%

Wet Bulb
Effectiveness



Design Concept







“How can the **desiccant cooling facade system** be integrated into the built environment to reduce cooling load of **office buildings** in a **hot and humid climate?**”

'Desi-grated'


Desiccant Integrated Facade System

'Desi-grated'

Part I : Dehumidification Component



Frame / Opening



'Desi-grated'

Part II : Air Supply Component




Frame / Opening



Modularity



Wall Component



'Desi-grated'

Part III : Shading Component



Frame / Opening




Modularity




Buoyancy


Roof Structure




'Desi-grated'

Desiccant Integrated Facade System









System Component

Composite Silica Gel Heat Exchanger (CCHE)

Ge et al. 2017



CCHE System Configuration

1.25

kW

Heat Transfer Value

3.9

g/kg

Humidity Difference

Water Parameter




Cooling Water (°C)	Heating Water (°C)	Water Volume (L/h)	Inlet Air Temperature (°C)	Relative Humidity (%)	Flow Velocity (m/s)	Cycle Switch Period (mins)
15	50	200	30	70	1.54	10

Air Parameter

System Component

M-Cycle - Cooling System

Riangvilaikul and Kumar



Dewpoint Indirect Evaporative System Configuration

101-104%

Wet Bulb Effectiveness

75-79%

Dew-point Effectiveness

Water Parameter

Water Volume
(g/h)

60

Air Parameter

Flow Velocity
(m/s)


<2.4

Working Air
(kg/kg)

0.33


'Desi-grated'

Desiccant Integrated Facade System





'Desi-grated'

Desiccant Integrated Facade System



Section 1


M-Cycle + Supply Air Channel



Connection Detail



M-Cycle Component

1. L-Bracket
2. Fiberwool Insulation
3. Aluminium Cladding
4. Transom
5. PUR Insulation
6. Waterproof Membrane
7. Thermalfoot
8. 10mm Concrete Bolt
9. Perforated Aluminium Cladding
10. Aluminium Composite Cladding
11. Inlet Air Channel
12. Inlet Aluminium Air Grill
13. Aluminium Facade Grill
14. Air Filter
15. M-cycle : Wet Channel
16. M-cycle : Dry Channel
17. Promatect Insulation
18. Water Sprinkler
19. C-Channel Bracket
20. Return Water Gutter
21. Inlet Cold Water Pipe
22. Return Main Hot Water Pipe
23. Supply Main Hot Water Pipe



Section 2

Dehumidification Channel




M-Cycle Component

Air Flow Schematic


M-Cycle : Supply Air Scheme

1. Inlet Air Chamber from CCHE
2. M-Cycle : Dry Channel
3. Air Channel
4. Supply Air Channel
5. Water Pipe Shaft





M-Cycle : Working Air Scheme

1. Inlet Air Chamber from Dry Channel
2. M-Cycle : Wet Channel
3. Air Channel
4. Water Pipe Shaft
5. Cold Water Inlet Pipe




Section 3

Water Pipe Shaft




Water Pipe Schematic

Cold Water Pipe Diagram





Water Pipe Schematic

Hot Water Pipe Diagram



Section 4

Supply Air Unit




Connection Detail

Air Supply Component

1. L-Bracket
2. Fiberwool Insulation
3. Aluminium Cladding
4. Transom
5. PUR Insulation
6. Waterproof Membrane
7. Thermalfoot
8. 10mm Concrete Bolt
9. Aluminium Composite Cladding
10. Supply Air Channel
11. Aluminium Supply Air Slot
12. Promatect Insulation
13. C-Channel Bracket
14. Metal Screw
15. Main Return Hot Water Pipe
16. Main Supply Hot Water Pipe

Detail C



Detail D



How Does it Work?



How does it work?

Inlet Ambient Air





How does it work?

Return Air





How does it work?

Mixed Air





How does it work?

CCHE - 1





How does it work?

CCHE - 2



How does it work?

Supply Air




Design Process

Design Concept

System Constraints

System Sizing

Cross Section Area = **0.12 m²**




Mass Flow Rate

$$m = \rho v A$$

	ρ Air Density (kg/m ³)	v Air Velocity (m/s)	A Cross Section Area (m ²)
CCHE	1.17	1.54	0.12
M-Cycle	1.17	1.54	0.12

0.22
kg/s

Mass Flowrate



Cross Section Area = **0.06 m²**

No. of Dry Channel = **2**

Total Area = **0.12 m²**

Volume Flow Rate

$$Q = v A$$

	v Air Velocity (m/s)	A Cross Section Area (m ²)
CCHE	1.54	0.12
M-Cycle	1.54	0.12

0.18
m³/s

Volume Flowrate

System Constraints

Fresh Air Ratio

Fresh Air Ratio

100% Fresh Air

0.13
m³/s

Conditioned Air
Volume Flowrate

Air Velocity
(m/s)

2. CCHE

1.54

70 : 30

0.18
m³/s

Conditioned Air
Volume Flowrate

Air Velocity
(m/s)

1.54

30 : 70

0.20
m³/s

Conditioned Air
Volume Flowrate

Air Velocity
(m/s)

1.08

30 : 70*

0.42
m³/s

Conditioned Air
Volume Flowrate

Air Velocity
(m/s)

1.54

4. Mixed Air

0.97

*M-Cycle Cross Section:
= 0.25m²

System Constraints

System Performance

1 Inlet Temperature

28.8


°C

Temperature

70


%

Relative Humidity




System Constraints

System Performance




System Constraints

System Performance




System Constraints

System Performance




System Constraints

System Performance




System Constraints

System Performance





System Constraints

System Performance





Design Concept

Concept 1 : Compact System





Design Concept

Concept 2 : Extensive System





Supply Air | Schematic Diagram

Inlet Ambient Air





Supply Air | Schematic Diagram

Mixed with Return Air





Supply Air | Schematic Diagram

Supply Air




Exhaust Air | Schematic Diagram

Inlet Ambient Air




Design Concept

Design Assessment



	Exterior Dimension WxLxH (mm)	Interior Dimension WxLxH (mm)	Air Supply Position
A	450 x 2200 x 3500	500 x 2200 x 3500	-
B	150 x 2200 x 3500	500 x 1800 x 3500	At Ceiling Level

Application Aspect



	Exterior Dimension WxLxH (mm)	Interior Dimension WxLxH (mm)	Air Supply Position
A	450 x 5100 x 3500	-	-
B	-	840 x 1100 x 3500	At Body Level



Conditioned Air
Volume Flowrate



Performance Aspect




Conditioned Air
Volume Flowrate



Window to Wall Ratio


Design Concept

Design Assessment



	Exterior Dimension WxLxH (mm)	Interior Dimension WxLxH (mm)	Air Supply Position
A	450 x 2200 x 3500	500 x 2200 x 3500	-
B	150 x 2200 x 3500	500 x 1800 x 3500	At Ceiling Level

Application Aspect



	Exterior Dimension WxLxH (mm)	Interior Dimension WxLxH (mm)	Air Supply Position
A	450 x 5100 x 3500	-	-
B	-	840 x 1100 x 3500	At Body Level

Performance Aspect



Conditioned Air
Volume Flowrate



Conditioned Air
Volume Flowrate






Window to Wall
Ratio




Design Concept

Design Assessment




System Requirement

Water / Thermal Requirement




Water Requirement for 3 - CCHE



System Requirement

Water / Thermal Requirement



Water Requirement for 3 - CCHE




Heating Requirement



System Requirement

Electricity Requirement



Electricity Requirement




Integrated System				
	Volume Flowrate (m^3/s)	Volume Flowrate (cfm)	Energy Consumption (kWh)	Energy Consumption (kWh/day) (11 Hours)
Blower 1	0.18	381	0.128	1.4
Blower 2	0.42	889	0.171	1.9
Fan 1	0.18	381	0.037	0.4
Fan 2	0.60	1271	0.117	1.3
Fan 3	0.18	381	0.037	0.4

5.4
kWh/day


Total Electricity
Consumption

Design Development



Solar Study





North Facade



South Facade




East Facade



West Facade

PVT Integration


Concept 1 : Horizontal Panel



Concept 1 :Horizontal Orientation


Total Area	3.68 sq.m			
Optimal HSA (°)	N	E	S	W
Module A	27	41	34	42
Module B	56	57	48	54
Average Daily Radiation (kWh)	7.1	10.5	12.6	10.5

PVT Performance	N	E	S	W
Average Daily AC Energy (kWh)	1.2	1.4	1.6	1.4
Average Daily Thermal Energy (kWh)	4.9	7.5	8.8	7.4



PVT Integration


Concept 2 : Vertical Panel



Concept 2 : Vertical Orientation


Total Area	3.74 sq.m			
Optimal HSA (°)	N	E	S	W
Module C	312	109	161	243
Module D	48	115	158	251
Average Daily Radiation (kWh)	5.4	8.4	8.6	8.3

PVT Performance	N	E	S	W
Average Daily AC Energy (kWh)	0.7	0.9	0.9	0.9
Average Daily Thermal Energy (kWh)	3.8	5.9	6.0	5.8



PVT Integration


Concept 3 : Mixed Panel



Concept 3 : Horizontal + Vertical Orientation


Total Area	6.70 sq.m			
Optimal HSA (°)	N	E	S	W
Module A	35	47	32	41
Module B	56	51	56	61
Module C	48	111	199	262
Module D	312	110	168	247
Average Daily Radiation (kWh)	9.9	15.7	17.4	15.6

PVT Performance	N	E	S	W
Average Daily AC Energy (kWh)	1.6	2.0	2.1	1.9
Average Daily Thermal Energy (kWh)	6.9	11.0	12.2	10.9



PVT Integration

Solar Radiation Assessment



Annual Total Solar Radiation
(kWh)


Annual Average Solar Radiation per sq.m
(kWh/m²)

	Concept 1 Horizontal Orientation				Concept 2 Vertical Orientation				Concept 3 Horizontal + Vertical Orientation			
Total Area	3.68 sq.m				3.74 sq.m				6.70 sq.m			
	N	E	S	W	N	E	S	W	N	E	S	W
Average Daily Radiation (kWh)	7.1	10.7	12.6	10.5	5.4	8.4	8.6	8.3	9.9	15.7	17.4	15.6
Average Daily Radiation per m ² (kWh/m ²)	1.9	2.9	3.4	2.9	1.4	1.1	1.1	1.1	1.5	2.3	2.6	2.3

PVT Performance	N	E	S	W	N	E	S	W	N	E	S	W
Average Daily AC Energy (kWh)	1.2	1.4	1.6	1.4	0.7	0.9	0.9	0.9	1.6	2.0	2.1	1.9
Average Daily Thermal Energy (kWh)	4.9	7.5	8.8	7.4	3.8	5.9	6.0	5.8	6.9	11.0	12.2	10.9

PVT Integration

Solar Radiation Assessment




	Concept 1 Horizontal Orientation				Concept 2 Vertical Orientation				Concept 3 Horizontal + Vertical Orientation			
Total Area	3.68 sq.m				3.74 sq.m				6.70 sq.m			
	N	E	S	W	N	E	S	W	N	E	S	W
Average Daily Radiation (kWh)	7.1	10.7	12.6	10.5	5.4	8.4	8.6	8.3	9.9	15.7	17.4	15.6
Average Daily Radiation per m ² (kWh/m ²)	1.9	2.9	3.4	2.9	1.4	1.1	1.1	1.1	1.5	2.3	2.6	2.3

PVT Performance	N	E	S	W	N	E	S	W	N	E	S	W
Average Daily AC Energy (kWh)	1.2	1.4	1.6	1.4	0.7	0.9	0.9	0.9	1.6	2.0	2.1	1.9
Average Daily Thermal Energy (kWh)	4.9	7.5	8.8	7.4	3.8	5.9	6.0	5.8	6.9	11.0	12.2	10.9

PVT Integration


Concept 4 : Additional Module



Concept 4 : Additional Horizontal Orientation

Total Area	2.84 sq.m (6.52 sq.m)
HSA (°)	N E S W
Module E	27 41 34 42
Average Daily Radiation (kWh)	5.5 8.3 9.7 8.1

PVT Performance	N	E	S	W
Average Daily AC Energy (kWh)	1.1	1.1	1.3	1.1
Combined with Concept 1 (kWh)	2.3	2.5	2.9	2.5
Average Daily Thermal Energy (kWh)	3.8	5.8	6.8	5.7
Combined with Concept 1 (kWh)	8.7	13.3	15.6	13.1



PVT Integration

Energy Assessment

Thermal Energy Requirements (kW/day)

	N	E	S	W
Energy Production	8.7	13.3	15.6	13.1
Concept 1 + 4	1.34 kW/m ²	2.04 kW/m ²	2.39 kW/m ²	2.00 kW/m ²
Case 1 Energy Required:	-34.9	-30.3	-28	-25
Case 1 Area Required:	+26.04 m ²	+14.85 m ²	+11.72 m ²	+12.5 m ²
Case 2 Energy Required:	-25.1	-22.5	-18.2	-20.7
Case 2 Area Required:	+18.73 m ²	+6.52 m ²	+6.53 m ²	+10.35 m ²
Case 3 Energy Required:	-4.4	+0.2	+2.5	+0.0
Case 3 Area Required:	+3.28 m ²	-	-	-

Electricity Requirements (kW/day)

	N	E	S	W
Energy Production	2.3	2.5	2.9	2.5
	0.35 kW/m ²	0.39 kW/m ²	0.46 kW/m ²	0.39 kW/m ²
Energy Required:	-3.1	-2.9	-2.5	-2.9
Area Required:	+7.95 m ²	+7.44 m ²	+5.4 m ²	+7.44 m ²

PVT Integration


Energy Assessment

Thermal Energy Requirements (kW/day)

	N	E	S	W
Energy Production Concept 1 + 4	8.7	13.3	15.6	13.1
	1.34 kW/m ²	2.04 kW/m ²	2.39 kW/m ²	2.00 kW/m ²
Case 1 Energy Required:	-34.9	-30.3	-28	-25
Case 1 Area Required:	+26.04 m ²	+14.85 m ²	+11.72 m ²	+12.5 m ²
Case 2 Energy Required:	-25.1	-22.5	-18.2	-20.7
Case 2 Area Required:	+18.73 m ²	+6.52 m ²	+6.53 m ²	+10.35 m ²
Case 3 Energy Required:	-4.4	+0.2	+2.5	+0.0
Case 3 Area Required:	+3.28 m ²	-	-	-

Electricity Requirements (kW/day)

	N	E	S	W
Energy Production	2.3	2.5	2.9	2.5
	0.35 kW/m ²	0.39 kW/m ²	0.46 kW/m ²	0.39 kW/m ²
Energy Required:	-3.1	-2.9	-2.5	-2.9
Area Required:	+7.95 m ²	+7.44 m ²	+5.4 m ²	+7.44 m ²



Design Application

Integration to Benchmark

Benchmark

Krungthai Bank - Sukhumvit Building


General Information

Building Function	Office Building
Operation Hours per Day	8
Operation Days per Year	246

Area Distribution

	m ²
Total Floor Area	38,857
Floor Area	27,731
Air Conditioned Floor Area	25,278
Un-Conditioned Floor Area	2,093
Parking Area	11,486






y
x
z

Benchmark

Solar Analysis



North Facade


South Facade

East Facade


West Facade

Benchmark

Central HVAC System




Pre-Cooled AHU - 1		
Cooling Capacity		
Sensible (BTU)	737,500	
	216.14kW	
Total (BTU)	281,700	
	82.56kW	
Water Flow (GPM)	75.3	
	17.10m³/h	
Supply Fan (CFM)	7,800	



Benchmark

Central HVAC System

Cooling Tower		
Unit	1-5	6
Water Flow (GPM)	600	450
	102,20m³/h	102,20m³/h
Temp. In/Out	100/90°F	
	37.78/32.2°C	
Ambient Temp.	83°F	
	28.33°C	
Fan Motor	5.5 kW	
	380/3/50	



Screw Water Cooled Chiller

Unit	1-3	4
Capacity (BTU)	4,800,000	1,800,000
	1406.74kW	527.52kW

Chilled Water

Water Flow (GPM)	960	360
	218.04m³/h	81.76m³/h
Temp. In/Out	55/45°F	
	12.78/7.22°C	

Condenser Water

Water Flow (GPM)	1200	450
	272.55m³/h	102.20m³/h
Temp. In/Out	90/100°F	
	32.2/17.78°C	

12.8

°C
Inlet Water

7.2

°C
Outlet Water

Pre-Cooled AHU - 1

Cooling Capacity	
Sensible (BTU)	737,500
	216.14kW
Total (BTU)	281,700
	82.56kW
Water Flow (GPM)	75.3
	17.10m³/h
Supply Fan (CFM)	7,800

Air Compressor Room

Pump Station

Air Compressor Room

Ventilation Fan Room

Pre-Cooled AHU - 2


Cooling Capacity	
Sensible (BTU)	2,516,720
	737.58kW
Total (BTU)	961,370
	281.75kW
Water Flow (GPM)	410
	93.12m³/h
Supply Fan (CFM)	29,690

Main Electrical Room

Generator Room

Benchmark

Typical Floor Area



Floor Area Distribution

	m ²	m ²	
Main Office Area	695.0	MEP Shaft	7.0
Secondary Office Area	29.4	AHU Room	24.1
Floor Entrance Foyer	36.6	Fresh air Shaft	2.4
Service Area	172.0	Electrical and Computer Room	8.5
		103	

Benchmark


Typical Floor Area - AHU System

8400
CFM

AHU - 1

9600
CFM

AHU - 2



Benchmark

Typical Floor Area - AHU System Energy Consumption

Air Handling Unit Schedule - 19th Floor

Unit No.	Chilled Water Requirement		Energy Consumption kWh/day (246days)
	GPM	kWh/Year	
AHU/1	47.76 10.85 m ³ /hr	17,670	71.83
AHU/2	54.5 12.38 m ³ /hr	13,732	55.82



Air Handling Units

Centralized System Energy Consumption - 19th Floor

Considering 10.6% of Energy Consumption

System	Average CDS CHS GPM	Total Avg. Energy Consumption kWh/day	19 th Floor Avg. Energy Consumption kWh/day
Screw Water Cooled Water Chiller	960 10.85 m ³ /hr	2240.89	237.5
Cooling Tower	570 10.85 m ³ /hr	58.67	6.22




Centralized
Cooling Systems


Benchmark

Energy Simulation

Existing Building Model



Proposed Application Model



North & South Facade
5 Systems/side

East & West Facade
8 Systems/side

26
Systems

Maximum no.
of Facade Integration

Preliminary Simulation Results - Existing Condition

Supply Air Condition	Supply Humidity Ratio (g/g)	Air Change Rate (ach)
Min. Supply Air temp. (°C)	0.0077	1.75
12.0		
134.31 kW Design Capacity	6.51 m³/s Design Flowrate	


Preliminary Simulation Results - Proposed System

Supply Air Condition	Supply Humidity Ratio (g/g)	Air Change Rate (ach)
Min. Supply Air temp. (°C)	0.0081	-
18.9		
82.24 kW Design Capacity	4.42 m³/s Design Flowrate	


Benchmark

Energy Simulation

Existing Building Model



Proposed Application Model



11
Systems

No. of Facade
System Required

Preliminary Simulation Results - Existing Condition

Supply Air Condition		
Min. Supply Air temp. (°C)	12.0	Supply Humidity Ratio (g/g)
	134.31	Air Change Rate (ach)
	kW	1.75
Design Capacity	6.51	m³/s
	Design Flowrate	Design Flowrate

Preliminary Simulation Results - Proposed System


Supply Air Condition		
Min. Supply Air temp. (°C)	18.9	Supply Humidity Ratio (g/g)
	82.24	Air Change Rate (ach)
	kW	-
Design Capacity	4.42	m³/s
	Design Flowrate	Design Flowrate

-52.07
kW
Design Capacity Reduction


-2.09
m³/s
Design Flowrate Reduction

System Application and Performances

Return air - Concept







Concept 1



Concept 2

System Application and Performances

Return air - Concept




System Evaluation

Calculation | Cross-Referencing

System Evaluation

Calculation Strategy



System Evaluation

Hourly Ambient Data

Hourly Ambient Air Data based on 8.00 - 18.00

Humidity Range	Temperature Range					
	<22.5°C	25°C	30°C	35°C	>37.5°C	
		≥22.5 - < 27.5 (°C)	≥27.5 - < 32.5 (°C)	≥32.5 - ≤37.5 (°C)		
>75%	6	300	329	-	-	629
70% ≥65 - ≤75%	12	99	806	13	-	918
60% ≥55 - <65%	22	72	750	374	-	1196
50% ≥45 - <55%	7	55	307	537	-	899
<45%	-	29	136	154	7	319
	6	555	2328	1078	7	

System Evaluation

Cross Referencing to Hourly Ambient Data

CCHE System Required

		Ambient Temperature Range		
		25°C ≥22.5 - < 27.5 (°C)	30°C ≥27.5 - < 32.5 (°C)	35°C ≥32.5 - ≤37.5 (°C)
Ambient Humidity Range ≥65 - ≤75%	70%	1 17.8°C 6.1 g kg 53.0%	3 17.2°C 5.3 g kg 40.8%	3 16.4°C 9.2g kg 65.5%
	60%	1 16.7°C 6.6 g kg 44.4%	2 16.8°C 5.4 g kg 38.0%	3 17.4°C 6.3 g kg 50.5%
	50%	1 19.4°C 5.0 g kg 33.0%	1 17.6°C 6.0 g kg 45.5%	2 18.0°C 6.8 g kg 53.1%

System Evaluation

Cross Referencing to Hourly Ambient Data

Cross Reference with Hourly Ambient Data

Humidity Range	Temperature Range					
	<22.5°C		25°C		30°C	
			≥22.5 - < 27.5 (°C)		≥27.5 - < 32.5 (°C)	
	-	6	-	300	-	329
>75%	-	6	-	300	-	329
70%	-	12	2	99	3	806
≥65 - ≤75%	-	12	2	99	3	806
60%	-	22	1	72	2	750
≥55 - <65%	-	22	1	72	2	750
50%	-	7	1	55	1	307
≥45 - <55%	-	7	1	55	1	307
<45%	-	-	1	29	1	136
					2	154
					-	7

System Evaluation

Cross Referencing to Hourly Ambient Data

Cross Reference with Hourly Ambient Data

Humidity Range	Temperature Range					
	<22.5°C		25°C	30°C	35°C	>37.5°C
			≥22.5 - < 27.5 (°C)	≥27.5 - < 32.5 (°C)	≥32.5 - ≤37.5 (°C)	
	>75%	-	6	-	300	-
70%	-	12	2	99	3	806
≥65 - ≤75%	-	22	1	72	2	750
60%	-	22	1	72	2	374
≥55 - <65%	-	7	1	55	1	307
50%	-	7	1	55	1	537
≥45 - <55%	-	-	1	29	1	136
<45%	-	-	1	29	1	154
						7



System Evaluation

Cross Referencing to Hourly Ambient Data

Cross Reference with Hourly Ambient Data

Humidity Range	Temperature Range					
	<22.5°C		25°C	30°C	35°C	>37.5°C
			≥22.5 - < 27.5 (°C)	≥27.5 - < 32.5 (°C)	≥32.5 - ≤37.5 (°C)	
	-	6	-	300	-	329
>75%	-	6	-	300	-	329
70%	-	12	2	99	3	806
≥65 - ≤75%	-	12	2	99	3	806
60%	-	22	1	72	2	750
≥55 - <65%	-	22	1	72	2	750
50%	-	7	1	55	1	307
≥45 - <55%	-	7	1	55	1	307
<45%	-	-	1	29	1	136
					2	154
						7



1 - CCHE



2 - CCHE

System Evaluation

Cross Referencing to Hourly Ambient Data

Cross Reference with Hourly Ambient Data

Humidity Range	Temperature Range					
	<22.5°C		25°C	30°C	35°C	>37.5°C
			≥22.5 - < 27.5 (°C)	≥27.5 - < 32.5 (°C)	≥32.5 - ≤37.5 (°C)	
	>75%	-	6	-	300	-
70%	-	12	2	99	3	806
≥65 - ≤75%	-	22	1	72	2	750
60%	-	7	1	55	1	307
≥55 - <65%	-	-	1	-	-	537
50%	-	-	1	-	-	-
≥45 - <55%	-	-	1	29	1	136
<45%	-	-	1	29	1	154
						7



1 - CCHE



2 - CCHE



3 - CCHE

System Evaluation

Cross Referencing to Hourly Ambient Data

Cross Reference with Hourly Ambient Data

Humidity Range	Temperature Range					
	<22.5°C		25°C	30°C	35°C	>37.5°C
			≥22.5 - < 27.5 (°C)	≥27.5 - < 32.5 (°C)	≥32.5 - ≤37.5 (°C)	
	>75%	-	6	-	300	-
70%	-	12	2	99	3	806
≥65 - ≤75%	-	22	1	72	2	750
60%	-	7	1	55	1	307
≥55 - <65%	-	-	1	29	1	136
50%	-	-	1	29	1	136
≥45 - <55%	-	-	1	29	1	136
<45%	-	-	1	29	1	136



1 - CCHE



2 - CCHE



3 - CCHE



3 - CCHE

Energy Assessment

Heat Pump Requirements

Heating Energy Requirement Based on Operable Hours

Component	No. of Operable Hours		Energy Consumption	
	Hours	kWh/day (11 Hours)	kWh	kWh/year
1 - CCHE	599	4.4	0.128	239.6
2 - CCHE	1540	8.7	0.171	1218.0
3 - CCHE	1180	13.1	0.037	1405.3
Total	3319			



Average Thermal Requirements

Heating with Air to Water Heat Pump Energy Consumption

COP = 3.5

Component	Energy Required		Energy Consumption	
	kWh/year		kWh/year	
1 - CCHE	239.6		68.5	
2 - CCHE	1218.0		348.0	
3 - CCHE	1405.3		401.5	
Total	2862.9		818	




Average Energy Requirement

Energy Assessment

26
Systems

Maximum no.
of Facade Integration




Facade Integrated
Components

5.40 kWh/day

2.70 kWh/day

70.2
kWh/day

Air to Water
Heat Pump



Total Energy Consumption


Energy Consumption Assessment

Daily Energy Consumption

Energy Consumption Reduction
in comparison to AHU

+64.9%

kWh/day




Energy Consumption Assessment

Daily Energy Consumption

Energy Consumption Reduction
in comparison to Conventional System

-43.4%

kWh/day




Energy Consumption Assessment

Annual Energy Consumption

Energy Consumption Reduction
in comparison to Conventional System

-36%

kWh/year




Design Development

Design Possibilities

Design Development

Design Base




Design Development

Achieving Buoyancy




Design Development

Achieving Buoyancy






Design Development

Achieving Buoyancy



Performance Assessment

PVT Concepts



Concept 1

PVT

7.7
sq.m

100%
Coverage Area

Total
Energy Production
kWh/day

392.5
Thermal Energy

79.2
Electricity Energy

Concept 2

PVT

2.0
sq.m

100%
Coverage Area

196.2
Thermal Energy

PV

5.7
sq.m

100%
Coverage Area

39.6
Electricity Energy

Concept 3

PVT

2.0
sq.m

100%
Coverage Area

101.9
Thermal Energy

PV

5.7
sq.m

50%
Coverage Area

29.3
Electricity Energy

Net Zero

71%

Electricity
Reduction Ratio

42%




Electricity
Reduction Ratio

28%

Electricity
Reduction Ratio

Performance Assessment

PV Concepts



Concept 3

PV

7.7
sq.m

100%
Coverage Area

58.7

Thermal Energy

Total
Energy Production
kWh/day

Concept 4

PV

7.7
sq.m

87%
Coverage Area

51.0

Thermal Energy

Concept 5

PV

7.7
sq.m

50%
Coverage Area

25.5

Thermal Energy

28%

Electricity
Reduction Ratio

24%

Electricity
Reduction Ratio

14%

Electricity
Reduction Ratio


Versatility

Design Integration


Design Possibilities

System Application

System Component Alteration




Resizing



Shading
Alteration


System Application

System Assembly




System Application


System Assembly - Prefabricated Component



1. Facade Bracket




2. Air Supply Component




3. Dehumidification Component

System Application


System Assembly - On-Site Adjustment




1. Unitized Glazing Unit



2. Air Supply Duct




3. Exterior Cladding



4. Interior Cladding

System Application

Concept 1 : Symmetrical Array Pattern



Symmetrical
Array Pattern



Every Floor



Standard Supply Unit





System Application

Concept 2 : 'Pakon' Alternating Pattern



System Application

Concept 2 : 'Pakon' Alternating Pattern



'Pakon'
Alternating Pattern



Every OtherFloor



Resized - Supply Unit




System Application

Concept 3 : Abstraction of Thai Pattern



System Application

Concept 3 : Abstraction of Thai Pattern




Abstraction
of Thai Pattern



Placement
according to design




Non-modular




System Maintenance

Interior Maintenance




System Maintenance

Exterior Maintenance



System Feasibility

Initial Investment



Conclusion


Limitations / Recommendations



Energy Consumption Reduction
in comparison to Conventional System



Limitations of performance data



System operation scheduling



Solar radiation analysis



Cost consideration



Architectural Application



Net Zero Approach

Maintenance aspects



"Achieving Sustainability is not as simple as snapping your fingers....."



*“But we are on track,
Paving a way for a sustainable future.”*



Thank You

**Desiccant Integrated
Facade System**

P5 Presentation

Natchai Suwannapruk
4738128

9 July 2019

