

Opportunities and challenges for large scale HT-ATES systems (PPT)

Bloemendal, Martin

Publication date

2019

Document Version

Final published version

Citation (APA)

Bloemendal, M. (2019). *Opportunities and challenges for large scale HT-ATES systems (PPT)*. DAP symposium 2019, Delft, Netherlands.

Important note

To cite this publication, please use the final published version (if applicable). Please check the document version above.

Copyright

Other than for strictly personal use, it is not permitted to download, forward or distribute the text or part of it, without the consent of the author(s) and/or copyright holder(s), unless the work is under an open content license such as Creative Commons.

Takedown policy


Please contact us and provide details if you believe this document breaches copyrights. We will remove access to the work immediately and investigate your claim.






Opportunities and challenges for large scale HT-ATES systems

Martin Bloemendal
2019-03-12



Geothermal Energy in NL







HT-ATES

- $>25^{\circ}\text{C}$
- Currently permitted as “pilot-projects”




High Temperature ATES
Houses, greenhouses & utility





Challenges

- Chemical & micro biological effects
- Clogging e.g. Deposition of CaCO_3
- Buoyancy flow



HT-ATES → Buoyancy



KWR

TU Delft

Multi partially penetrating wells

Freshwater surplus:

ASR Well

Basin

Greenhouse





Freshwater demand:

ASR Well

Basin

Greenhouse




Effects
Efficiency
GW-quality

HEATSTORE (geothermica funding)




EGC 19
field-trip

● Case study sites ● Demonstration sites



Sources of heat

- Geothermal
- Waste heat
- Solar heat
- Solar / wind power



Demand:
180 TJ/y


Direct from
DAP-well :
180TJ/y

Potential
DAP well:
>400TJ/y
(p50)

KWR

TU Delft

HT-ATES @ TUDelft



Add 15,000
houses to
Demand:
330 TJ/y

BACK-UP/
redundancy


Store:
~100TJ


~750,000 m³

KWR


TU Delft

HT-ATES @ TUDelft





number of ATEs systems [-]




Bloemendal, M. and N. Hartog (2018). "Analysis of the impact of storage conditions on the thermal recovery efficiency of low-temperature ATEs systems." *Geothermics* 17(C): 306-319.

20 --- 100 ----- 2000

10TJ ----- 100 TJ ----- 1PJ



Heat storage for district heating of Amsterdam



Take home message

- Some challenges to tackle, but:
- Aquifers = Time & Space
- HT-ATES is complementary to geothermal systems
- HT-ATES offers back-up/redundancy
- NL = ATES

Opportunities and challenges for large scale HT-ATES systems

DAP symposium 2019-03-12
dr.ir. Martin Bloemendal

+31 625179849

j.m.bloemendal@tudelft.nl



KWR

TU Delft