P5 BOOKLET

RELIGHT V&D HAARLEM: DAYLIGHTING IN A FORMER DEPARTMENT STORE

Mark van der Blom, 4596080



AR3AH105 Graduation Studio Adapting 20th Century Heritage: Vacant Heritage Main mentor: Lidy Meijers Second mentor (BT): Frank Koopman Research mentor: Hielkje Zijlstra Examination committee member: Leo van den Burg

June 29th 2021

Transformation framework



Existing situation with demolition

Transformation framework



New situation with interventions

Transformation framework



L

Existing situation with demolition

New situation with interventions



Demolition drawing of typical floor

В \blacklozenge 6300 С E 300 F G 3300 (\mathbf{H}) 6300 6300 6300 6300 N 2 3 5 4 (1)

Redesign of typical floor









Accessibility & use (evening)



Circulation & accessibility







Evening circulation

Public circulation library
Circulation to dwellingfloors
Logistics library
Emergency staircases
Transparant pivot doors



New context and entrances

- Pedestrian friendly zone
- Bicycle and car as guest road
- Car road + bus (50km/h)
- Parking spots for bicycles +
- Area for terrace horeca
- Entrance bicycle storage
- Dwellings' main entrance
- Entrance expedition

Main public entrance Verwulft





Day



Lower & Upper basement floor





- 3. Trashcans for dwellings
- 4. Installations space



Basement B1

1. Children Library 2. Playfull net for children to enter

3. Part focussed on playing

basement

- - and workshops 8. Storage
- 4. Part focussed on reading 5. Part focussed on picking books



- 7. Rooms for readingsessions
- 9. Public bicycle storage
- 10. Bicycle storage for dwellings





First floor

1. Mix of bookstacks and seats (focussed on adult and teen books) 2. Seats around atrium

- 3. Lecture space
- 4. Workshop space
- 5. (rentable) Meeting rooms
- 6. Exposition V&D
- 7. Storage

- 8. Gamelab
- 9. Futurelab





- 1. Mix of bookstacks and seats (focussed on studying)
- 2. Seats around atrium
- 3. Lecture space
- 4. Workshop space 5. (rentable) Meeting rooms
- 6. Exposition V&D
- 7. Storage
- 8. Pockets around atrium
- 9. Auditorium
- 10. Foyer auditorium
- 11. Cantine personnel



Third floor

1. Mix of bookstacks and seats (focussed on studying)

- 2. Seats around atrium 3. Lecture space
- 4. Workshop space
- 5. (rentable) Meeting rooms
- 6. Exposition V&D
- 7. Storage
- 8. Pockets around atrium 9. Auditorium





- 2. Seats around atrium 3. Lecture space
- 4. Workshop space
- 5. (rentable) Meeting rooms
- 6. Exposition V&D
- 7. Pockets around atrium
- 8. Archive reading room
- 9. Info desk to request archive material
- 10. Lockers
- 11. Private study room



Fifth floor

- 1. Archive reading room 2. Private study room
- 3. Storage archive
- 4. Exposition V&D
- 5. Entrance area dwellingfloor
- 6. Dwellings
- 7. Collective fitness space
- 8. Storage





Sixth floor

- 2. Entrance area collective spaces dwelling floor
- 3. Collective living room
- 4. Collective rooftop terrace
- 5. VVE meeting room
- 6. Collective multi use room
- 7. Collective laundry space
- 8. Storage
- 9. Installations space

Roof

Section



6300









Structure existing











Structure existing



Structure with intervention glass floor

P5 Booklet | Mark van der Blom





Spatial idea upper floors



Materiality upper floors



Spatial sequence main entrance





P5 Booklet | Mark van der Blom



The atrium

















Dwellings' entrance Gierstraat



New entrance dwellings in Gierstraat



Schematic elevation facade Gierstraat with intervention new entrance dwellings



View on new double heigh space for entrance dwellings (ground floor)

Spatial sequence of routing towards dwellings



1. View on circulation in existing staircase leading to dwellingfloors



3. View on entrancearea 6th floor with main collective living room and circulation to the dwellings around atrium



2. View on entrancearea 5th floor with a broad staircase leading towards the collective spaces and connecting the two dwellingfloors



4. View on circulation around atrium with recessed entrances of dwellings

Daylightmodel of lightwell







Daylight orientation 1: dwelling 5th floor view

Daylight orientation 2: dwelling 5th floor view



Daylight orientation 1: dwelling 6th floor view



Daylight orientation 2: dwelling 6th floor view



1. Mechanical ventilation, pre-heated

- 2. Floor heating for library and dwellings
- 3. Natural air inlet for by ventilation grille in new window (dwellings)
- 4. Mechanical air outlet by ventilatorunits on roof (dwellings)
- 5. Openable windows (dwellings)
- 6. Dynamic sunscreens to block sunlight, not daylight
- 7. Louvres as dynamic daylight reducing element
- 8. Heat pump with ground as source, open groundenergysystem (WKO) with two aquifers
- 9. South orientated solar panels for electricity
- 10. Water collection in basement to reuse for toilets and rooftop terrace dwellings 11. Air handling units placed on roof, provided with WTW by thermal wheel (n= 60-
- 90%).



Π

Principle heating in winter irt heatpump

- A. Fresh inlet air
- B. Fresh air comes into spaces
- C. Exhaust air is sucked out of spaces
- D. Expelled air out of building

- up the fresh inlet air in combination with the residual heat from the exhaust air

34



E. Heat pump gets warm water from ground and flows to floor heating system in building F. The warm water from the ground in the HP heats the pipe with water going up to the air handling unit G. The warm water of the pipe is used in the heat exchanger of the AHU (fresh air/fluid medium) to heat

Climate: summer situation



8. Louvres as dynamic daylight reducing element

9. Heat pump with ground as source, open groundenergysystem (WKO) with two aquifers

10. South orientated solar panels for electricity

11. Water collection in basement to reuse for toilets and rooftop terrace dwellings

12. Air handling units placed on roof, provided with WTW by thermal wheel (n= 60-90%).

Principle cooling in summer irt heatpump

A. Fresh inlet air

B. Fresh air comes into spaces C. Exhaust air is sucked out of spaces

D. Expelled air out of building

E. Heat pump gets cool water from ground and flows to floor cooling system in building F. The cool water from the ground in the HP cools the pipe with water going up to the air handling unit

G. The cool water of the pipe is used in the heat exchanger of the AHU (fresh air/fluid medium) to cool

down the fresh inlet air



Climate: thermal zones winter



Climate: thermal zones summer





21 to max 25 °C - these spaces are cooled alltime (when necessary) due to constantly used during the day (floor cooling)

22 to max 25°C - these spaces are cooled alltime (when necessary) due to constantly used during the day within openinghours (cooling by air + floor cooling) (medium to low occupancy, light activity)

22 to max 28 °C - cooling is necessary if atrium/void or circulation space gets too warm (cooling by air + floor cooling)

Exterior climate









First floor

20 to max 23 °C - these spaces are seperately cooled (when necessary) due to partly used during the day (cooling by air + floor cooling) (high





Acoustic zones in section

should be silent, no sound penetrating from adjacent spaces in different acoustic zone and vice versa

could be more noisy

Ventilation distribution principle



Second floor plan

Ventilation calculation from shaft 1 to library spaces spaces Beginning of ventilation ducts: Beginning of ventilation ducts: 677m2 * 3,5 m = 2370 m3 481m2 * 3,5 m = 1684 m3 1684 * 5/h = 8418 m3/h = 2,3382 m3/s 2370 * 5/h = 11848 m3/h = 3,29097 m3/s 3.29097 / 5m/s = 0.658 m2 = 6582 cm2 2.3382 / 5m/s = 0.4676 m2 = 4676 cm2 > 2 ventilation ducts of 60x40cm (rectangular) -> 3 ventilation ducts of 55x40cm (rectangular) Ventilation ducts in study area: Ventilation ducts in study area: 354m2 * 3,5m = 1239 m3 348m2 * 3.5m = 1218 m3 1218 * 5/h = 6090 m3/h = 1,6917 m3/s 1239 * 5/h = 6195 m3/h = 1,7208m3/s1.6917 / 5m/s = 0.3383 m2 = 3383 cm2 1,7208 / 5m/s = 0,3442 m2 = 3442 cm2 -> 2 ventilation ducts of 45x40cm (rectangular) > 2 ventilation ducts of 45x40cm (rectangular)

Ventilation calculation from shaft 2 to library

Ventilation calculation from shaft 2 to atrium 160m2 * 3.5 m = 560 m3 560 * 15/h = 8400 m3/h = 2,3333 m3/s

2,3333 / 5m/s = 0,4667 m2 = 4667 cm2 -> 1 ventilation duct of 120x40cm (rectangular)

Ventilation calculation size shaft 1

6¹ * 2370 m3 * 5/h = 71100 m3/h = 19,75 m3/s 19,75 / 10 m/s = 1,974 m2 = 19750 cm2 > vertical ventilation duct in shaft of 210x95cm (rectangular) (one for inlet and one for outlet) -> So 2 AHU's of around 36000 m3/h needed

Ventilation calculation size shaft 2:

6¹* 1684 m3 * 5/h + 7² * 560 m3 * 15/h + 1123 m3 * 7/h = 117181 m3/h = 32,550 m3/s 32,55 / 10 m/s = 3,255 m2 = 32550 cm2 > vertical ventilation duct in shaft of 260x130cm (rectangular) (one for inlet and one for outlet) -> So 3 AHU's of around 40000 m3/h needed

amount of floors connected to this shaft for ventilation, volume of floor is estimated by taking one floor for example amount of floors where atrium is at (so ground floor till 6th floor)



Third floor plan

Ventilation calculation from shaft 1 to library	Ventilation calculation from shaft 2 to library	Ventilation calculation from shaft 2 to atrium
spaces	spaces	160m2 * 3,5 m = 560 m3
Beginning of ventilation ducts:	Beginning of ventilation ducts:	560 * 15/h = 8400 m3/h = 2,3333 m3/s
677m2 * 3,5 m = 2370 m3	476m2 * 3,5 m = 1666 m3	2,3333 / 5m/s = 0,4667 m2 = 4667 cm2
2370 * 5/h = 11848 m3/h = 3,29097 m3/s	1666 * 5/h = 8330 m3/h = 2,3129 m3/s	-> 1 ventilation duct of 120x40cm (rectangular)
3,29097 / 5m/s = 0,658 m2 = 6582 cm2	2,3139 / 5m/s = 0,4628 m2 = 4628 cm2	
-> 3 ventilation ducts of 55x40cm (rectangular)	-> 2 ventilation ducts of 60x40cm (rectangular)	Ventilation calculation from shaft 2 to
		auditorium
Ventilation ducts in study area:	Ventilation ducts in study area:	156m2 * 7,2m = 1123 m3
348m2 * 3,5m = 1218 m3	354m2 * 3,5m = 1239 m3	1123 * 7/h = 7861 m3/h = 2,184 m3/s
1218 * 5/h = 6090 m3/h = 1,6917 m3/s	1239 * 5/h = 6195 m3/h = 1,7208m3/s	2,184 / 5m/s = 0,4368 m2 = 4368 cm2
1,6917 / 5m/s = 0,3383 m2 = 3383 cm2	1,7208 / 5m/s = 0,3442 m2 = 3442 cm2	-> 2 ventilation ducts of 55x40cm (rectangular)
-> 2 ventilation ducts of 45x40cm (rectangular)	-> 2 ventilation ducts of 45x40cm (rectangular)	



40









-10mm gray acoustic spray by Asona (same

texture as concrete)







Vertical 1:5 detail, scaled

Vertical 1:5 detail, scaled

oak board 30mm as top finish parapet with integrated octogonal shaped handrail

	5 5 5	
0		
,		
	4	
· · · · ·	4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4 4	
)	-oak boards 8mm + PU rubber underlay 2mm -2x 9mm Fermacell floorplates with milled floorheatingtubes with 2mm egaliseermiddel	
×>>	(alphahalfhydraat) on top	
E Color	-10mm polystyreenhardschuim (XPS) for	
S.	thermal insulation (pressure resistant)	
	-10mm fiberboard to reduce sound and	
	heighten fire resistancy (pressure resistant)	
	-concrete floor 140mm	