



RENOVATION FOR DIFFERENT ENERGY SYSTEMS

Prefabricated renovation approach for post-war walk-up apartments that is applicable to different energy systems



Jessie Hoondert
Dr. ing. Msc Thaleia Konstantinou
Dr. ir. Sabine Jansen
Dr. Marcin Dąbrowski

GLOBAL ENERGY RELATED CO2 EMISSIONS - 2015



Adapted from (UN Environment and International Energy Agency, 2017)



Reprinted from (Hiveminer, n.d.)

RESIDENTIAL BUILDING STOCK EU


- Energy and CO2 emission targets of 2050
- Reduction needed up to 90%
- New buildings only add 1%
- Remaining 99% is already built



Reprinted from (Delft University of Technology, n.d.)

POST-WAR WALK-UP APARTMENTS (Naoorlogse portiekwoningen)

- Post-war walk-up is 8% of total building stock in the Netherlands
- 70% of which is social housing
- In 2020 all rental dwellings with energy label B



ENERGY SYSTEMS

- Reuse sources


A.- District heating

B.- Aquifer

C.- Heat pump with outdoor air


D.- Heat pump with PVT panels

RESEARCH QUESTION




'What prefabricated renovation approach for post-war walk-up apartments is applicable to accommodate energy saving measures, depending on different energy systems?'


METHODOLOGY




METHODOLOGY



METHODOLOGY



METHODOLOGY



SOENDALAAN VLAARDINGEN

- Building constructed in 1952
- 12 apartments
- Three stories high
- Central staircase, characteristic for walk-up apartment building



Reprinted from (Stedenbouw & Van der Beek, 2018)

SOENDALAAN VLAARDINGEN


- Unoccupied attic
- Symmetric facade lay-out
- Balconies are cold connected
- Kitchen and bathroom located at balcony side







Reprinted from (Climate-KIC, n.d.)

CONSTRUCTION



- Prefabricated concrete elements
- Not possible to remove parts of facade
- Simplex - Aircavity - Masonry





Reprinted from (Van Elk & Priemus, 1971)

| | HIGH TEMPERATURE | LOW TEMPERATURE |
|--------------------|--|---|
| COLLECTIVE SYSTEMS | A  | B  |
| INDIVIDUAL SYSTEMS | D  | C  |



CONCEPT A
DISTRICT HEATING
(Stadsverwarming)




CONCEPT A
HIGH TEMPERATURE THERMAL GRID



CONCEPT B
AQUIFER





WINTER





SUMMER



CONCEPT B
LOW TEMPERATURE THERMAL GRID





CONCEPT C - D
HEAT PUMP





External
heat source





CONCEPT C
OUTDOOR AIR




CONCEPT D
PVT PANELS











INPUT MEASURES

SOFTWARE UNIEC^{2.2}

| EAST FACADE | Facade openings [m2] | Glazing [m2] | Window frames [m2] | Pieces [#] | All facade openings [m2] | All glazing [m2] | All window frames [m2] |
|---------------------------------|----------------------|--------------|--------------------|------------|--------------------------|------------------|------------------------|
| Openings | | | | | | | |
| Window 1 | 2,0 | 1,7 | 0,3 | 2 | 4,0 | 3,4 | 0,6 |
| Window 2 | 2,0 | 1,5 | 0,5 | 4 | 8,0 | 6,0 | 2,0 |
| TOTAL OPENINGS AREA [m2] | | | | | 12,0 | 9,4 | 2,6 |
| TOTAL FACADE AREA | | | | | 85,8 | | |
| TOTAL OPENINGS AREA [m2] | | | | | 12,0 | - | |
| TOTAL CLOSED AREA | | | | | 73,8 | | |



| WEST FACADE | Facade openings [m2] | Glazing [m2] | Window frames [m2] | Pieces [#] | All facade openings [m2] | All glazing [m2] | All window frames [m2] |
|---------------------------------|----------------------|--------------|--------------------|------------|--------------------------|------------------|------------------------|
| Openings | | | | | | | |
| Window 1 | 2,0 | 1,7 | 0,3 | 2 | 4,0 | 3,4 | 0,6 |
| Window 2 | 2,0 | 1,5 | 0,5 | 4 | 8,0 | 6,0 | 2,0 |
| TOTAL OPENINGS AREA [m2] | | | | | 12,0 | 9,4 | 2,6 |
| TOTAL FACADE AREA | | | | | 85,8 | | |
| TOTAL OPENINGS AREA [m2] | | | | | 12,0 | - | |
| TOTAL CLOSED AREA | | | | | 73,8 | | |



INPUT MEASURES

| OVERVIEW Measures in Uniec | Concept A External heat supply >70°C | |
|-------------------------------|--|--|
| | A. Low | A. High |
| Building envelope | | |
| Rc-value Floor | 2,6 | 3,7 |
| Rc-value Facade | 2,1 | 4,6 |
| Rc-value Roof | 6,1 | 6,1 |
| Rc-value internal wall | 0,1 | 0,1 |
| U-value glazing | 1,2 | 0,7 |
| Heating systems | | |
| External heat supply | City grid Amsterdam Zuid-Oost - primary grid | |
| Delivery temperature | >50°C | |
| Ventilation | | |
| System | Inlet: Natural Exhaust: Mechanic | Inlet: Mechanic Exhaust: Mechanic |
| Product | Itho Daalderop CO2 Optima NGG | Itho Daalderop HRU ECO 350 Optima 2 CO2 |
| PV panels | | |
| Peak power | 180 Wp/m2 | |
| RFpv | Z=1,00 N=0,70 | |
| Number/orientation | 150m2 | 29° |

| OVERVIEW Measures in Uniec | Concept B External heat supply ≈20°C | |
|-------------------------------|--|--|
| | B. Low | B. High |
| Building envelope | | |
| Rc-value Floor | 2,6 | 3,7 |
| Rc-value Facade | 2,1 | 4,6 |
| Rc-value Roof | 6,1 | 6,1 |
| Rc-value internal wall | 0,1 | 0,1 |
| U-value glazing | 1,2 | 0,7 |
| Heating systems | | |
| System | Combi-heat pump | |
| Source | Groundwater | |
| Product | Itho Daalderop WPU 25 5G + buffertank WPV150 | |
| COp heating | 4,85 | 5,70 |
| COp DHW | 3,45 | 3,70 |
| COp additional heating | 1,00 | 1,00 |
| Supply temperature | 50° < Θsup ≤ 55° | 35° < Θsup ≤ 40° |
| Delivery temperature | >50°C | ≤ 50°C |
| Ventilation | | |
| System | Inlet: Natural Exhaust: Mechanic | Inlet: Mechanic Exhaust: Mechanic |
| Product | Itho Daalderop CO2 Optima NGG | Itho Daalderop HRU ECO 350 Optima 2 CO2 |
| PV panels | | |
| Peak power | 180 Wp/m2 | |
| RFpv | Z=1,00 N=0,70 | |
| Number/orientation | 150m2 | 29° |


INPUT MEASURES

| OVERVIEW Measures in Uniec | | Concept A External heat supply >70°C | |
|-------------------------------|-------------------------------|--|---|
| | | A. Low | A. High |
| Building envelope | | | |
| | OVERVIEW Measures in Uniec | Concept C Outdoor air | |
| | | C. Low | C. High |
| Building envelope | | | |
| Heating systems | Rc-value Floor | 2,6 | 3,7 |
| | Rc-value Facade | 2,1 | 4,6 |
| | Rc-value Roof | 6,1 | 6,1 |
| | Rc-value internal wall | 0,1 | 0,1 |
| | U-value glazing | 1,2 | 0,7 |
| Heating systems | | | |
| | System | Combi-heat pump | |
| | Source | Outdoor air | |
| Ventilation | | | |
| | Product | Itho Daalderop HP-S 55 + buffertank SVV 200l | |
| PV panels | | | |
| | COp heating | 3,80 | 4,20 |
| | COp DHW | 1,75 | 1,75 |
| | COp additional heating | 1,00 | 1,00 |
| | Supply temperature | 50° < Θ_{sup} ≤ 55° | 35° < Θ_{sup} ≤ 40° |
| | Delivery temperature | >50°C | ≤ 50°C |
| Cooling | | | |
| | System | Compression cooling machine | |
| | Specification | HT-delivery system | |
| Ventilation | | | |
| | System | Inlet: Natural Exhaust: Mechanic | Inlet: Mechanic Exhaust: Mechanic |
| | Product | Itho Daalderop CO2 Optima NGG | Itho Daalderop HRU ECO 350 Optima 2 CO2 |
| PV panels | | | |
| | Peak power | 180 Wp/m2 | |
| | RFpv | Z=1,00 N=0,70 | |
| | Number/orientation | 150m2 | 29° |





| OVERVIEW Measures in Uniec | | Concept B External heat supply =20°C | |
|-------------------------------|-------------------------------|--|---|
| | | D. Low | D. High |
| Building envelope | | | |
| | OVERVIEW Measures in Uniec | Concept D PVT panels | |
| | | D. Low | D. High |
| Building envelope | | | |
| | Rc-value Floor | 2,6 | 3,7 |
| | Rc-value Facade | 2,1 | 4,6 |
| | Rc-value Roof | 6,1 | 6,1 |
| | Rc-value internal wall | 0,1 | 0,1 |
| | U-value glazing | 1,2 | 0,7 |
| Heating systems | | | |
| | System | Combi-heat pump | |
| | Source | Ground | |
| | Product | Nibe F1255-6 (PC) with Triple Solar source | |
| | COp heating | 5,05 | |
| | COp DHW | 3,50 | |
| | COp additional heating | 1,00 | |
| | Supply temperature | 30° < Θ_{sup} ≤ 35° | |
| | Delivery temperature | > 50°C | ≤ 50°C |
| Ventilation | | | |
| | System | Inlet: Natural Exhaust: Mechanic | Inlet: Mechanic Exhaust: Mechanic |
| | Product | Itho Daalderop CO2 Optima NGG | Itho Daalderop HRU ECO 350 Optima 2 CO2 |
| PV panels | | | |
| | Peak power | 180 Wp/m2 | |
| | RFpv | S=1,00 N=0,70 | |
| | Number/orientation | 75 m2 (S) 150m2(N) | 29° |
| PVT panels | | | |
| | Peak power | 165 Wp/m2 | |
| | RFpv | S = 1,00 | |
| | Number/orientation | 75m2 | 29° |

RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|--|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |







RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|---|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |




RESULTS

Final energy consumption all concepts







RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|--|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |







RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|---|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |







RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|---|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |







RESULTS

Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|---|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |







RESULTS


Final energy consumption all concepts




| | A. Low | A. High | B. Low | B. High | C. Low | C. High | D. Low | D. High |
|--|--------|---------|--------|---------|--------|---------|--------|---------|
| ■ User related electricity [kWh] | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 | 1.506 |
| ■ Building related electricity [kWh] | 617 | 572 | 1.675 | 1.245 | 2.510 | 1.912 | 1.604 | 1.237 |
| ■ External heat supply [kWh] (converted from MJ) | 2.685 | 1.759 | 0 | 0 | 0 | 0 | 0 | 0 |
| ● Produced electricity [kWh] | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.798 | 3.541 | 3.541 |



BUILDING ENVELOPE




BUILDING ENVELOPE




BUILDING SERVICES

| Concept A: External heat supply >70°C | | Dimensions [mm] L x W x H | Weight [kg] | Requirements estimation |
|---|---|--------------------------------------|--------------------|---|
| 1. Sub-station EcoMechanic | | 588 x 258 x 493 | 9 | Inlet – outlet city grid |
| 2. Ventilation | 2a. CO2 regulated Itho Daalderop Optima Flow system | 355 x 294 x 350 | 3,5 | Electricity, air outlet |
| | 2b. WTW Itho Daalderop HRU ECO 200 E | 597 x 290 x 916 | 12 | Electricity, air outlet, air inlet, condensation drain |
| 3. PV CSUN 255-60P | 1 panel | 990 x 35 x 1640 | 18,3 | Electricity |




BUILDING SERVICES

| Concept B: External heat supply $\approx 20^{\circ}\text{C}$ | | Dimensions [mm] L x W x H | Weight [kg] | Requirements estimation |
|--|--|------------------------------|-------------|--|
| 1. Sub-station EcoMechanic | | 588 x 258 x 493 | 9 | Inlet – outlet city grid |
| 2. Heat pump Itho Daalderop WPU 5G | 2a. Heat pump only | 600 x 600 x 830 | 85 | Electricity, water inlet, water outlet |
| | 2b. <i>Optional: Buffer tank Itho Daalderop I-SVV 200l</i> | 1486,5 x \varnothing 595 | 56 (empty) | <i>Electricity, water inlet, CV supply, CV outlet</i> |
| | 2c. In combination with buffer tank 200l | 600 x 600 x 2103 | | Electricity, water inlet, CV supply, CV outlet |
| 3. Ventilation | 3a. CO2 regulated Itho Daalderop Optima Flow system | 355 x 294 x 350 | 3,5 | Electricity, air outlet |
| | 3b. WTW Itho Daalderop HRU ECO 200 E | 597 x 290 x 916 | 12 | Electricity, air outlet, air inlet, condensation drain |
| 3. PV CSUN 255-60P | 1 panel | 990 x 35 x 1640 | 18,3 | Electricity |




BUILDING SERVICES

| Concept C: Outdoor air | | Dimensions [mm] L x W x H | Weight [kg] | Requirements estimation |
|--|---|------------------------------|-------------|--|
| 1. Heat pump Itho Daalderop HP-s 55 | 1a. Indoor unit | 505 x 288 x 790 | 45 | Electricity, outdoor air, CV supply, CV outlet |
| | 1b. Outdoor unit | 934 x 354 x 753 | 62,5 | Electricity, outdoor air, air outlet |
| 2. Buffer tank Itho Daalderop I-SVV 200I | | 1486,5 x Ø595 | 56 (empty) | Electricity, water inlet, CV supply, CV outlet |
| 3. Ventilation | 3a. CO2 regulated Itho Daalderop Optima Flow system | 355 x 294 x 350 | 3,5 | Electricity, air outlet |
| | 3b. WTW Itho Daalderop HRU ECO 200 E | 597 x 290 x 916 | 12 | Electricity, air outlet, air inlet, condensation drain |
| 4. PV CSUN 255-60P | 1 panel | 990 x 35 x 1640 | 18,3 | Electricity |






BUILDING SERVICES



| Concept D: PVT | | Dimensions [mm] L x W x H | Weight [kg] | Requirements estimation |
|-----------------------------------|---|--------------------------------------|--------------------|---|
| 1. Heat pump NIBE-F1255-6 | In combination with buffer tank 180l | 600 x 620 x 1800 | 240 | Electricity, water inlet, water outlet, CV supply, CV outlet |
| 2. Ventilation | 2a. CO2 regulated Itho Daalderop Optima Flow system | 355 x 294 x 350 | 3,5 | Electricity, air outlet |
| | 2b. WTW Itho Daalderop HRU ECO 200 E | 597 x 290 x 916 | 12 | Electricity, air outlet, air inlet, condensation drain |
| 3. PVT Triple Solar M2 285 165 | 1 panel | 995 x 65 x 1668 | 27 | Electricity, water inlet, water outlet |




CONCEPT B



CONCEPT C






900





950


CONCEPT D





CONCEPT A




FLOOR PLAN




SUBSTRUCTURE




LOW IMPACT






LOW IMPACT




FLOOR PLAN




FULLY PREFABRICATED ELEMENTS




HIGH IMPACT







HIGH IMPACT



HIGH IMPACT




FLOOR PLAN






LOW IMPACT




HIGH IMPACT

CONCLUSION




‘What prefabricated renovation approach for post-war walk-up apartments is applicable to accommodate energy saving measures, depending on different energy systems?’

TEMPLATE DESIGN







Low impact




High impact


ENERGY SYSTEMS




HOUSING CORPORATION OR HOMEOWNER ASSOCIATION




HOUSING CORPORATION OR HOMEOWNER ASSOCIATION




HOUSING CORPORATION OR HOMEOWNER ASSOCIATION



HOUSING CORPORATION OR HOMEOWNER ASSOCIATION




HOUSING CORPORATION OR HOMEOWNER ASSOCIATION




'INDISCHE BUURT' VLAARDINGEN


- 195 walk-up apartments
- 129 East-West orientation
- 66 North-South orientation




SCENARIO 1




SCENARIO 2



SCENARIO 3: EAST-WEST ORIENTATION





SCENARIO 3: NORTH-SOUTH ORIENTATION




COMPARISON WITH EXISTING SITUATION

SCENARIO 1



2,9
TIMES
Less Energy

SCENARIO 2



5,0
TIMES
Less Energy



SCENARIO 3



4,4
TIMES
Less Energy



COMPARISON WITH EXISTING SITUATION

SCENARIO 1



2,9
TIMES
Less Energy

SCENARIO 2



5,0
TIMES
Less Energy



SCENARIO 3



4,4
TIMES
Less energy

COMPARISON WITH EXISTING SITUATION

SCENARIO 1




2,9

TIMES

Less Energy

SCENARIO 2





5,0

TIMES

Less Energy

SCENARIO 3



4,4


TIMES

Less Energy

COST ASSESSMENT OF DIFFERENT ENERGY CONCEPTS

UPSCALING TO DIFFERENT BUILDING TYPES

CIRCULARITY OF THE APPROACH



THANK YOU!

